

SECHLT, BC, Canada

WMO: 716380

Lat: 49.4581N

Lon: 123.7153W

Elev: 86

StdP: 100.30

Time Zone: -8.00 (NAP)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-4.3	-3.0	-11.5	1.4	-1.7	-7.8	2.0	-1.0	9.3	8.2	8.6	7.9	1.6	330	0.499

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	27.4	17.4	25.3	16.9	23.5	16.4	18.5	24.9	17.7	23.5	17.0	22.2	1.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.0	11.5	20.7	15.3	11.0	20.1	14.7	10.5	19.5	52.4	24.6	50.0	23.8	47.9	22.3	21.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.7	6.4	5.5	-7.1	31.4	1.6	1.8	-8.3	32.8	-9.3	33.8	-10.2	34.8	-11.3	36.2
			-8.1	20.0	1.8	1.1	-9.4	20.8	-10.5	21.4	-11.5	22.0	-12.8	22.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.0	3.9	4.0	6.1	8.6	12.6	15.0	17.7	17.8	14.5	9.8	6.1	3.3		
	DBStd	5.86	3.01	3.06	2.62	2.30	2.78	2.63	2.28	2.22	2.59	2.38	3.30	3.10		
	HDD10.0	909	191	168	123	54	8	0	0	0	1	33	123	209		
	HDD18.3	3102	448	401	379	293	179	107	38	38	117	265	368	468		
	CDD10.0	899	0	1	2	12	87	149	239	241	137	26	5	1		
	CDD18.3	50	0	0	0	0	0	7	19	21	3	0	0	0		
	CDH23.3	431	0	0	0	1	12	67	168	152	30	0	0	0		
	CDH26.7	87	0	0	0	0	0	14	39	29	4	0	0	0		
(14) Wind	WSAvg	2.1	2.3	2.1	2.6	2.4	1.9	2.0	1.8	1.8	1.8	2.1	2.4	2.3		
(15) Precipitation	PrecAvg	1564	221	151	142	99	75	64	43	50	69	172	236	229		
	PrecMax	1849	382	275	245	188	116	118	78	201	165	295	407	292		
	PrecMin	1264	146	49	55	41	25	24	11	9	20	59	125	160		
	PrecStd	162	61	49	38	38	24	25	17	45	37	59	74	37		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.1	12.0	16.0	20.6	25.0	28.6	30.4	29.8	26.6	18.7	15.3	12.3		
		MCWB	9.8	9.0	10.1	12.2	14.4	16.9	18.7	17.7	17.0	13.1	12.2	9.7		
	2%	DB	10.7	10.7	13.4	16.6	22.4	25.3	27.2	27.0	23.6	16.6	13.3	10.1		
		MCWB	8.6	8.2	9.0	10.3	14.0	16.1	17.6	17.8	15.9	12.8	11.4	8.3		
	5%	DB	9.5	9.5	11.6	14.4	20.1	22.1	25.0	24.8	21.3	15.0	11.9	8.8		
		MCWB	7.8	7.3	8.2	9.4	13.3	15.2	17.1	17.4	15.4	12.1	10.1	7.4		
	10%	DB	8.4	8.4	10.4	12.7	17.9	19.8	23.1	22.9	19.2	13.9	10.8	7.9		
		MCWB	6.9	6.6	7.8	8.8	12.7	14.3	16.5	16.8	14.6	11.4	9.2	6.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.4	10.5	11.0	12.7	15.8	18.4	20.0	19.4	18.1	14.9	13.1	10.6		
		MCDB	11.6	11.5	14.5	18.3	22.1	25.4	27.8	26.1	23.8	16.8	14.3	11.8		
	2%	WB	9.1	8.8	9.6	11.4	14.8	17.1	18.5	18.5	16.9	13.6	11.6	8.6		
		MCDB	10.2	9.8	12.3	15.3	20.2	23.9	25.2	24.6	21.5	15.5	13.1	9.7		
	5%	WB	7.9	7.6	8.7	10.3	14.0	15.7	17.6	17.8	16.0	12.5	10.4	7.6		
		MCDB	9.2	8.9	11.0	13.3	18.8	20.8	23.5	23.5	20.1	14.4	11.7	8.6		
	10%	WB	7.0	6.7	7.9	9.4	13.1	14.8	16.8	17.1	15.1	11.5	9.4	6.6		
		MCDB	8.4	8.2	10.0	11.9	17.3	19.0	22.2	22.1	18.3	13.5	10.6	7.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.0	5.9	6.8	7.8	8.8	8.2	9.6	9.3	8.3	6.7	5.7	4.8		
		MCDBR	5.7	6.7	8.7	10.8	13.1	13.1	13.7	13.4	12.3	8.4	5.7	5.0		
	5% WB	MCWBR	4.0	4.6	5.3	6.0	6.3	5.8	5.9	6.2	6.4	5.4	4.1	3.7		
		MCWBR	5.3	5.6	7.7	8.9	10.9	11.1	12.2	11.7	10.1	7.1	5.6	4.9		
(40) Clear-Sky Solar Irradiance	taub	taub	0.313	0.305	0.329	0.358	0.374	0.369	0.356	0.356	0.337	0.330	0.313	0.301		
		taud	2.444	2.518	2.466	2.414	2.405	2.432	2.503	2.509	2.563	2.557	2.528	2.467		
	Ebn at Noon	Ebn at Noon	741	855	885	889	886	891	897	882	869	812	743	707		
		Edh at Noon	63	73	91	106	112	110	101	96	82	70	58	54		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.83	1.69	2.50	3.92	5.16	5.51	6.18	5.27	3.63	1.98	0.98	0.66		
	RadStd	RadStd	0.14	0.27	0.36	0.43	0.48	0.69	0.59	0.44	0.33	0.30	0.19	0.10		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (62 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page