

BOUCTOUCHE, NB, Canada

WMO: 716660

Lat: 46.431N

Lon: 64.767W

Elev: 118

StdP: 14.63

Time Zone: -4.00 (NAA)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -6.7	(c) -2.6	(d) -15.6	(e) 2.4	(f) -5.2	(g) -11.1	(h) 3.0	(i) -0.4	(j) 25.3	(k) 26.6	(l) 22.9	(m) 28.3	(n) 8.0	(o) 230	(p) 0.592

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.0	83.9	69.4	81.2	67.9	78.3	66.2	71.8	80.5	70.3	77.6	68.7	75.2	10.0	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.0	107.1	75.8	67.6	101.7	74.8	66.1	96.6	73.1	35.7	81.3	34.3	77.5	33.0	75.2	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 21.2	(b) 18.6	(c) 16.4	(e) -14.4	(f) 89.7	(g) 4.3	(h) 2.8	(i) -17.5	(j) 91.8	(k) -20.0	(l) 93.4	(m) -22.4	(n) 95.0	(o) -25.6	(p) 97.0		
(4) 21.2	(5) 18.6	(6) 16.4	(7) -14.8	(8) 74.8	(9) 4.2	(10) 1.2	(11) -17.9	(12) 75.6	(13) -20.4	(14) 76.3	(15) -22.7	(16) 76.9	(17) -25.8	(18) 77.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.1	18.7	19.2	27.0	38.8	50.4	59.7	67.9	66.1	58.5	47.4	36.5	24.8	
	DBStd	19.09	11.60	10.40	9.24	7.72	7.45	6.35	5.44	5.17	7.22	7.46	9.07	10.23	
	HDD50	4330	971	863	715	347	87	3	0	0	10	141	413	780	
	HDD65	8271	1436	1283	1179	785	456	184	33	50	218	548	854	1245	
	CDD50	1796	0	0	2	12	100	294	554	500	265	60	9	0	
	CDD65	258	0	0	0	0	4	24	122	84	23	1	0	0	
	CDH74	1799	0	0	2	4	66	181	855	538	150	3	0	0	
	CDH80	358	0	0	0	0	10	27	200	93	28	0	0	0	
Wind	WSAvg	7.9	8.6	8.7	9.1	8.8	8.2	7.1	6.6	6.2	7.1	7.7	8.4	8.4	
Precipitation	PrecAvg	44.4	3.5	3.1	3.7	3.2	3.5	3.7	3.8	3.4	4.0	4.3	3.8	4.1	
	PrecMax	57.4	5.8	5.0	7.7	5.6	7.1	6.6	6.5	7.7	8.6	7.6	7.0	9.6	
	PrecMin	35.4	1.4	1.1	1.7	1.5	1.1	1.2	1.3	1.0	1.2	1.2	1.6	1.5	
	PrecStd	5.6	1.2	1.1	1.4	1.1	1.4	1.3	1.2	1.7	2.0	2.0	1.5	1.6	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.3	49.8	58.5	71.4	81.1	83.9	88.5	86.0	84.1	73.4	64.6	54.5	
		MCWB	51.7	46.2	47.3	58.8	63.4	65.7	72.0	70.7	71.2	63.6	61.9	52.6	
	2%	DB	44.9	42.5	48.0	62.3	74.6	78.9	84.7	82.7	78.1	67.1	59.6	47.7	
		MCWB	43.5	39.8	42.2	53.9	60.2	65.1	70.4	69.0	66.7	59.2	56.2	46.2	
	5%	DB	39.4	37.6	43.1	57.0	69.1	75.4	82.1	79.7	74.2	63.4	55.2	42.7	
		MCWB	37.4	34.3	38.5	50.1	57.3	64.0	68.9	67.2	65.4	58.6	51.4	41.1	
	10%	DB	34.5	33.8	39.5	52.2	64.0	72.1	79.0	76.7	70.6	59.7	50.6	38.5	
		MCWB	32.9	31.9	35.2	45.2	54.7	61.7	67.2	65.8	63.5	54.8	47.2	36.8	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.8	47.2	50.8	60.7	66.7	70.5	74.3	73.4	71.7	65.3	62.3	52.8
			MCDB	53.2	49.5	56.8	66.1	76.2	78.2	84.2	82.1	80.9	68.9	64.5	54.1
2%		WB	43.9	40.1	43.9	55.6	62.7	68.2	72.4	71.2	69.2	62.0	57.0	46.5	
		MCDB	44.8	42.4	47.0	59.8	70.9	75.2	81.9	78.7	74.9	65.6	59.0	47.7	
5%		WB	37.5	35.2	39.1	50.8	59.5	65.8	70.9	69.6	67.0	58.9	52.2	41.3	
		MCDB	39.1	37.1	42.2	55.2	66.0	72.6	79.2	76.3	72.2	62.6	54.5	42.5	
10%		WB	33.1	32.2	35.5	45.9	56.1	63.3	69.2	67.9	64.7	55.4	47.2	37.0	
		MCDB	34.3	33.5	39.1	51.3	62.9	69.9	76.1	74.2	70.1	58.7	49.7	38.0	
Mean Daily Temperature Range		5% DB	MDBR	16.6	17.0	15.9	16.2	18.8	17.5	18.0	18.2	18.6	16.2	14.2	13.8
			MCDBR	21.0	19.3	19.8	26.1	28.4	23.2	22.0	22.4	21.9	20.6	20.1	17.4
	MCWBR		20.7	17.1	15.3	18.2	16.4	13.1	10.6	11.5	13.1	14.9	17.5	17.4	
	5% WB	MCDBR	20.8	19.5	18.1	23.2	24.0	20.1	18.8	18.1	19.1	17.8	18.8	17.7	
		MCWBR	20.5	18.0	16.0	18.4	16.1	12.4	10.4	10.8	12.9	14.6	18.0	17.8	
Clear-Sky Solar Irradiance	taub	0.287	0.283	0.320	0.346	0.367	0.387	0.414	0.389	0.356	0.327	0.306	0.284		
	taud	2.412	2.388	2.389	2.418	2.408	2.345	2.307	2.371	2.451	2.530	2.535	2.498		
	Ebn at Noon	259	285	288	289	285	279	269	272	272	266	252	249		
	Edh at Noon	22	27	32	34	36	38	40	36	30	24	20	18		
All-Sky Solar Radiation	RadAvg	451	672	1057	1331	1572	1697	1745	1526	1218	766	425	329		
	RadStd	41	67	68	134	166	130	120	102	107	75	51	32		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (32 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page