

OOTSA LAKE SKINS LAKE, BC, Canada

WMO: 716790

Lat: 53.7719N

Lon: 125.9967W

Elev: 2825

StdP: 13.26

Time Zone: -8.00 (NAP)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-14.2	-7.7	-19.6	2.1	-12.6	-13.1	3.0	-6.1	26.3	33.3	22.8	34.6	3.1	50	0.695

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	18.5	76.5	58.9	72.8	57.6	69.3	56.3	60.7	73.0	58.9	69.8	57.3	67.3	7.4	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.7	73.5	64.9	54.0	69.0	62.9	52.6	65.3	61.5	28.1	73.4	26.8	70.0	25.8	67.7	70.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.4	19.1	16.4	DB	-20.2	83.1	7.5	4.0	-25.6	86.0	-29.9	88.3	-34.1	90.5	-39.6	93.4	
			WB	-20.5	65.0	7.4	2.6	-25.8	66.8	-30.1	68.3	-34.3	69.8	-39.6	71.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	38.1	20.4	18.9	26.6	35.6	46.1	52.0	57.8	57.7	50.2	40.3	29.6	21.0	(6)
(7)		DBStd	16.31	12.47	12.19	9.51	5.61	5.67	5.19	5.11	5.21	5.73	5.96	9.69	11.49	(7)
(8)		HDD50	5013	919	870	727	431	147	35	2	3	66	302	612	899	(8)
(9)		HDD65	9821	1384	1290	1192	881	586	390	232	232	444	764	1062	1364	(9)
(10)		CDD50	682	0	0	0	0	26	95	243	243	72	3	0	0	(10)
(11)		CDD65	15	0	0	0	0	0	1	8	6	0	0	0	0	(11)
(12)		CDH74	222	0	0	0	0	0	14	111	90	7	0	0	0	(12)
(13)		CDH80	25	0	0	0	0	0	1	19	4	1	0	0	0	(13)
(14)	Wind	WSAvg	6.5	5.1	4.8	5.6	6.4	6.9	7.4	7.2	7.2	6.8	7.0	7.1	6.1	(14)
(15)	Precipitation	PrecAvg	16.9	1.7	1.0	0.9	0.7	1.1	1.6	1.7	1.6	1.3	1.5	1.8	1.9	(15)
(16)		PrecMax	22.4	4.6	2.4	2.0	1.9	2.4	3.5	3.9	3.9	3.3	3.5	5.6	4.1	(16)
(17)		PrecMin	10.4	0.1	0.2	0.2	0.0	0.1	0.2	0.1	0.4	0.2	0.5	0.0	0.7	(17)
(18)		PrecStd	3.1	1.2	0.6	0.5	0.6	0.7	1.0	1.0	0.9	0.7	0.7	1.0	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.8	42.7	49.4	57.5	70.9	75.7	83.0	80.1	73.8	60.2	49.4	43.2	(19)
(20)			MCWB	38.1	36.9	38.7	43.4	51.4	56.0	60.7	59.3	58.1	51.4	44.0	38.7	(20)
(21)		2%	DB	40.2	38.8	44.0	51.3	65.7	70.4	76.8	76.8	69.0	55.4	46.2	40.2	(21)
(22)			MCWB	36.3	34.2	36.2	40.5	49.5	55.0	59.5	59.2	56.8	49.0	41.6	36.6	(22)
(23)		5%	DB	38.1	36.4	41.0	48.0	61.4	66.2	72.7	72.9	64.4	52.5	43.2	38.0	(23)
(24)			MCWB	34.9	32.8	34.9	39.2	48.3	53.2	57.7	58.4	54.5	46.3	39.4	34.6	(24)
(25)		10%	DB	35.7	34.1	38.7	44.8	57.4	62.4	68.5	69.1	60.7	49.5	40.6	35.6	(25)
(26)			MCWB	33.0	31.1	33.5	37.3	46.5	51.6	56.6	57.1	52.8	44.1	37.2	32.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.5	37.8	39.6	45.0	53.3	59.1	64.3	62.9	60.2	52.5	44.4	39.1	(27)
(28)			MCDWB	42.2	41.5	47.1	52.4	66.4	70.2	77.7	74.7	71.4	58.6	48.8	42.2	(28)
(29)		2%	WB	36.7	34.9	37.0	42.1	51.0	56.6	61.0	60.7	57.3	49.7	42.1	36.8	(29)
(30)			MCDWB	39.5	38.0	42.4	49.3	62.4	66.7	74.0	72.7	66.6	54.4	46.0	39.9	(30)
(31)		5%	WB	35.2	33.2	35.5	40.0	49.1	54.5	58.8	59.1	55.3	46.9	39.8	34.8	(31)
(32)			MCDWB	37.9	35.9	40.2	46.7	58.8	63.5	69.4	70.4	63.7	51.6	42.9	37.4	(32)
(33)		10%	WB	33.1	31.3	33.9	37.9	47.4	52.6	57.1	57.6	53.2	44.5	37.7	32.9	(33)
(34)			MCDWB	35.4	34.1	38.0	43.8	55.8	60.9	66.7	68.0	59.9	49.1	40.4	35.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.3	17.0	18.1	16.5	18.5	17.1	17.6	18.5	17.2	13.1	10.0	11.0	(35)
(36)			MCDBR	12.5	15.7	19.4	22.3	26.5	24.7	25.8	25.9	26.0	18.3	12.4	12.5	(36)
(37)			MCWBR	9.7	11.9	12.7	12.5	12.3	11.4	11.7	11.9	14.7	12.1	9.3	9.8	(37)
(38)		5% WB	MCDWB	11.9	15.1	17.4	19.4	22.5	21.3	23.3	23.8	24.3	17.5	12.4	12.1	(38)
(39)			MCWBR	9.3	11.7	11.6	11.9	11.3	10.8	11.5	11.6	13.8	12.3	9.5	9.7	(39)
(40)		Clear-Sky Solar Irradiance	taub	0.258	0.267	0.293	0.318	0.337	0.347	0.328	0.334	0.312	0.297	0.283	0.245	(40)
(41)	taud		2.343	2.402	2.399	2.438	2.454	2.446	2.552	2.526	2.580	2.575	2.355	2.333	(41)	
(42)	Ebn at Noon		232	271	285	291	289	286	291	282	277	258	216	214	(42)	
(43)	Edh at Noon		17	23	29	31	33	34	30	29	24	19	17	14	(43)	
(44)	All-Sky Solar Radiation	RadAvg	218	498	871	1378	1641	1797	1766	1507	998	546	253	171	(44)	
(45)		RadStd	26	59	82	81	144	146	185	73	94	66	32	20	45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)			
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+106	N/A	N/A

Nomenclature: See separate page