

OOTSA LAKE SKINS LAKE, BC, Canada

WMO: 716790

Lat: 53.7719N

Lon: 125.9967W

Elev: 861

StdP: 91.40

Time Zone: -8.00 (NAP)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-25.6	-22.0	-28.7	0.3	-24.8	-25.1	0.4	-21.1	11.8	0.7	10.2	1.4	1.4	50	0.695

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.3	24.7	15.0	22.7	14.2	20.7	13.5	16.0	22.8	14.9	21.0	14.1	19.6	3.3	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.2	10.5	18.3	12.2	9.9	17.2	11.4	9.3	16.4	47.5	23.0	44.5	21.1	42.1	19.9	21.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.0	8.5	7.3	-29.0	28.4	4.2	2.2	-32.0	30.0	-34.4	31.3	-36.7	32.5	-39.8	34.1		
(5)			-29.2	18.3	4.1	1.4	-32.1	19.3	-34.5	20.2	-36.8	21.0	-39.8	22.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	3.4	-6.5	-7.3	-3.0	2.0	7.8	11.1	14.3	14.3	10.1	4.6	-1.3	-6.1		
	DBStd	9.06	6.93	6.77	5.28	3.12	3.15	2.88	2.84	2.89	3.18	3.31	5.38	6.38		
	HDD10.0	2785	511	483	404	239	82	19	1	2	37	168	340	499		
	HDD18.3	5456	769	717	662	489	326	217	129	129	247	424	590	758		
	CDD10.0	379	0	0	0	0	14	53	135	135	40	2	0	0		
	CDD18.3	8	0	0	0	0	0	1	4	3	0	0	0	0		
	CDH23.3	123	0	0	0	0	0	8	62	50	4	0	0	0		
	CDH26.7	14	0	0	0	0	0	1	11	2	1	0	0	0		
(14) Wind	WSAvg	2.9	2.3	2.2	2.5	2.9	3.1	3.3	3.2	3.2	3.0	3.1	3.2	2.7		
(15) Precipitation	PrecAvg	430	44	26	24	18	27	40	43	40	34	39	46	48		
	PrecMax	570	117	61	50	47	62	90	98	100	83	88	142	104		
	PrecMin	263	2	6	4	0	2	5	3	10	6	12	0	18		
	PrecStd	79	30	15	12	14	19	25	25	23	18	19	26	19		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.0	6.0	9.6	14.2	21.6	24.3	28.3	26.7	23.2	15.7	9.7	6.2		
		MCWB	3.4	2.7	3.7	6.3	10.8	13.3	15.9	15.2	14.5	10.8	6.6	3.7		
	2%	DB	4.5	3.8	6.7	10.7	18.7	21.3	24.9	24.9	20.5	13.0	7.9	4.6		
		MCWB	2.4	1.2	2.4	4.7	9.7	12.8	15.3	15.1	13.8	9.4	5.4	2.6		
	5%	DB	3.4	2.4	5.0	8.9	16.3	19.0	22.6	22.7	18.0	11.4	6.2	3.3		
		MCWB	1.6	0.4	1.6	4.0	9.1	11.8	14.3	14.7	12.5	7.9	4.1	1.4		
	10%	DB	2.1	1.1	3.7	7.1	14.1	16.9	20.3	20.6	15.9	9.7	4.8	2.0		
		MCWB	0.5	-0.5	0.9	2.9	8.1	10.9	13.7	13.9	11.5	6.7	2.9	0.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.6	3.2	4.2	7.2	11.8	15.0	18.0	17.2	15.7	11.4	6.9	3.9		
		MCDB	5.6	5.3	8.4	11.3	19.1	21.2	25.4	23.7	21.9	14.8	9.3	5.6		
	2%	WB	2.6	1.6	2.8	5.6	10.6	13.7	16.1	16.0	14.1	9.8	5.6	2.7		
		MCDB	4.2	3.3	5.8	9.6	16.9	19.3	23.3	22.6	19.2	12.4	7.8	4.4		
	5%	WB	1.8	0.6	1.9	4.4	9.5	12.5	14.9	15.1	13.0	8.3	4.3	1.6		
		MCDB	3.3	2.2	4.6	8.2	14.9	17.5	20.8	21.4	17.6	10.9	6.1	3.0		
	10%	WB	0.6	-0.4	1.1	3.3	8.6	11.5	14.0	14.2	11.8	7.0	3.2	0.5		
		MCDB	1.9	1.1	3.3	6.5	13.2	16.0	19.3	20.0	15.5	9.5	4.7	1.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.8	9.4	10.1	9.2	10.3	9.5	9.8	10.3	9.6	7.3	5.5	6.1		
		MCDBR	6.9	8.7	10.8	12.4	14.7	13.7	14.4	14.4	14.4	10.2	6.9	6.9		
	5% WB	MCWBR	5.4	6.6	7.0	6.9	6.8	6.3	6.5	6.6	8.2	6.7	5.2	5.5		
		MCWBR	6.6	8.4	9.7	10.8	12.5	11.8	13.0	13.2	13.5	9.7	6.9	6.7		
(40) Clear-Sky Solar Irradiance	taub		0.258	0.267	0.293	0.318	0.337	0.347	0.328	0.334	0.312	0.297	0.283	0.245		
		taud	2.343	2.402	2.399	2.438	2.454	2.446	2.552	2.526	2.580	2.575	2.355	2.333		
	Ebn at Noon		732	853	899	917	912	902	916	890	873	813	682	674		
		Edh at Noon	55	72	90	99	104	106	93	91	76	61	54	45		
(44) All-Sky Solar Radiation	RadAvg		0.69	1.57	2.75	4.34	5.17	5.66	5.57	4.75	3.15	1.72	0.80	0.54		
	RadStd		0.08	0.19	0.26	0.26	0.45	0.46	0.58	0.23	0.29	0.21	0.10	0.06		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (6 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page