

ASHCROFT, BC, Canada

WMO: 716810

Lat: 50.708N

Lon: 121.281W

Elev: 327

StdP: 97.46

Time Zone: -8.00 (NAP)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.0	-14.5	-23.3	0.5	-15.2	-20.3	0.6	-13.4	6.3	5.4	5.4	0.5	1.5	0	0.495

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.6	35.9	17.1	33.8	16.6	31.8	16.1	18.0	32.1	17.2	30.9	16.6	29.5	2.6	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.2	10.5	19.0	13.0	9.7	19.0	11.9	9.0	18.7	51.6	31.9	49.5	31.2	47.6	29.6	21.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.5	5.8	5.0	-20.0	39.0	3.2	1.5	-22.3	40.1	-24.1	41.0	-25.9	41.9	-28.2	43.0		
(5)			-20.3	19.7	3.3	1.1	-22.7	20.5	-24.6	21.2	-26.5	21.8	-28.9	22.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.1	-2.4	-1.5	5.6	10.3	16.4	19.6	23.1	22.7	16.9	9.5	2.1	-2.3	(6)
(7)		DBStd	10.20	5.12	5.86	4.22	3.16	3.63	3.48	3.40	3.12	3.80	3.47	5.49	4.92	(7)
(8)		HDD10.0	1557	386	322	144	33	1	0	0	0	1	51	240	381	(8)
(9)		HDD18.3	3425	644	555	396	241	83	24	4	5	72	274	487	639	(9)
(10)		CDD10.0	1582	0	0	6	42	199	288	407	393	208	35	3	0	(10)
(11)		CDD18.3	408	0	0	0	0	23	62	153	140	30	0	0	0	(11)
(12)		CDH23.3	4949	0	0	1	24	389	743	1872	1574	344	2	0	0	(12)
(13)		CDH26.7	2273	0	0	0	6	138	304	947	751	127	0	0	0	(13)
(14)	Wind	WSAvg	1.7	1.0	1.4	1.7	2.1	2.1	2.3	2.1	1.8	1.7	1.3	1.3	1.0	(14)
(15)	Precipitation	PrecAvg	421	48	25	28	21	30	37	27	28	27	39	58	54	(15)
(16)		PrecMax	529	81	56	62	41	69	65	69	108	53	86	142	101	(16)
(17)		PrecMin	336	16	6	7	8	4	18	2	4	8	14	16	20	(17)
(18)		PrecStd	52	16	13	14	8	17	13	18	22	13	16	31	21	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.7	11.8	19.9	26.5	33.1	36.2	39.1	37.8	33.5	22.7	16.9	10.3	(19)
(20)			MCWB	5.4	6.1	9.8	13.0	15.0	16.8	18.2	17.7	16.8	13.3	10.0	5.5	(20)
(21)		2%	DB	6.3	9.4	17.1	22.2	30.2	33.2	36.6	35.5	30.3	19.6	13.2	7.0	(21)
(22)			MCWB	2.9	4.7	8.2	11.0	14.2	16.6	17.2	17.1	15.6	11.5	8.4	4.1	(22)
(23)		5%	DB	4.0	7.4	14.7	19.3	27.8	30.1	34.4	33.1	27.4	17.5	10.8	4.5	(23)
(24)			MCWB	2.0	3.8	7.2	9.3	13.5	15.1	16.9	16.6	14.9	10.1	6.7	2.6	(24)
(25)		10%	DB	2.4	5.5	12.6	17.1	24.9	27.4	32.2	30.9	24.5	15.5	8.6	2.9	(25)
(26)			MCWB	1.1	2.9	6.1	8.2	12.8	14.3	16.2	16.1	13.8	9.3	5.7	1.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.7	7.4	10.1	13.3	15.9	18.6	18.7	18.9	17.6	14.2	11.0	6.0	(27)
(28)			MCDWB	9.8	10.3	18.9	23.8	28.0	31.7	35.0	31.2	29.2	21.6	16.3	8.8	(28)
(29)		2%	WB	3.3	5.4	8.6	11.7	14.9	17.0	18.0	17.8	16.5	12.4	8.7	4.3	(29)
(30)			MCDWB	5.6	7.9	15.9	21.2	28.3	31.0	33.4	31.2	27.6	18.1	12.5	6.9	(30)
(31)		5%	WB	2.1	4.1	7.5	10.0	14.0	15.9	17.2	17.2	15.7	11.1	7.2	3.0	(31)
(32)			MCDWB	3.4	7.1	13.9	18.5	25.5	28.4	31.5	30.7	25.6	16.4	10.4	4.6	(32)
(33)		10%	WB	1.3	2.9	6.5	8.7	13.3	14.9	16.6	16.5	14.6	9.7	6.0	1.8	(33)
(34)			MCDWB	2.3	5.5	12.0	15.8	23.7	25.2	29.9	29.1	23.5	15.1	8.6	3.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.3	8.1	11.0	12.6	13.8	12.9	14.6	14.8	13.1	10.1	6.6	5.3	(35)
(36)			MCDBR	7.4	9.9	14.4	16.9	19.0	17.7	19.0	18.8	18.3	13.0	9.4	7.3	(36)
(37)			MCWBR	5.0	5.7	7.0	7.7	6.8	5.7	5.8	5.7	6.6	6.2	4.9	4.6	(37)
(38)		5% WB	MCDWB	6.4	9.4	13.7	15.6	16.6	16.5	17.1	17.0	16.2	11.9	8.4	7.0	(38)
(39)			MCWBR	4.5	5.7	7.0	7.1	6.1	5.4	5.3	5.2	6.0	5.8	4.6	4.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.298	0.304	0.337	0.382	0.396	0.391	0.372	0.378	0.354	0.340	0.313	0.295	(40)	
(41)		taud	2.326	2.390	2.384	2.262	2.278	2.335	2.417	2.403	2.455	2.450	2.413	2.327	(41)	
(42)		Ebn at Noon	726	834	866	857	860	866	878	854	838	779	707	666	(42)	
(43)		Edh at Noon	66	80	97	122	126	120	109	105	90	75	61	57	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.98	1.94	3.19	4.55	5.45	5.91	6.43	5.47	3.82	2.22	1.06	0.74	(44)	
(45)		RadStd	0.09	0.15	0.21	0.38	0.43	0.51	0.50	0.31	0.32	0.22	0.11	0.08	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (21 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page