

LINDBURG LANDING, NT, Canada

WMO: 716820

Lat: 61.125N

Lon: 122.852W

Elev: 183

StdP: 99.15

Time Zone: -7.00 (NAM)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -40.0	(c) -37.2	(d) -44.1	(e) 0.1	(f) -39.9	(g) -41.0	(h) 0.1	(i) -37.1	(j) 4.9	(k) -9.4	(l) 4.2	(m) -7.5	(n) 0.2	(o) 260	(p) 0.634

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.1	28.3	17.5	26.4	16.6	24.7	15.9	19.1	25.4	18.1	23.8	17.1	22.5	1.7	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.1	12.5	20.6	16.0	11.6	19.6	15.0	10.9	18.7	55.0	25.5	51.8	24.0	48.8	22.6	23.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 4.4	(b) 3.7	(c) 3.2	(e) -42.7	(f) 31.7	(g) 2.5	(h) 1.7	(i) -44.5	(j) 32.9	(k) -46.0	(l) 33.8	(m) -47.4	(n) 34.8	(o) -49.2	(p) 36.0		
(a) 4.4	(b) 3.7	(c) 3.2	(e) -42.6	(f) 21.5	(g) 2.3	(h) 1.3	(i) -44.3	(j) 22.4	(k) -45.6	(l) 23.1	(m) -46.9	(n) 23.8	(o) -48.5	(p) 24.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-2.3	-22.8	-18.6	-13.2	-0.4	8.6	14.7	16.9	14.5	8.2	-0.6	-14.9	-21.6		
	DBStd	15.72	8.89	7.36	8.14	6.04	4.75	3.39	2.81	3.61	4.02	4.85	7.43	8.42		
	HDD10.0	5072	1016	801	718	311	82	4	1	7	79	329	746	978		
	HDD18.3	7575	1274	1034	977	561	302	117	61	127	303	587	996	1237		
	CDD10.0	569	0	0	0	0	39	145	214	144	26	1	0	0		
	CDD18.3	30	0	0	0	0	1	7	16	7	0	0	0	0		
	CDH23.3	678	0	0	0	0	41	177	301	153	7	0	0	0		
	CDH26.7	144	0	0	0	0	4	41	64	34	1	0	0	0		
(14) Wind	WSAvg	1.1	0.7	0.8	1.1	1.4	1.6	1.3	1.1	1.1	1.2	1.1	0.8	0.6		
(15) Precipitation	PrecAvg	413	22	17	17	15	32	64	71	55	42	30	26	22		
	PrecMax	582	42	45	42	31	62	129	186	110	101	53	55	52		
	PrecMin	256	2	3	1	2	7	17	11	10	12	14	4	6		
	PrecStd	72	9	10	10	8	14	32	33	21	20	12	10	10		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.8	6.9	10.2	18.2	26.9	30.2	30.8	30.2	23.8	16.1	8.1	9.3		
		MCWB	1.8	2.6	3.6	8.9	13.8	17.5	18.9	18.7	15.3	9.1	3.4	4.5		
	2%	DB	1.4	1.7	7.1	15.1	24.3	27.7	28.4	27.0	20.9	12.3	2.7	1.4		
		MCWB	-1.1	-0.9	1.8	6.8	13.0	16.4	18.0	17.7	13.0	6.9	0.3	-0.8		
	5%	DB	-4.7	-5.0	3.6	12.8	21.6	25.2	26.6	24.7	18.6	9.3	-1.9	-4.7		
		MCWB	-5.5	-5.8	-0.3	5.5	11.8	15.2	17.3	16.7	12.1	5.4	-2.5	-5.2		
	10%	DB	-11.4	-8.5	-0.2	10.2	18.8	23.2	24.8	22.6	16.3	6.3	-5.4	-9.6		
		MCWB	-11.8	-9.2	-2.7	4.2	10.3	14.5	16.7	15.9	11.0	3.9	-5.8	-9.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.1	2.7	3.9	9.1	15.2	19.2	20.5	20.8	16.2	9.8	3.7	4.5		
		MCDB	5.2	6.8	9.6	17.4	24.5	25.6	26.7	27.2	22.1	14.7	8.2	9.3		
	2%	WB	-1.1	-0.9	2.0	7.1	13.7	17.8	19.2	18.9	14.1	7.3	0.3	-0.7		
		MCDB	1.4	1.5	6.6	14.1	22.0	23.9	25.6	24.7	18.6	11.3	2.6	1.7		
	5%	WB	-5.5	-5.7	-0.2	5.7	12.3	16.7	18.3	17.6	12.7	5.8	-2.6	-5.4		
		MCDB	-4.7	-4.9	3.4	12.2	20.6	22.6	24.4	22.9	17.1	9.1	-1.9	-4.8		
	10%	WB	-11.8	-9.2	-2.7	4.4	10.8	15.5	17.5	16.4	11.5	4.0	-5.7	-9.9		
		MCDB	-11.5	-8.6	-0.4	9.9	17.9	21.2	23.1	21.4	15.6	6.1	-5.4	-9.6		
(35) Mean Daily Temperature Range	MDBR		8.8	11.7	15.1	14.2	14.4	13.6	13.1	13.0	12.0	8.0	8.2	8.5		
	5% DB	MCDBR	14.6	16.2	19.1	18.3	19.6	18.1	17.5	18.0	16.8	13.6	11.1	15.0		
		MCWBR	12.4	14.0	13.9	10.5	9.0	7.9	8.2	9.4	9.5	8.6	9.3	12.8		
	5% WB	MCDBR	14.6	16.2	18.5	17.4	18.3	15.1	15.8	16.4	15.3	13.2	11.1	14.9		
		MCWBR	12.4	13.9	13.5	10.1	8.7	7.4	8.1	9.3	9.4	8.5	9.3	12.7		
(40) Clear-Sky Solar Irradiance	taub		0.204	0.251	0.267	0.329	0.349	0.365	0.380	0.356	0.307	0.282	0.209	0.166		
	taud		2.134	2.269	2.284	2.259	2.417	2.411	2.400	2.469	2.593	2.508	2.179	1.988		
	Ebn at Noon		569	755	867	862	875	863	838	833	828	724	553	439		
	Edh at Noon		36	62	86	109	102	104	103	89	66	50	33	23		
(44) All-Sky Solar Radiation	RadAvg		0.35	1.19	2.93	4.71	5.51	5.67	5.33	4.26	2.70	1.24	0.44	0.18		
	RadStd		0.03	0.09	0.18	0.23	0.35	0.46	0.43	0.32	0.29	0.10	0.05	0.01		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+126	+20
(47) Regional (5 neighbors)		N/A	+1.84	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page