

TEEPEE CREEK AGCM, AB, Canada

WMO: 716900

Lat: 55.3524N

Lon: 118.4076W

Elev: 670

StdP: 93.53

Time Zone: -7.00 (NAM)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-35.1	-31.3	-38.7	0.1	-35.1	-34.7	0.2	-31.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.1	27.7	16.1	25.8	15.5	24.2	14.8	17.9	24.1	16.9	23.4	15.9	22.2	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.5	12.0	20.6	14.5	11.2	19.2	13.5	10.4	18.0	53.1	24.0	49.9	23.5	46.9	22.4	22.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	-38.8	30.6	4.1	1.5	-41.8	31.7	-44.2	32.6	-46.5	33.4	-49.5	34.5
			-38.9	19.7	4.1	1.8	-41.9	20.9	-44.3	22.0	-46.5	23.0	-49.5	24.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	2.0	-11.0	-11.3	-6.1	3.0	10.3	14.1	16.0	15.0	9.8	3.2	-6.7	-12.8	(6)
	DBStd	12.18	8.91	8.89	7.70	4.90	4.20	2.96	2.48	3.22	4.22	4.73	7.06	7.78	(7)
	HDD10.0	3491	650	597	500	214	48	3	0	3	54	215	500	706	(8)
	HDD18.3	5966	908	830	758	461	248	129	80	110	256	470	750	964	(9)
	CDD10.0	584	0	0	0	3	58	127	186	157	49	4	0	0	(10)
	CDD18.3	16	0	0	0	0	0	3	7	6	0	0	0	0	(11)
	CDH23.3	546	0	0	0	4	39	93	198	169	42	0	0	0	(12)
	CDH26.7	99	0	0	0	1	5	13	37	38	6	0	0	0	(13)
(14) Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(14)
(15) Precipitation	PrecAvg	470	33	20	23	25	46	76	73	54	39	30	30	24	(15)
	PrecMax	642	102	52	46	49	88	138	133	139	108	88	91	96	(16)
	PrecMin	307	9	4	10	6	17	17	29	17	8	6	5	1	(17)
	PrecStd	92	19	10	10	12	20	35	29	29	21	18	19	18	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.5	5.0	9.4	21.8	27.1	28.3	30.1	30.1	27.3	20.9	9.8	4.9	(19)
		MCWB	2.5	1.9	4.7	10.1	12.3	16.3	17.7	17.2	14.7	11.9	5.6	1.8	(20)
	2%	DB	4.3	3.8	7.3	17.0	24.0	26.0	27.3	27.5	24.3	16.1	6.1	2.9	(21)
		MCWB	2.0	1.5	3.1	8.0	12.0	15.2	16.6	17.0	14.3	9.1	3.5	0.7	(22)
	5%	DB	3.1	2.6	5.4	13.3	21.7	23.9	25.5	25.0	21.5	13.1	4.0	1.1	(23)
		MCWB	1.4	0.7	2.0	6.0	11.0	13.9	15.9	15.9	12.9	7.3	1.6	-0.8	(24)
	10%	DB	1.6	0.8	3.8	10.8	19.5	21.8	23.7	23.0	18.4	10.9	2.3	-1.1	(25)
		MCWB	0.1	-0.9	1.1	4.9	9.9	13.2	15.2	15.1	11.7	6.2	0.7	-2.5	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.7	2.5	5.2	10.8	14.4	17.9	19.7	19.3	16.5	12.5	6.2	2.3	(27)
		MCDB	4.7	4.4	8.6	21.1	23.3	25.2	26.5	26.4	25.0	19.2	8.5	4.2	(28)
	2%	WB	2.2	1.7	3.4	8.5	12.8	16.2	18.1	17.9	14.8	9.9	3.6	0.8	(29)
		MCDB	3.9	3.5	6.7	16.1	21.1	23.6	24.0	24.1	22.0	15.1	5.9	2.7	(30)
	5%	WB	1.4	0.8	2.2	6.6	11.6	15.2	17.0	16.9	13.4	8.0	2.0	-0.7	(31)
		MCDB	3.0	2.6	5.1	12.3	19.8	21.9	23.2	23.1	20.5	11.9	3.6	1.1	(32)
	10%	WB	0.1	-0.9	1.2	5.2	10.7	14.2	16.0	15.8	12.1	6.6	0.8	-2.6	(33)
		MCDB	1.6	0.7	3.7	10.3	18.3	20.1	22.0	21.9	17.8	10.2	2.2	-1.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	9.9	11.5	12.1	11.3	13.7	12.1	13.1	13.5	13.8	10.8	9.6	9.7	(35)
		MCDBR	9.2	10.4	13.1	16.8	18.0	16.6	17.5	17.5	19.5	15.3	10.9	11.6	(36)
		MCWBR	7.6	8.3	9.3	8.9	8.1	7.3	8.1	8.2	9.8	9.1	8.2	9.8	(37)
	5% WB	MCDBR	8.7	9.8	12.4	15.3	16.1	14.2	15.1	15.5	18.0	14.6	10.0	11.7	(38)
		MCWBR	7.3	8.0	8.8	8.4	7.6	6.9	7.8	7.9	9.4	9.2	8.0	10.0	(39)
(40) Clear-Sky Solar Irradiance	taub		0.239	0.250	0.303	0.326	0.343	0.350	0.350	0.350	0.310	0.284	0.246	0.234	(40)
	taud		2.332	2.390	2.305	2.386	2.400	2.398	2.419	2.409	2.530	2.563	2.437	2.250	(41)
	Ebn at Noon		727	859	870	900	900	895	887	863	863	812	722	629	(42)
	Edh at Noon		50	68	96	103	108	110	106	100	77	59	45	42	(43)
(44) All-Sky Solar Radiation	RadAvg		0.74	1.68	3.14	4.66	5.55	6.06	5.92	4.82	3.31	1.78	0.81	0.53	(44)
	RadStd		0.07	0.13	0.25	0.27	0.39	0.48	0.39	0.41	0.30	0.20	0.07	0.05	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (19 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page