

POINT LEPREAU, NB, Canada

WMO: 716990

Lat: 45.059N

Lon: 66.459W

Elev: 6

StdP: 101.25

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.3	-15.9	-24.5	0.4	-17.3	-22.1	0.5	-14.5	14.2	5.0	12.4	3.6	4.8	320	0.605

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.2	23.3	17.5	21.5	17.0	20.1	16.4	19.0	21.4	18.0	20.2	17.2	19.1	3.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.0	13.0	20.1	17.1	12.2	18.9	16.3	11.6	18.0	54.0	21.5	50.7	20.3	48.3	19.2	23.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.3	8.7	7.4	-21.4	27.8	2.5	1.6	-23.2	28.9	-24.7	29.9	-26.1	30.8	-27.9	31.9
			-22.1	21.6	2.4	0.9	-23.8	22.2	-25.2	22.7	-26.6	23.2	-28.3	23.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.4	-5.0	-4.1	-0.3	4.5	9.0	13.1	15.8	16.5	14.1	9.4	4.4	-1.2
	DBStd	8.31	6.12	5.17	4.20	2.72	2.47	2.49	2.03	1.80	2.59	3.28	4.27	5.21
	HDD10.0	1969	467	394	318	165	48	3	0	0	2	51	173	348
	HDD18.3	4365	725	627	576	414	288	158	83	62	130	276	419	606
	CDD10.0	657	0	0	0	1	18	96	180	201	124	33	4	0
	CDD18.3	12	0	0	0	0	0	1	4	5	2	0	0	0
	CDH23.3	54	0	0	0	0	2	8	17	19	7	1	0	0
	CDH26.7	4	0	0	0	0	0	1	2	1	1	0	0	0
(14) Wind	WSAvg	3.4	4.3	4.1	4.0	3.5	3.0	2.6	2.1	2.3	2.7	3.6	4.0	4.3
(15) Precipitation	PrecAvg	1262	102	92	96	100	104	111	96	89	102	128	123	127
	PrecMax	1670	180	187	193	195	214	270	228	201	230	311	210	258
	PrecMin	922	47	34	14	24	47	40	30	19	26	35	55	54
	PrecStd	189	33	31	45	43	40	58	52	43	56	63	41	47
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.9	7.7	11.3	15.0	20.8	24.4	25.5	25.5	23.8	18.8	14.5	11.6
		MCWB	9.4	6.4	5.8	7.9	12.7	16.1	19.1	18.3	18.2	14.6	13.0	10.8
	2%	DB	8.1	6.0	8.0	11.7	16.6	21.4	22.8	23.2	20.8	16.3	13.3	10.2
		MCWB	7.3	4.9	5.3	6.8	11.6	15.6	17.9	17.9	16.2	14.1	12.2	9.4
	5%	DB	6.3	4.8	6.5	10.0	14.6	19.1	20.9	21.4	19.2	15.2	12.2	8.6
		MCWB	5.5	3.8	4.6	6.4	10.8	14.7	17.3	17.3	15.9	13.4	11.2	7.7
	10%	DB	4.3	3.6	5.1	8.5	12.9	17.2	19.3	20.0	17.9	14.3	11.1	6.9
		MCWB	3.2	2.5	3.6	5.9	9.9	14.1	16.5	16.8	15.4	12.7	9.9	5.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.5	7.0	8.1	10.3	15.2	18.5	21.0	20.6	19.2	16.2	13.8	11.1
		MCDB	9.8	7.4	8.9	12.2	17.9	21.8	23.8	23.1	21.2	17.4	14.1	11.4
	2%	WB	7.5	5.2	6.2	8.3	12.9	16.7	19.0	18.9	17.7	14.9	12.6	9.7
		MCDB	7.9	5.7	7.1	10.0	15.4	19.5	21.4	21.4	19.3	15.6	13.0	10.1
	5%	WB	5.7	4.0	5.0	7.3	11.6	15.4	17.7	18.0	16.9	14.1	11.4	7.9
		MCDB	6.2	4.6	6.0	8.9	13.5	17.9	20.0	20.2	18.3	14.8	12.0	8.5
	10%	WB	3.3	2.6	3.8	6.4	10.5	14.4	16.8	17.2	16.1	13.1	10.0	5.8
		MCDB	4.2	3.5	4.9	7.9	12.2	16.6	18.7	19.2	17.4	14.0	11.0	6.8
(35) Mean Daily Temperature Range	5% DB	MDBR	8.8	8.3	7.3	7.0	7.0	7.2	6.7	7.2	7.3	7.1	7.0	7.8
		MCDBR	10.6	7.9	8.2	9.5	10.2	10.9	9.8	9.8	8.7	7.4	7.1	8.9
		MCWBR	11.0	7.8	6.5	6.2	6.2	6.3	5.9	5.6	5.6	5.8	7.0	9.3
	5% WB	MCDBR	10.8	7.9	7.1	7.3	8.5	8.9	8.3	7.7	6.7	6.1	6.7	8.9
		MCWBR	11.3	8.1	6.5	5.6	5.9	6.1	5.7	5.2	5.0	5.6	7.0	9.5
(40) Clear-Sky Solar Irradiance	taub		0.292	0.299	0.325	0.355	0.376	0.414	0.430	0.408	0.374	0.337	0.314	0.299
	taud		2.482	2.481	2.454	2.410	2.397	2.321	2.300	2.367	2.424	2.523	2.539	2.482
	Ebn at Noon		831	894	911	906	893	856	836	843	845	836	799	781
	Edh at Noon		68	82	97	110	115	125	126	114	99	79	65	62
(44) All-Sky Solar Radiation	RadAvg		1.43	2.31	3.52	4.39	5.01	5.48	5.58	4.97	4.06	2.57	1.50	1.11
	RadStd		0.13	0.20	0.24	0.41	0.60	0.47	0.45	0.32	0.28	0.26	0.16	0.10

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	+1.74	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.43	N/A	N/A	+54	N/A

Nomenclature: See separate page