

SUMMERSIDE, PE, Canada

WMO: 717020

Lat: 46.4413N

Lon: 63.8375W

Elev: 40

StdP: 14.67

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-2.7	1.2	-11.8	2.9	-1.8	-7.1	3.8	2.5	37.0	22.7	32.9	23.6	10.9	270	0.699

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.5	80.4	69.3	77.8	67.4	75.5	66.2	71.6	77.8	69.8	75.2	68.3	73.2	12.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.3	107.9	75.2	67.8	102.3	73.4	66.3	97.0	71.7	35.4	78.1	33.9	75.3	32.6	73.2	78.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 30.0	26.3	23.3	DB	-9.3	86.3	4.5	2.7	-12.5	88.2	-15.2	89.8	-17.7	91.3	-21.0	93.3	(4)
(5)			WB	-10.0	74.6	4.4	1.5	-13.2	75.7	-15.7	76.5	-18.2	77.4	-21.4	78.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	43.6	19.8	19.8	27.5	38.3	49.5	59.4	67.3	66.6	59.4	48.6	38.1	27.4	(6)
(7)		DBStd	18.30	10.25	9.84	8.21	6.76	6.70	6.39	4.35	4.70	6.39	6.80	7.90	8.77	(7)
(8)		HDD50	4114	937	846	697	357	92	5	0	0	5	109	365	701	(8)
(9)		HDD65	8033	1402	1266	1162	801	480	187	27	39	188	508	807	1166	(9)
(10)		CDD50	1782	0	0	0	6	78	287	536	513	287	67	8	0	(10)
(11)		CDD65	225	0	0	0	0	0	19	98	87	20	1	0	0	(11)
(12)		CDH74	850	0	0	0	0	10	86	377	316	60	1	0	0	(12)
(13)		CDH80	98	0	0	0	0	0	9	43	38	8	0	0	0	(13)
(14)	Wind	WSAvg	11.6	12.5	12.3	12.8	12.4	11.8	11.0	10.0	9.5	10.6	11.4	12.4	12.7	(14)
(15)	Precipitation	PrecAvg	39.7	2.6	2.5	2.8	3.1	3.0	3.8	2.9	3.3	3.8	4.2	3.7	3.8	(15)
(16)		PrecMax	53.5	5.3	4.6	5.8	5.5	7.4	6.0	5.7	6.3	6.9	8.1	6.3	8.9	(16)
(17)		PrecMin	29.8	0.4	0.3	0.8	1.6	0.9	1.6	1.3	0.9	0.5	1.1	1.3	1.5	(17)
(18)		PrecStd	6.3	1.2	1.1	1.3	1.1	1.5	1.1	1.2	1.4	1.9	2.1	1.3	1.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.0	46.6	52.7	63.3	75.3	80.7	84.5	84.5	79.7	69.9	62.4	52.4	(19)
(20)			MCWB	48.5	44.1	45.8	54.6	59.9	67.7	71.9	72.3	69.2	61.9	59.2	50.5	(20)
(21)		2%	DB	42.6	40.6	45.4	57.3	69.8	76.3	80.6	80.1	75.0	65.0	57.9	47.3	(21)
(22)			MCWB	41.2	38.8	41.8	50.1	58.3	64.9	69.7	69.2	66.1	59.9	55.5	45.8	(22)
(23)		5%	DB	37.9	36.9	41.3	52.9	64.9	73.3	78.1	77.4	71.7	62.0	53.9	42.6	(23)
(24)			MCWB	36.3	35.1	38.3	47.5	55.5	63.6	67.9	67.7	64.9	57.5	51.1	40.7	(24)
(25)		10%	DB	34.2	34.0	38.1	48.8	60.7	70.1	75.6	75.0	69.0	59.1	49.9	38.8	(25)
(26)			MCWB	32.8	32.6	35.4	43.9	53.5	61.7	66.8	66.4	63.2	55.1	47.2	36.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.5	44.1	47.5	57.3	63.7	71.1	73.7	74.2	71.1	64.5	59.4	50.9	(27)
(28)			MCD B	50.0	46.0	50.5	61.7	70.7	77.7	81.0	81.3	77.3	67.6	61.3	51.9	(28)
(29)		2%	WB	41.3	38.8	42.5	52.3	60.0	68.0	71.7	71.5	68.3	61.2	55.9	46.1	(29)
(30)			MCD B	42.2	40.2	44.7	55.6	66.4	73.1	78.3	77.2	72.5	64.3	57.8	47.4	(30)
(31)		5%	WB	36.4	35.2	38.7	48.1	57.2	65.5	70.0	69.6	66.2	58.4	51.5	41.2	(31)
(32)			MCD B	37.7	36.6	40.8	51.8	62.6	70.6	75.6	74.8	70.2	61.3	53.6	42.5	(32)
(33)		10%	WB	32.9	32.7	35.7	44.3	54.4	63.1	68.5	68.0	64.1	55.5	47.2	37.1	(33)
(34)			MCD B	34.0	33.9	37.8	48.2	59.9	68.3	73.6	72.9	68.2	58.5	49.5	38.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	13.8	14.3	12.6	13.0	15.2	15.1	14.5	14.4	14.2	12.4	10.8	11.1	(35)
(36)			MCDBR	19.6	16.0	16.1	19.9	22.7	20.0	18.1	17.5	16.7	15.5	15.5	15.3	(36)
(37)			MCWBR	19.8	15.1	13.8	14.0	13.3	11.4	9.5	9.3	10.3	11.9	14.7	15.4	(37)
(38)		5% WB	MCD BR	19.6	16.0	15.7	17.8	19.3	16.6	15.5	14.9	14.6	14.4	15.4	15.6	(38)
(39)			MCWBR	19.9	15.6	14.4	14.7	13.4	11.4	9.7	9.3	10.4	12.4	15.2	15.9	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.299	0.289	0.320	0.348	0.369	0.383	0.411	0.392	0.357	0.332	0.309	0.291	(40)
(41)		taud		2.357	2.336	2.354	2.406	2.406	2.372	2.335	2.377	2.469	2.519	2.520	2.471	(41)
(42)		Ebn at Noon		251	281	287	288	285	280	270	271	272	264	250	245	(42)
(43)		Edh at Noon		23	29	33	35	36	37	38	36	30	24	20	19	(43)
(44)	All-Sky Solar Radiation	RadAvg		368	588	1009	1332	1609	1746	1781	1562	1209	749	394	279	(44)
(45)		RadStd		27	75	88	125	151	131	119	99	106	75	48	27	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.58	N/A	N/A	N/A	N/A

Nomenclature: See separate page