

POINT ESCUMINAC, NB, Canada

WMO: 717055

Lat: 47.073N

Lon: 64.798W

Elev: 4

StdP: 101.28

Time Zone: -4.00 (NAA)

Period: 90-01

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -22.1	(c) -19.6	(d) -28.3	(e) 0.3	(f) -21.5	(g) -25.5	(h) 0.4	(i) -19.0	(j) 18.1	(k) -7.2	(l) 16.4	(m) -7.9	(n) 6.5	(o) 270	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 7.2	(c) 27.9	(d) 19.7	(e) 25.0	(f) 18.7	(g) 23.0	(h) 18.6	(i) 21.4	(j) 25.0	(k) 20.5	(l) 23.2	(m) 19.5	(n) 21.9	(o) 5.7	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.3	15.0	22.7	19.5	14.2	22.0	18.6	13.4	21.2	62.3	24.9	59.2	23.2	55.9	22.0	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 16.3	(b) 14.3	(c) 12.8	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 16.3	(b) 14.3	(c) 12.8	(e) -25.1	(f) 23.5	(g) 2.8	(h) 1.2	(i) -27.1	(j) 24.4	(k) -28.7	(l) 25.1	(m) -30.3	(n) 25.8	(o) -32.3	(p) 26.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.3	-8.8	-8.5	-3.1	2.0	8.6	15.5	18.0	18.4	14.3	7.9	2.2	-3.7	
	DBStd	10.39	5.71	5.39	4.50	2.99	3.86	4.03	2.87	2.53	3.13	3.33	3.92	5.46	
	HDD10.0	2568	583	518	407	239	74	2	0	0	3	83	234	424	
	HDD18.3	4839	842	752	665	489	301	106	41	29	126	324	483	682	
	CDD10.0	859	0	0	0	1	32	166	248	261	134	18	1	0	
	CDD18.3	88	0	0	0	0	1	19	31	32	6	0	0	0	
	CDH23.3	422	0	0	0	0	9	133	126	138	17	0	0	0	
	CDH26.7	112	0	0	0	0	1	41	30	38	2	0	0	0	
Wind	WSAvg	6.0	6.3	6.5	6.3	5.9	5.7	5.0	4.7	4.8	5.6	6.7	7.3	7.4	
Precipitation	PrecAvg	1031	89	77	83	74	87	84	88	86	83	103	91	105	
	PrecMax	1227	152	140	170	128	172	156	148	154	177	209	153	240	
	PrecMin	770	26	17	27	38	20	30	23	20	37	25	39	35	
	PrecStd	127	31	33	34	26	34	30	31	35	39	41	27	40	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.8	7.7	8.9	14.9	24.3	30.5	29.7	30.6	25.6	19.4	13.8	9.3	
		MCWB	5.3	4.9	6.0	8.9	15.5	20.3	20.3	21.1	19.5	14.2	11.1	7.9	
	2%	DB	3.4	4.0	5.3	10.3	19.7	27.4	26.7	27.0	22.4	16.1	10.6	5.6	
		MCWB	2.4	2.6	3.0	6.3	13.8	18.9	20.2	19.6	18.1	12.9	8.9	4.3	
	5%	DB	1.1	1.2	3.5	7.9	16.2	23.6	24.2	24.2	20.7	14.5	8.9	3.8	
		MCWB	0.4	0.1	1.7	5.1	12.0	17.9	19.3	19.0	17.5	12.3	7.5	2.8	
	10%	DB	-0.8	-0.3	2.0	5.8	14.1	20.8	22.5	22.4	19.1	13.1	7.3	2.5	
		MCWB	-1.7	-1.2	0.7	3.7	11.1	17.5	18.8	18.7	16.5	11.2	5.8	1.6	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.1	5.8	6.9	10.2	17.1	22.0	23.1	22.4	21.2	15.5	11.8	8.6
			MCDB	6.6	7.6	8.2	13.5	22.8	28.3	26.6	27.3	23.5	17.4	12.9	9.6
2%		WB	2.4	2.2	3.7	7.3	14.4	20.2	21.5	21.2	19.6	14.1	9.4	4.7	
		MCDB	3.2	3.8	5.2	10.1	17.9	23.6	24.3	24.8	21.3	15.8	10.5	5.3	
5%		WB	0.5	0.3	2.0	5.4	12.8	19.0	20.4	20.4	18.2	12.7	7.9	2.9	
		MCDB	1.1	1.1	3.1	7.4	15.8	22.1	22.9	23.2	20.1	14.3	8.8	3.5	
10%		WB	-1.5	-1.5	0.9	4.0	11.3	17.9	19.3	19.4	17.0	11.3	6.3	1.7	
		MCDB	-0.9	-0.6	1.8	5.6	13.8	20.7	21.8	21.6	18.6	12.8	7.0	2.4	
Mean Daily Temperature Range	5% DB	MDBR	8.5	8.5	6.4	5.1	6.2	7.1	6.5	7.2	6.9	6.4	5.5	6.5	
		MCDBR	11.4	9.8	8.3	9.2	11.3	12.5	10.2	10.6	9.8	9.3	8.1	7.5	
		MCWBR	11.3	9.0	7.0	6.5	6.8	6.3	5.0	5.3	6.1	7.0	7.5	7.0	
	5% WB	MCDBR	11.2	9.4	7.9	8.5	10.6	10.2	8.0	8.6	7.4	8.3	7.6	7.3	
		MCWBR	11.1	8.8	6.7	6.3	6.6	5.9	4.7	5.3	5.5	6.8	7.3	7.2	
Clear-Sky Solar Irradiance	taub		0.286	0.282	0.320	0.352	0.367	0.385	0.413	0.392	0.357	0.330	0.305	0.286	
	taud		2.393	2.335	2.340	2.403	2.426	2.377	2.344	2.395	2.475	2.536	2.541	2.492	
	Ebn at Noon		806	891	903	903	898	879	848	853	855	830	787	771	
	Edh at Noon		69	90	105	109	111	117	120	109	92	75	61	57	
All-Sky Solar Radiation	RadAvg		1.33	2.12	3.33	4.25	5.07	5.47	5.53	4.83	3.79	2.38	1.30	0.97	
	RadStd		0.14	0.23	0.23	0.39	0.50	0.41	0.39	0.31	0.33	0.21	0.16	0.10	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page