

SYDNEY, NS, Canada

WMO: 717070

Lat: 46.163N

Lon: 60.043W

Elev: 203

StdP: 14.59

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	2.0	6.5	-7.2	3.8	4.0	-2.5	4.8	7.6	35.4	26.2	31.6	24.0	9.4	250	0.692

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	16.0	81.8	68.9	78.8	67.3	75.9	65.8	71.3	78.3	69.5	75.8	67.8	73.2	12.5	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.9	107.0	74.6	67.3	101.1	72.7	65.6	95.3	71.0	35.2	78.5	33.7	76.1	32.3	73.3	77.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.9	25.3	22.5	-3.0	87.9	5.7	2.4	-7.1	89.7	-10.5	91.1	-13.7	92.4	-17.9	94.2		
(5)			-3.9	74.5	5.6	1.6	-7.9	75.6	-11.1	76.6	-14.3	77.5	-18.3	78.7	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	43.6	23.9	22.9	28.3	36.9	46.3	55.8	65.2	65.4	58.4	48.4	39.6	30.8	(6)
(7)		DBStd	16.33	8.90	8.86	7.80	6.34	6.68	6.94	5.45	4.97	6.39	6.39	7.18	7.50	(7)
(8)		HDD50	3854	809	759	673	398	159	21	0	0	7	110	322	596	(8)
(9)		HDD65	7978	1273	1179	1138	844	580	287	66	57	215	516	762	1061	(9)
(10)		CDD50	1516	0	0	0	3	44	194	470	478	259	59	9	0	(10)
(11)		CDD65	168	0	0	0	0	0	10	71	70	17	0	0	0	(11)
(12)		CDH74	1027	0	0	0	0	10	109	465	361	82	0	0	0	(12)
(13)		CDH80	170	0	0	0	0	1	14	79	65	11	0	0	0	(13)
(14)	Wind	WSAvg	10.9	12.4	12.4	12.3	11.7	10.4	9.7	9.1	8.9	9.8	10.6	11.4	12.2	(14)
(15)	Precipitation	PrecAvg	60.0	6.1	5.3	5.6	4.8	3.9	3.6	3.6	3.8	4.4	5.6	6.4	6.9	(15)
(16)		PrecMax	80.7	10.2	9.0	10.0	10.9	9.6	7.3	8.7	8.9	13.1	11.0	13.8	12.4	(16)
(17)		PrecMin	46.1	2.4	2.2	2.2	1.0	0.9	1.1	0.7	0.8	1.7	1.5	2.9	2.6	(17)
(18)		PrecStd	6.9	1.7	1.9	1.8	2.1	2.0	1.7	2.0	1.7	2.0	2.2	2.7	2.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.2	49.0	52.9	63.3	74.3	81.9	86.2	86.2	81.0	70.1	61.8	54.7	(19)
(20)			MCWB	50.9	47.6	45.9	53.5	59.7	66.2	71.4	71.3	68.9	62.5	59.3	53.3	(20)
(21)		2%	DB	46.1	43.5	46.6	55.5	69.2	77.2	82.1	81.3	75.9	65.8	58.4	50.4	(21)
(22)			MCWB	45.4	41.9	44.0	49.5	57.1	64.8	69.9	68.8	66.5	60.9	56.3	49.3	(22)
(23)		5%	DB	40.9	38.9	42.5	51.2	63.5	72.9	79.2	78.0	71.8	62.3	55.4	45.7	(23)
(24)			MCWB	39.8	37.1	39.6	46.3	53.7	61.7	67.6	67.4	64.8	58.2	53.6	44.5	(24)
(25)		10%	DB	36.2	34.9	38.8	47.5	58.4	68.6	76.2	74.9	68.7	59.1	51.5	41.4	(25)
(26)			MCWB	34.7	33.2	36.1	43.3	50.9	60.1	66.2	65.9	63.4	55.5	49.3	40.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.1	47.9	48.3	56.6	63.9	69.9	73.4	73.7	71.3	64.8	60.0	53.7	(27)
(28)			MCDWB	52.0	48.4	50.3	60.7	71.0	78.8	82.4	81.4	76.8	67.5	61.2	54.4	(28)
(29)		2%	WB	45.6	42.4	44.3	51.0	59.0	66.8	71.5	71.1	68.9	62.1	56.6	49.4	(29)
(30)			MCDWB	46.2	43.5	45.8	53.7	66.0	73.6	79.8	77.2	73.7	64.8	57.8	50.5	(30)
(31)		5%	WB	39.9	37.5	40.1	47.3	55.4	63.9	69.6	69.3	66.7	59.1	53.8	44.6	(31)
(32)			MCDWB	40.8	38.8	42.2	50.2	61.2	69.8	76.5	75.3	70.4	61.6	55.4	45.7	(32)
(33)		10%	WB	34.9	33.3	36.4	43.5	51.9	61.0	67.7	67.6	64.4	55.8	49.8	40.4	(33)
(34)			MCDWB	35.9	34.4	38.3	47.0	57.5	67.8	73.2	72.8	67.8	58.6	51.1	41.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	13.7	14.1	13.2	13.6	16.8	17.3	17.1	16.0	15.9	13.5	11.8	11.2	(35)
(36)			MCDBR	19.4	18.6	18.6	21.8	26.2	24.7	21.7	20.6	19.7	18.1	16.6	17.4	(36)
(37)			MCWBR	19.9	18.0	15.9	16.1	16.3	14.3	11.1	10.8	12.2	13.8	15.9	17.8	(37)
(38)		5% WB	MCDWB	19.4	18.7	18.0	19.6	23.3	20.9	18.5	17.6	16.2	16.2	16.0	17.0	(38)
(39)			MCWBR	20.1	18.8	16.8	16.7	16.4	13.8	10.5	10.4	11.9	14.1	16.2	17.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.303	0.297	0.329	0.359	0.370	0.390	0.420	0.394	0.364	0.346	0.324	0.300	(40)	
(41)		taud	2.368	2.401	2.366	2.391	2.430	2.396	2.350	2.428	2.488	2.500	2.490	2.443	(41)	
(42)		Ebn at Noon	251	280	285	285	285	278	267	271	271	259	244	241	(42)	
(43)		Edh at Noon	23	27	33	35	35	37	38	34	29	25	21	20	(43)	
(44)	All-Sky Solar Radiation	RadAvg	331	587	1003	1342	1618	1712	1702	1533	1200	746	393	253	(44)	
(45)		RadStd	25	64	89	106	147	156	115	107	88	64	49	21	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	+0.74	+1.10	N/A	N/A	N/A
(47) Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	+0.61	N/A	N/A	N/A

Nomenclature: See separate page