

MISCOU ISLAND, NB, Canada

WMO: 717190

Lat: 48.0089N

Lon: 64.4942W

Elev: 4

StdP: 101.28

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.9	-17.6	-27.0	0.3	-18.9	-23.6	0.4	-16.9	17.7	-5.5	16.1	-6.3	6.3	280	0.741

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.9	26.3	20.2	24.5	19.3	22.9	18.4	21.2	25.0	20.2	23.5	19.2	22.0	5.8	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.8	14.5	23.6	18.8	13.6	22.2	18.0	12.9	21.2	61.8	24.9	58.0	23.6	54.8	22.1	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
14.5	12.7	11.1		-22.8	30.2	2.3	1.5	-24.5	31.3	-25.9	32.2	-27.2	33.0	-28.9	34.1
			DB	-23.0	23.3	2.3	0.9	-24.7	24.0	-26.0	24.5	-27.3	25.1	-29.0	25.7
			WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.0	-8.2	-8.1	-4.1	1.4	7.7	13.6	18.1	18.0	13.9	8.1	2.1	-3.8
	DBStd	10.02	5.18	4.94	4.23	2.93	3.56	3.73	2.71	2.50	3.01	3.15	3.79	4.15
	HDD10.0	2612	564	508	438	259	92	8	0	0	3	76	237	427
	HDD18.3	4944	823	741	697	508	330	148	37	37	135	317	486	685
	CDD10.0	777	0	0	0	1	21	117	252	247	122	17	1	0
	CDD18.3	66	0	0	0	0	0	7	30	26	3	0	0	0
	CDH23.3	290	0	0	0	0	4	49	131	93	13	0	0	0
	CDH26.7	41	0	0	0	0	0	8	18	13	1	0	0	0
(14) Wind	WSAvg	5.5	6.4	5.8	6.0	5.4	4.7	4.6	4.4	4.5	5.2	5.8	6.1	6.6
(15) Precipitation	PrecAvg	958	65	62	72	68	87	82	85	78	77	101	87	83
	PrecMax	1409	130	132	120	134	172	175	130	151	151	204	162	216
	PrecMin	595	26	9	24	14	40	30	38	9	20	38	31	20
	PrecStd	166	28	31	26	32	37	32	25	36	33	40	27	41
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.5	3.4	6.0	13.3	23.2	27.9	28.8	28.5	25.1	19.2	13.5	6.6
		MCWB	4.0	2.5	3.6	8.5	15.6	19.7	21.7	21.7	20.3	15.0	12.3	6.0
	2%	DB	2.2	1.6	3.6	8.8	19.2	24.5	26.3	25.7	22.2	16.1	10.7	4.6
		MCWB	1.5	0.9	1.7	5.5	13.5	18.4	20.6	20.2	18.2	13.0	9.5	3.9
	5%	DB	0.7	0.3	2.4	6.7	15.9	21.9	24.7	24.0	20.2	14.2	9.0	3.0
		MCWB	0.1	-0.4	0.9	4.1	11.5	16.7	19.6	19.2	16.8	11.8	7.5	2.0
	10%	DB	-0.8	-0.8	1.3	5.2	13.3	19.7	23.0	22.4	18.7	12.8	7.2	1.7
		MCWB	-1.5	-1.4	0.1	3.2	10.0	15.5	18.6	18.5	15.9	10.7	5.8	1.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.3	3.0	4.0	9.4	17.1	21.1	22.8	22.5	20.9	16.0	12.5	6.2
		MCDB	4.5	3.3	5.3	12.7	21.9	25.9	27.6	27.2	24.2	18.4	13.2	6.6
	2%	WB	1.6	1.1	2.1	6.2	14.1	19.3	21.4	21.1	18.9	13.7	9.8	4.1
		MCDB	2.1	1.6	3.1	8.1	18.0	23.3	25.2	24.6	21.1	15.5	10.6	4.5
	5%	WB	0.2	-0.1	1.1	4.7	12.1	17.6	20.3	20.0	17.5	12.3	7.8	2.2
		MCDB	0.7	0.3	2.2	6.3	15.4	20.8	23.7	23.2	19.6	13.9	8.7	2.8
	10%	WB	-1.4	-1.3	0.2	3.5	10.2	16.0	19.3	19.1	16.2	11.0	6.0	1.1
		MCDB	-0.9	-0.7	1.1	4.9	13.0	19.1	22.2	21.6	18.2	12.5	6.9	1.6
(35) Mean Daily Temperature Range	5% DB	MDBR	6.9	7.2	6.6	5.8	7.7	8.4	7.9	7.5	7.2	5.7	5.1	5.2
		MCDBR	8.3	6.8	7.6	8.8	13.2	12.7	10.8	10.1	9.5	8.4	7.0	5.9
	5% WB	MCWBR	8.3	6.5	6.4	6.2	8.2	7.4	6.0	5.8	6.3	6.6	6.7	5.9
		MCWBR	8.4	6.7	7.3	8.1	12.5	11.4	9.6	8.9	8.5	7.7	6.7	5.7
(40) Clear-Sky Solar Irradiance	taub		0.281	0.283	0.318	0.353	0.367	0.385	0.416	0.391	0.360	0.338	0.309	0.289
		taud	2.407	2.305	2.312	2.401	2.428	2.390	2.348	2.409	2.480	2.510	2.509	2.459
	Ebn at Noon		802	880	899	899	896	878	843	851	848	811	766	747
		Edh at Noon	66	91	107	109	110	115	119	107	91	75	61	57
(44) All-Sky Solar Radiation	RadAvg		1.26	2.08	3.32	4.34	5.14	5.55	5.44	4.78	3.68	2.28	1.23	0.91
	RadStd		0.13	0.22	0.26	0.36	0.44	0.43	0.43	0.30	0.30	0.18	0.15	0.09

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)		N/A	N/A	+1.36	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page