

RIVIERE AUX FEUILLES, QC, Canada

WMO: 717430

Lat: 57.910N

Lon: 72.976W

Elev: 562

StdP: 14.40

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-41.0	-36.0	-48.1	0.3	-40.1	-43.0	0.5	-35.5	31.6	3.0	27.9	0.5	1.4	210	0.905

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.9	74.9	58.5	71.1	57.0	67.1	55.8	61.8	69.5	59.8	67.5	57.6	64.7	10.7	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
58.9	75.9	64.4	56.4	69.1	62.0	54.0	63.3	60.8	28.0	69.6	26.6	68.3	25.1	64.5	69.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.3	24.3	21.4	DB	-49.3	81.4	4.7	3.2	-52.7	83.7	-55.4	85.6	-58.0	87.4	-61.4	89.7	(4)
(5)			WB	-47.5	65.6	3.1	1.7	-49.7	66.8	-51.5	67.8	-53.2	68.8	-55.4	70.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	22.2	-12.3	-13.5	-3.0	12.8	31.7	47.5	55.0	53.7	42.7	32.4	17.0	0.2		
	DBStd	26.41	13.95	12.90	14.91	12.79	9.55	8.02	5.68	6.06	5.91	7.66	10.06	14.50		
	HDD50	10530	1932	1777	1644	1117	570	140	14	24	231	546	991	1544		
	HDD65	15626	2397	2197	2109	1567	1032	527	315	354	668	1010	1441	2009		
	CDD50	389	0	0	0	0	3	64	168	140	13	1	0	0		
	CDD65	9	0	0	0	0	0	1	4	4	0	0	0	0		
	CDH74	135	0	0	0	0	0	30	57	48	0	0	0	0		
	CDH80	10	0	0	0	0	0	2	2	6	0	0	0	0		
	WSAvg	9.9	8.6	8.4	9.6	10.4	11.1	10.3	10.0	9.4	11.0	10.8	10.1	9.0		
	PrecAvg	18.2	0.7	0.6	0.9	0.8	1.2	1.9	2.6	2.1	3.0	2.1	1.5	0.9		
(15) Precipitation	PrecMax	23.3	1.5	2.2	2.6	1.9	2.6	3.3	4.1	3.7	4.7	3.5	2.6	1.9		
	PrecMin	13.3	0.1	0.0	0.1	0.2	0.5	0.6	1.5	1.3	1.3	1.1	0.6	0.2		
	PrecStd	2.8	0.3	0.5	0.6	0.4	0.5	0.7	0.6	0.6	0.8	0.6	0.5	0.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.3	29.3	35.0	44.9	65.7	77.9	79.5	79.8	66.7	56.0	38.8	36.0		
		MCWB	31.3	28.3	32.8	39.5	50.9	59.9	60.1	62.5	56.0	51.0	36.7	35.3		
	2%	DB	21.3	20.5	30.7	39.1	58.1	72.6	75.0	73.8	60.3	50.3	35.0	30.4		
		MCWB	20.5	19.8	29.2	36.3	47.5	55.9	57.7	60.2	53.3	46.4	33.8	29.6		
	5%	DB	16.3	12.0	25.4	35.7	51.9	67.9	71.4	69.1	56.3	45.5	32.7	25.4		
		MCWB	15.7	11.1	24.0	33.6	44.1	54.1	56.3	58.4	50.5	42.8	31.8	24.5		
	10%	DB	9.7	5.5	20.7	32.4	45.9	63.5	67.4	65.1	52.6	41.9	29.5	20.8		
		MCWB	8.9	4.8	19.6	30.7	40.8	51.7	55.9	56.8	48.0	39.8	28.3	20.1		
	0.4%	WB	31.0	28.5	33.0	40.0	51.8	62.0	63.6	65.0	59.1	51.4	37.4	35.1		
		MCDB	32.1	29.6	34.7	44.3	63.1	72.2	71.4	72.8	64.5	54.4	38.8	35.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	20.7	19.9	29.4	36.6	47.9	59.5	61.1	62.5	54.5	47.0	34.0	29.5		
		MCDB	21.5	20.7	30.7	38.9	57.3	68.9	68.8	70.3	58.6	49.9	34.9	30.2		
	5%	WB	15.6	11.4	24.2	33.8	44.3	55.9	59.1	60.4	51.3	43.0	32.0	24.8		
		MCDB	16.2	12.2	25.4	35.5	51.4	64.9	66.9	67.3	55.7	45.0	32.8	25.5		
	10%	WB	9.1	4.9	19.5	30.5	40.7	52.5	57.3	57.8	48.5	40.0	28.4	20.2		
		MCDB	9.9	5.6	20.6	32.4	45.6	61.8	64.9	64.1	52.2	41.7	29.4	20.9		
	5% DB	MDBR	15.7	17.3	19.8	17.6	13.8	18.8	16.9	15.9	12.5	9.4	11.5	14.1		
		MCDBR	16.3	19.0	19.8	16.9	23.9	28.3	25.4	23.1	19.9	14.9	10.3	12.8		
		MCWBR	16.2	18.7	19.0	14.7	14.5	14.9	11.1	11.5	13.2	11.4	10.4	12.9		
		MCWBR	16.3	19.2	19.4	15.3	23.2	24.8	18.7	19.9	16.4	13.3	10.4	13.1		
(35) Mean Daily Temperature Range	5% WB	MCWBR	16.2	18.9	18.7	13.3	14.9	15.2	10.9	11.3	12.2	11.0	10.5	13.2		
	taub		0.228	0.253	0.301	0.378	0.363	0.359	0.381	0.358	0.335	0.294	0.250	0.203		
		taud	2.096	2.177	2.084	1.890	2.150	2.375	2.354	2.425	2.452	2.433	2.118	2.060		
(42) Clear-Sky Solar Irradiance	Ebn at Noon		201	252	266	258	275	279	269	268	257	238	184	174		
		Edh at Noon	16	24	36	52	43	35	35	30	25	19	16	12		
	RadAvg		204	522	1061	1605	1708	1695	1529	1217	744	362	146	117		
(45) All-Sky Solar Radiation	RadStd		15	36	76	115	168	163	134	93	75	35	32	10		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page