

RIVIERE AUX FEUILLES, QC, Canada

WMO: 717430

Lat: 57.910N

Lon: 72.976W

Elev: 171

StdP: 99.28

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-40.6	-37.8	-44.5	0.0	-40.0	-41.6	0.1	-37.5	14.1	-16.1	12.5	-17.5	0.6	210	0.905

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.4	23.8	14.7	21.7	13.9	19.5	13.2	16.5	20.9	15.5	19.7	14.2	18.1	4.8	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.0	10.8	18.0	13.5	9.9	16.7	12.2	9.0	16.0	47.3	20.9	44.0	20.1	40.6	18.1	21.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.2	10.8	9.6	DB	-45.2	27.5	2.6	1.8	-47.0	28.7	-48.6	29.8	-50.0	30.8	-51.9	32.1	(4)
(5)			WB	-44.2	18.7	1.7	1.0	-45.4	19.3	-46.4	19.9	-47.3	20.4	-48.6	21.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-5.4	-24.6	-25.3	-19.5	-10.7	-0.2	8.6	12.8	12.1	6.0	0.2	-8.4	-17.7
	DBStd	14.67	7.75	7.17	8.29	7.10	5.31	4.46	3.16	3.37	3.28	4.25	5.59	8.06
	HDD10.0	5850	1073	987	913	621	317	78	8	13	128	303	551	858
	HDD18.3	8681	1332	1221	1172	871	573	293	175	197	371	561	801	1116
	CDD10.0	216	0	0	0	0	2	36	93	78	7	1	0	0
	CDD18.3	5	0	0	0	0	0	1	2	2	0	0	0	0
	CDH23.3	75	0	0	0	0	0	17	32	27	0	0	0	0
	CDH26.7	6	0	0	0	0	0	1	1	3	0	0	0	0
Wind	WSAvg	4.4	3.8	3.8	4.3	4.7	4.9	4.6	4.5	4.2	4.9	4.8	4.5	4.0
Precipitation	PrecAvg	463	17	15	22	20	31	47	67	53	75	54	38	23
	PrecMax	593	38	56	66	49	65	85	104	94	120	90	67	47
	PrecMin	338	2	0	2	5	12	15	37	33	34	28	14	5
	PrecStd	71	8	12	15	10	13	17	16	16	20	16	12	10
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.2	-1.5	1.7	7.2	18.7	25.5	26.4	26.5	19.3	13.3	3.8	2.2
		MCWB	-0.4	-2.1	0.5	4.2	10.5	15.5	15.6	16.9	13.3	10.6	2.6	1.8
	2%	DB	-5.9	-6.4	-0.7	4.0	14.5	22.6	23.9	23.2	15.7	10.1	1.7	-0.9
		MCWB	-6.4	-6.8	-1.6	2.4	8.6	13.3	14.3	15.7	11.8	8.0	1.0	-1.4
	5%	DB	-8.7	-11.1	-3.7	2.0	11.1	19.9	21.9	20.6	13.5	7.5	0.4	-3.6
		MCWB	-9.1	-11.6	-4.5	0.9	6.7	12.3	13.5	14.6	10.3	6.0	-0.1	-4.1
	10%	DB	-12.4	-14.7	-6.3	0.2	7.7	17.5	19.6	18.4	11.5	5.5	-1.4	-6.2
		MCWB	-12.8	-15.1	-6.9	-0.7	4.9	10.9	13.3	13.8	8.9	4.4	-2.1	-6.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.6	-1.9	0.6	4.4	11.0	16.7	17.6	18.3	15.1	10.8	3.0	1.7
		MCDB	0.1	-1.3	1.5	6.9	17.3	22.4	21.9	22.7	18.1	12.5	3.8	2.0
	2%	WB	-6.3	-6.7	-1.5	2.5	8.8	15.3	16.2	16.9	12.5	8.4	1.1	-1.4
		MCDB	-5.8	-6.3	-0.7	3.8	14.0	20.5	20.5	21.3	14.8	9.9	1.6	-1.0
	5%	WB	-9.1	-11.5	-4.3	1.0	6.8	13.3	15.1	15.8	10.7	6.1	0.0	-4.0
		MCDB	-8.8	-11.0	-3.7	2.0	10.8	18.3	19.4	19.6	13.1	7.2	0.5	-3.6
	10%	WB	-12.7	-15.1	-7.0	-0.9	4.8	11.4	14.0	14.3	9.1	4.5	-2.0	-6.6
		MCDB	-12.3	-14.7	-6.3	0.2	7.6	16.6	18.3	17.9	11.2	5.4	-1.4	-6.2
Mean Daily Temperature Range		MDBR	8.7	9.6	11.0	9.8	7.7	10.5	9.4	8.8	7.0	5.2	6.4	7.8
	5% DB	MCDBR	9.1	10.5	11.0	9.4	13.3	15.7	14.1	12.8	11.1	8.3	5.7	7.1
		MCWBR	9.0	10.4	10.6	8.2	8.1	8.3	6.2	6.4	7.3	6.3	5.8	7.1
	5% WB	MCDBR	9.0	10.7	10.8	8.5	12.9	13.8	10.4	11.1	9.1	7.4	5.8	7.3
		MCWBR	9.0	10.5	10.4	7.4	8.3	8.4	6.1	6.3	6.8	6.1	5.9	7.3
Clear-Sky Solar Irradiance	taub	0.228	0.253	0.301	0.378	0.363	0.359	0.381	0.358	0.335	0.294	0.250	0.203	
	taud	2.096	2.177	2.084	1.890	2.150	2.375	2.354	2.425	2.452	2.433	2.118	2.060	
	Ebn at Noon	633	796	837	813	866	878	847	845	810	749	581	550	
	Edh at Noon	51	77	113	164	136	111	111	96	80	61	50	38	
All-Sky Solar Radiation	RadAvg	0.64	1.65	3.35	5.06	5.38	5.34	4.82	3.83	2.35	1.14	0.46	0.37	
	RadStd	0.05	0.11	0.24	0.36	0.53	0.51	0.42	0.29	0.24	0.11	0.10	0.03	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page