

WELLAND-PELHAM, ON, Canada

WMO: 717520

Lat: 42.9733N

Lon: 79.3250W

Elev: 180

StdP: 99.18

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-18.4	-15.2	-22.4	0.5	-18.1	-19.3	0.7	-14.6	11.2	-2.5	10.1	-2.4	2.9	260	0.494

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.7	29.6	21.8	28.4	21.2	27.2	20.6	23.6	27.3	22.8	26.5	22.0	25.6	3.6	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.4	17.4	25.9	21.5	16.6	25.1	20.7	15.7	24.4	71.3	27.3	68.2	26.5	65.3	25.7	26.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.9	7.9	6.9	-23.8	31.9	4.1	1.1	-26.7	32.6	-29.1	33.2	-31.4	33.8	-34.4	34.6		
(5)			-24.2	24.9	3.9	1.3	-27.0	25.8	-29.3	26.5	-31.5	27.2	-34.3	28.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.9	-3.9	-4.2	0.6	7.1	14.2	18.8	21.4	20.5	17.0	10.8	4.3	-0.6		
	DBStd	10.24	6.31	6.14	5.70	4.61	4.47	3.21	2.82	2.80	3.89	4.53	4.72	5.00		
	HDD10.0	1800	432	397	296	109	12	0	0	0	1	45	179	328		
	HDD18.3	3714	690	630	550	336	144	32	6	11	69	237	422	586		
	CDD10.0	1401	1	0	4	23	141	264	353	325	212	71	8	1		
	CDD18.3	274	0	0	0	0	15	47	101	78	31	3	0	0		
	CDH23.3	1943	0	0	1	6	143	302	725	522	231	13	0	0		
	CDH26.7	359	0	0	0	0	23	53	148	88	45	1	0	0		
(14) Wind	WSAvg	3.1	3.9	3.8	3.5	3.6	2.9	2.7	2.3	2.3	2.3	3.1	3.4	3.7		
(15) Precipitation	PrecAvg	968	80	54	69	83	85	67	85	80	97	88	95	75		
	PrecMax	1166	134	111	127	141	154	171	186	141	190	198	140	156		
	PrecMin	795	40	29	36	41	20	18	27	30	37	35	43	31		
	PrecStd	120	28	19	26	28	39	39	42	30	38	41	24	29		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.9	12.8	20.0	23.8	28.9	29.8	31.2	30.9	30.0	25.0	18.6	13.9		
		MCWB	10.9	9.3	15.0	15.8	20.4	20.4	22.3	21.5	22.3	19.1	13.6	11.5		
	2%	DB	9.6	9.6	14.0	20.8	26.9	28.3	29.8	28.8	28.0	22.3	16.0	10.5		
		MCWB	7.8	7.1	9.8	13.3	19.3	20.2	22.3	21.7	21.5	17.2	12.2	8.5		
	5%	DB	6.9	6.2	11.4	17.7	24.8	26.6	28.4	27.5	26.1	20.3	14.1	8.5		
		MCWB	5.1	4.2	8.3	11.7	17.7	19.5	21.3	21.1	20.0	16.6	10.4	6.8		
	10%	DB	4.6	3.7	8.9	15.0	22.3	25.0	27.1	26.2	24.1	18.3	12.0	6.2		
		MCWB	3.3	1.9	6.1	10.0	16.0	18.9	20.7	20.7	19.5	15.1	9.3	4.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.0	10.6	15.2	16.6	21.7	22.8	25.2	24.5	23.6	20.8	14.7	11.3		
		MCDB	12.4	12.1	19.4	22.8	27.5	28.0	29.2	28.2	27.3	24.2	17.7	13.2		
	2%	WB	7.8	7.1	11.0	14.3	20.1	21.7	23.9	23.4	22.5	18.9	12.9	8.7		
		MCDB	9.0	9.1	13.0	19.2	25.9	26.1	27.5	26.9	26.1	20.8	15.7	9.9		
	5%	WB	5.3	4.3	8.6	12.6	18.7	20.8	22.9	22.6	21.5	17.0	11.1	6.6		
		MCDB	6.5	6.0	11.1	16.2	23.6	24.6	26.7	25.9	25.0	19.7	13.4	8.2		
	10%	WB	3.1	2.0	6.2	10.7	17.2	19.9	22.0	21.7	20.3	15.3	9.5	4.4		
		MCDB	4.4	3.5	8.7	14.0	21.1	23.5	25.6	24.9	23.4	17.9	11.9	5.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.4	8.0	8.6	10.2	11.0	9.7	9.7	9.8	10.2	8.7	7.9	6.3		
		MCDBR	8.6	10.9	12.4	15.1	13.7	11.8	10.7	10.7	11.8	10.9	11.1	8.5		
	5% WB	MCWBR	7.9	9.2	8.8	9.4	7.1	5.9	5.2	5.4	6.4	6.9	8.1	7.8		
		MCWBR	8.2	10.6	11.3	12.9	12.3	9.2	8.8	8.7	10.1	9.3	10.1	8.7		
(40) Clear-Sky Solar Irradiance	taub	taub	0.298	0.333	0.335	0.377	0.405	0.435	0.436	0.422	0.382	0.362	0.314	0.300		
		taud	2.410	2.303	2.397	2.322	2.292	2.241	2.259	2.285	2.375	2.409	2.509	2.462		
	Ebn at Noon	Ebn at Noon	839	858	907	889	870	841	836	835	845	817	818	804		
		Edh at Noon	77	101	104	122	129	137	133	125	106	91	70	68		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.34	2.12	3.28	4.42	5.41	5.88	5.91	5.23	4.15	2.52	1.56	1.06		
	RadStd	RadStd	0.12	0.20	0.38	0.47	0.56	0.43	0.45	0.28	0.38	0.24	0.22	0.13		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (50 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page