

UPPER STEWIACKE, NS, Canada

WMO: 717530

Lat: 45.2326N

Lon: 63.0546W

Elev: 24

StdP: 101.04

Time Zone: -4.00 (NAA)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-21.1	-18.0	-24.3	0.4	-19.5	-21.6	0.5	-16.3	12.2	1.3	10.9	1.7	1.0	40	0.587

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.2	28.4	20.4	26.9	19.7	25.5	18.9	22.1	26.4	21.2	24.9	20.3	23.6	4.0	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.7	15.4	24.4	19.9	14.6	23.2	19.0	13.8	22.3	65.0	26.4	61.6	25.1	58.5	23.6	27.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.4	7.3	-26.3	31.1	2.7	1.0	-28.3	31.8	-29.9	32.5	-31.4	33.0	-33.4	33.8		
(5)			-26.5	24.1	2.7	1.2	-28.5	25.0	-30.1	25.6	-31.6	26.3	-33.6	27.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.6	-5.0	-5.3	-1.7	4.3	9.8	14.6	19.0	18.3	14.1	8.5	3.6	-1.7	(6)
(7)		DBStd	9.54	6.07	5.73	4.97	3.90	3.43	3.44	2.68	2.79	3.94	4.21	4.94	5.78	(7)
(8)		HDD10.0	2139	466	429	363	177	46	4	0	0	8	81	203	363	(8)
(9)		HDD18.3	4378	724	663	621	422	264	121	25	34	134	306	443	621	(9)
(10)		CDD10.0	899	0	0	1	6	40	141	278	258	132	34	9	1	(10)
(11)		CDD18.3	96	0	0	0	0	1	8	45	34	8	1	0	0	(11)
(12)		CDH23.3	879	0	0	1	2	21	82	403	307	63	1	0	0	(12)
(13)		CDH26.7	147	0	0	0	0	3	9	77	49	8	0	0	0	(13)
(14)	Wind	WSAvg	3.0	3.3	3.4	3.7	3.6	3.2	2.8	2.4	2.2	2.4	2.8	3.1	3.2	(14)
(15)	Precipitation	PrecAvg	1311	120	96	104	94	95	94	98	108	91	115	133	141	(15)
(16)		PrecMax	1611	230	170	168	169	169	269	196	336	153	230	257	250	(16)
(17)		PrecMin	916	31	30	29	17	32	26	21	15	24	30	34	77	(17)
(18)		PrecStd	207	44	39	39	37	41	46	50	62	38	52	52	49	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.5	11.3	14.7	20.0	26.2	28.1	30.6	30.0	28.2	22.6	18.0	14.4	(19)
(20)			MCWB	11.7	10.2	9.5	12.9	16.4	18.3	21.7	21.8	21.0	17.6	16.0	13.0	(20)
(21)		2%	DB	9.1	7.6	10.6	16.4	22.2	25.6	28.7	28.0	25.2	20.0	16.3	11.7	(21)
(22)			MCWB	8.4	6.2	7.5	11.3	15.0	18.3	20.9	20.4	19.2	16.2	14.8	10.8	(22)
(23)		5%	DB	6.3	4.9	7.9	13.9	19.3	23.8	27.2	26.5	23.2	18.0	14.6	9.1	(23)
(24)			MCWB	5.2	3.2	5.5	9.9	12.9	17.1	19.9	19.5	18.3	15.4	13.2	8.2	(24)
(25)		10%	DB	3.4	2.6	5.5	11.8	17.1	21.8	25.7	25.0	21.5	16.3	12.5	6.5	(25)
(26)			MCWB	2.3	1.4	3.1	8.5	12.2	16.5	19.3	18.8	17.9	13.7	10.9	5.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.8	10.3	11.0	15.2	18.5	21.7	23.2	23.1	22.2	19.7	16.5	13.4	(27)
(28)			MCD B	12.5	11.2	12.5	18.6	23.8	25.8	28.1	27.5	26.7	20.8	17.5	14.2	(28)
(29)		2%	WB	8.5	6.7	8.2	12.9	16.3	20.0	22.3	22.0	20.8	17.3	15.1	10.7	(29)
(30)			MCD B	9.1	7.4	9.5	15.1	19.7	23.0	26.7	25.9	23.1	18.9	16.1	11.6	(30)
(31)		5%	WB	5.4	3.6	5.7	10.9	14.4	18.6	21.4	20.9	19.8	15.8	13.6	8.2	(31)
(32)			MCD B	6.2	4.6	7.5	13.1	17.5	21.9	25.3	24.9	22.0	17.4	14.6	8.9	(32)
(33)		10%	WB	2.5	1.5	3.4	9.0	13.0	17.2	20.4	19.8	18.6	14.0	11.1	5.7	(33)
(34)			MCD B	3.3	2.4	5.4	10.9	16.1	20.7	23.9	23.5	20.9	16.1	12.2	6.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.2	10.3	10.4	10.9	11.9	11.8	12.2	12.5	12.8	11.3	9.4	8.8	(35)
(36)			MCDBR	12.5	11.2	13.6	15.7	17.0	15.8	15.3	14.8	14.5	12.8	11.1	11.4	(36)
(37)			MCWBR	12.5	10.0	10.6	10.7	10.1	9.2	8.3	8.3	9.1	9.4	9.7	11.3	(37)
(38)		5% WB	MCDBR	12.3	10.5	12.6	12.5	12.7	11.8	12.0	12.5	10.7	10.8	9.9	11.3	(38)
(39)			MCWBR	12.3	10.0	11.0	10.0	8.6	7.4	7.2	7.5	7.6	9.0	9.4	11.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.298	0.293	0.322	0.353	0.369	0.397	0.414	0.397	0.351	0.331	0.314	0.291	(40)	
(41)		taud	2.451	2.484	2.448	2.411	2.410	2.356	2.330	2.375	2.481	2.532	2.530	2.525	(41)	
(42)		Ebn at Noon	818	900	914	908	899	871	851	853	871	843	796	796	(42)	
(43)		Edh at Noon	70	81	97	110	114	121	122	113	93	77	65	59	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.37	2.20	3.40	4.18	4.87	5.29	5.35	4.92	3.91	2.50	1.41	1.03	(44)	
(45)		RadStd	0.12	0.18	0.23	0.37	0.57	0.48	0.38	0.36	0.30	0.27	0.15	0.07	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (37 neighbors)		N/A	N/A	N/A	N/A	N/A	+0.44	N/A	N/A	+54	+16

Nomenclature: See separate page