

LYTTON, BC, Canada

WMO: 717650

Lat: 50.2244N

Lon: 121.5819W

Elev: 225

StdP: 98.65

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-15.7	-12.8	-22.6	0.5	-13.9	-19.1	0.7	-11.6	14.1	5.8	13.0	5.5	3.3	0	0.709

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.3	35.4	18.3	33.2	17.8	30.9	17.0	19.4	32.0	18.5	30.6	17.7	29.0	5.4	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.4	11.2	21.2	14.3	10.4	21.1	13.3	9.8	20.7	55.9	32.5	53.0	30.6	50.5	29.1	23.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.8	12.5	11.5	-17.4	39.0	3.7	1.7	-20.1	40.3	-22.3	41.3	-24.3	42.2	-27.0	43.4		
(5)			-18.1	20.8	3.6	1.2	-20.7	21.7	-22.8	22.3	-24.8	23.0	-27.4	23.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.4	-1.0	1.4	5.8	10.3	15.2	18.5	22.5	22.1	17.2	9.8	3.4	-1.1		
	DBStd	9.29	5.88	4.41	3.88	3.15	3.62	3.53	3.63	3.40	3.58	3.34	4.77	5.31		
	HDD10.0	1337	341	240	134	33	3	0	0	0	1	43	198	343		
	HDD18.3	3244	599	473	388	242	112	40	8	8	63	263	447	601		
	CDD10.0	1482	0	0	5	42	163	254	387	376	215	38	2	0		
	CDD18.3	347	0	0	0	0	14	44	136	126	28	0	0	0		
	CDH23.3	3951	0	0	0	21	226	521	1537	1329	316	2	0	0		
	CDH26.7	1785	0	0	0	4	73	221	757	621	109	0	0	0		
(14) Wind	WSAvg	4.8	3.3	3.5	5.0	5.6	5.8	6.5	6.3	5.6	4.5	4.4	3.8	3.2		
(15) Precipitation	PrecAvg	455	71	47	34	20	18	19	15	18	27	37	69	76		
	PrecMax	637	193	149	78	42	45	96	44	34	67	95	166	167		
	PrecMin	273	6	12	10	3	3	1	0	1	2	1	6	7		
	PrecStd	113	47	32	18	11	11	21	13	10	17	26	47	45		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.3	12.3	19.2	26.1	32.2	36.0	38.8	37.6	33.0	22.2	14.3	10.6		
		MCWB	7.3	7.3	10.3	13.1	16.2	18.1	19.8	19.1	17.4	13.9	10.5	7.3		
	2%	DB	8.9	10.1	15.6	22.1	28.8	32.2	36.0	35.0	29.9	18.9	12.0	8.3		
		MCWB	6.1	6.4	8.8	11.6	15.0	17.0	18.5	18.3	16.5	11.9	9.1	5.9		
	5%	DB	7.2	8.6	13.5	19.0	25.8	29.0	33.5	32.7	27.0	16.7	10.6	6.8		
		MCWB	5.1	5.4	7.6	9.9	13.9	15.6	18.1	17.8	15.6	11.1	8.1	4.9		
	10%	DB	5.8	7.2	11.6	16.6	22.9	26.0	31.1	30.3	24.3	15.0	9.2	5.5		
		MCWB	4.1	4.4	6.8	9.1	12.8	14.9	17.3	17.1	14.6	10.3	7.0	3.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.8	8.4	11.0	14.0	17.0	18.9	21.3	20.2	18.2	14.7	11.5	7.7		
		MCDB	10.0	10.9	17.0	24.4	29.1	33.0	34.1	33.1	29.2	19.4	13.3	9.7		
	2%	WB	6.4	7.0	9.4	12.2	15.6	17.6	19.8	19.2	17.2	13.3	9.4	6.1		
		MCDB	8.5	9.4	14.5	20.2	26.6	29.9	32.2	31.6	27.0	17.6	11.5	8.0		
	5%	WB	5.3	5.7	8.2	10.8	14.6	16.5	18.7	18.4	16.3	11.8	8.3	5.0		
		MCDB	7.0	8.1	12.5	17.8	23.9	26.9	31.0	30.4	25.2	15.7	10.3	6.6		
	10%	WB	4.2	4.7	7.1	9.6	13.5	15.4	17.8	17.6	15.3	10.7	7.3	3.9		
		MCDB	5.7	7.0	11.1	15.7	21.6	24.7	29.2	28.8	23.1	14.2	9.1	5.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.4	7.4	9.3	11.3	12.2	11.5	13.3	13.5	12.3	8.6	5.5	4.9		
		MCDBR	7.0	8.7	12.9	17.1	18.5	18.5	18.9	19.1	18.4	11.4	6.5	6.1		
	5% WB	MCWBR	5.2	5.5	6.9	7.9	7.2	6.6	5.8	6.0	6.9	5.9	4.4	4.3		
		MCWBR	6.8	8.1	11.5	15.1	16.1	16.3	17.0	16.9	16.0	9.8	6.1	6.0		
(40) Clear-Sky Solar Irradiance	taub		0.296	0.303	0.332	0.380	0.391	0.380	0.367	0.369	0.354	0.355	0.315	0.287		
		taud	2.281	2.312	2.271	2.158	2.264	2.367	2.426	2.439	2.464	2.388	2.380	2.319		
	Ebn at Noon		731	834	869	859	866	878	884	865	842	761	708	687		
		Edh at Noon	69	87	108	136	128	117	108	102	90	81	64	58		
(44) All-Sky Solar Radiation	RadAvg		1.00	1.93	3.09	4.50	5.43	5.81	6.44	5.49	3.82	2.21	1.07	0.77		
	RadStd		0.11	0.16	0.25	0.37	0.45	0.54	0.52	0.34	0.32	0.23	0.12	0.09		

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+52	(46)
(47) Regional (38 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page