

CRESTON, BC, Canada

WMO: 717700

Lat: 49.0817N

Lon: 116.5007W

Elev: 646

StdP: 93.80

Time Zone: -7.00 (W07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-13.8	-11.1	-20.6	0.6	-12.5	-16.7	0.9	-9.8	7.4	-2.8	6.8	-3.1	2.7	70	0.515

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.6	32.6	19.3	30.7	18.5	28.8	17.7	20.7	29.9	19.5	28.4	18.4	26.9	2.2	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.6	13.6	25.4	16.3	12.5	23.4	15.1	11.6	22.1	62.8	30.2	58.3	28.4	54.6	27.3	26.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.0	6.0	5.1	-16.3	35.7	3.4	1.5	-18.8	36.8	-20.8	37.7	-22.7	38.5	-25.2	39.6
			-17.0	23.2	3.4	1.4	-19.4	24.2	-21.4	25.0	-23.3	25.8	-25.8	26.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.9	-1.5	-0.1	4.0	8.4	13.4	16.6	21.4	20.8	15.2	8.0	2.1	-2.0	(6)
(7)		DBStd	8.98	4.42	4.02	3.55	3.29	3.87	3.69	3.51	3.30	3.70	3.56	3.78	4.22	(7)
(8)		HDD10.0	1600	357	284	186	68	11	1	0	0	3	82	237	371	(8)
(9)		HDD18.3	3679	616	517	444	297	158	76	13	15	107	321	487	629	(9)
(10)		CDD10.0	1206	0	0	1	22	117	199	352	335	160	19	0	0	(10)
(11)		CDD18.3	242	0	0	0	0	6	24	108	92	13	0	0	0	(11)
(12)		CDH23.3	2419	0	0	0	3	96	249	1078	861	132	1	0	0	(12)
(13)		CDH26.7	901	0	0	0	0	18	72	449	331	31	0	0	0	(13)
(14)	Wind	WSAvg	1.9	1.6	1.7	2.1	2.3	2.2	2.1	2.1	2.0	1.8	1.7	1.7	1.6	(14)
(15)	Precipitation	PrecAvg	579	63	39	43	39	55	58	30	27	30	43	67	71	(15)
(16)		PrecMax	833	124	83	92	80	164	137	59	65	96	160	169	140	(16)
(17)		PrecMin	459	25	7	0	14	23	16	0	3	1	0	22	30	(17)
(18)		PrecStd	98	22	19	25	16	31	27	18	16	23	31	34	27	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.7	9.7	16.5	23.3	29.0	32.0	35.2	34.5	30.0	20.9	12.6	7.6	(19)
(20)			MCWB	5.4	6.0	9.2	13.6	17.2	18.8	20.3	19.8	17.0	14.1	9.9	5.1	(20)
(21)		2%	DB	5.7	7.1	13.2	19.5	26.1	28.6	33.3	32.3	26.8	17.6	9.8	5.7	(21)
(22)			MCWB	3.8	4.5	7.7	11.4	15.4	18.0	19.6	18.8	16.4	11.6	7.6	4.1	(22)
(23)		5%	DB	4.3	5.7	10.9	16.9	23.4	26.2	31.3	30.3	24.4	15.2	8.2	4.2	(23)
(24)			MCWB	2.9	3.5	6.5	9.9	14.1	16.8	19.1	18.0	15.3	10.5	6.6	3.0	(24)
(25)		10%	DB	3.1	4.4	9.1	14.6	20.8	23.8	29.2	28.3	22.0	13.2	7.0	2.8	(25)
(26)			MCWB	2.1	2.7	5.4	8.7	12.8	15.4	18.4	17.3	14.3	9.4	5.7	2.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.9	6.9	10.1	14.3	18.2	20.8	23.1	21.8	18.4	14.8	10.5	6.0	(27)
(28)			MCDWB	7.3	8.3	14.2	22.0	27.2	29.7	32.4	31.3	27.1	19.0	11.9	6.9	(28)
(29)		2%	WB	4.2	5.0	8.2	12.0	16.2	18.9	21.4	20.0	17.0	12.7	8.3	4.5	(29)
(30)			MCDWB	5.3	6.6	12.4	18.4	24.0	26.7	30.3	29.6	24.8	16.4	9.3	5.5	(30)
(31)		5%	WB	3.2	3.8	7.0	10.4	14.8	17.4	20.1	18.9	16.0	11.2	7.1	3.3	(31)
(32)			MCDWB	4.1	5.2	10.1	15.8	21.9	24.8	28.9	28.3	23.2	14.1	8.0	4.1	(32)
(33)		10%	WB	2.2	2.9	5.8	9.1	13.5	16.1	18.9	17.9	14.8	9.9	5.8	2.1	(33)
(34)			MCDWB	3.0	4.1	8.5	13.7	19.8	22.3	27.4	26.5	21.2	12.8	6.8	2.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.5	6.1	8.2	10.2	11.6	11.3	13.6	13.6	11.7	8.6	5.1	4.1	(35)
(36)			MCDBR	5.5	7.0	11.2	14.3	15.6	15.0	16.2	16.2	15.2	11.2	6.4	5.2	(36)
(37)			MCWBR	4.1	4.8	6.8	8.0	8.2	7.9	7.8	7.6	7.6	6.6	4.7	4.0	(37)
(38)		5% WB	MCDBR	5.3	6.5	10.3	13.3	14.3	14.0	15.1	15.1	14.1	10.1	5.9	4.9	(38)
(39)			MCWBR	4.1	4.7	6.6	7.8	8.0	7.7	8.0	7.5	7.3	6.2	4.6	3.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.267	0.276	0.298	0.368	0.374	0.371	0.366	0.379	0.343	0.313	0.287	0.262	(40)	
(41)		taud	2.323	2.304	2.293	2.204	2.340	2.394	2.417	2.386	2.473	2.539	2.480	2.356	(41)	
(42)		Ebn at Noon	797	880	916	876	885	889	888	858	860	834	778	754	(42)	
(43)		Edh at Noon	68	88	107	131	120	114	110	109	90	71	59	58	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.94	1.86	2.78	4.28	5.35	5.62	6.80	5.68	3.99	2.29	1.03	0.74	(44)	
(45)		RadStd	0.13	0.24	0.39	0.41	0.44	0.53	0.52	0.45	0.43	0.31	0.15	0.10	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	-0.60	N/A	N/A	N/A	N/A	N/A
(47) Regional (18 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+58	N/A

Nomenclature: See separate page