

ENTRANCE ISLAND, BC, Canada

WMO: 717720

Lat: 49.2090N

Lon: 123.8100W

Elev: 25

StdP: 14.68

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 30.0	(c) 32.5	(d) 12.7	(e) 10.5	(f) 33.3	(g) 19.0	(h) 14.3	(i) 35.9	(j) 36.0	(k) 43.0	(l) 33.2	(m) 44.3	(n) 12.9	(o) 130	(p) 0.644

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 7.3	(c) 74.4	(d) 64.6	(e) 72.0	(f) 63.7	(g) 70.1	(h) 63.0	(i) 65.7	(j) 71.1	(k) 64.7	(l) 70.2	(m) 63.7	(n) 69.0	(o) 9.8	(p) 310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.3	87.2	69.7	62.1	83.5	68.5	61.1	80.4	67.5	30.6	71.2	29.7	70.4	29.0	69.3	
					</										

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 31.8	(b) 28.1	(c) 25.1	(e) 27.8	(f) 79.9	(g) 3.3	(h) 4.0	(i) 25.4	(j) 82.8	(k) 23.4	(l) 85.2	(m) 21.6	(n) 87.4	(o) 19.1	(p) 90.4		
(4) 31.8	(5) 28.1	(6) 25.1	(7) 24.7	(8) 68.2	(9) 3.4	(10) 1.0	(11) 22.3	(12) 68.9	(13) 20.3	(14) 69.5	(15) 18.4	(16) 70.1	(17) 16.0	(18) 70.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.2	42.3	42.7	45.3	49.5	55.5	60.4	64.9	65.1	59.9	52.0	46.2	42.4
	DBStd	9.29	4.55	3.95	3.67	3.58	4.34	4.13	3.76	3.70	3.66	3.46	4.35	4.65
	HDD50	1030	241	206	150	49	5	0	0	0	0	18	125	236
	HDD65	4772	705	625	611	465	295	150	49	44	160	404	564	700
	CDD50	1845	1	0	5	34	176	312	461	468	296	79	11	2
	CDD65	111	0	0	0	0	1	12	45	47	6	0	0	0
	CDH74	106	0	0	0	1	3	16	38	46	2	0	0	0
	CDH80	10	0	0	0	0	0	1	2	7	0	0	0	0
Wind	WSAvg	11.8	12.4	12.1	12.1	11.3	10.5	10.7	11.3	10.7	10.9	11.8	13.2	13.9
Precipitation	PrecAvg	42.0	6.5	4.2	3.9	2.3	1.7	1.5	0.8	1.1	1.5	4.2	6.3	7.1
	PrecMax	54.5	13.2	12.2	8.0	4.5	3.3	2.8	1.6	4.8	4.9	9.6	14.1	10.7
	PrecMin	25.7	1.8	0.6	1.0	0.7	0.2	0.3	0.0	0.2	0.1	0.8	2.1	2.9
	PrecStd	7.4	2.6	2.3	1.6	1.1	0.9	0.7	0.4	1.0	1.2	2.1	2.9	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.5	52.9	56.3	64.3	70.2	76.1	78.1	78.4	72.3	61.6	57.5	54.1
		MCWB	48.9	48.2	49.4	55.7	59.0	61.3	66.2	64.2	64.6	56.9	53.0	49.7
	2%	DB	50.2	50.0	52.8	58.3	65.9	71.2	74.4	74.2	68.9	58.9	54.1	50.8
		MCWB	47.3	46.6	47.9	52.0	58.1	62.4	64.9	64.6	62.7	54.5	51.2	47.7
	5%	DB	48.7	48.3	50.9	55.7	63.2	68.4	72.0	71.8	66.4	57.3	52.5	49.2
		MCWB	46.5	45.4	46.9	50.1	56.5	61.1	63.8	64.0	61.0	53.4	50.2	46.5
	10%	DB	47.5	47.2	49.5	53.9	61.0	66.0	70.0	69.9	64.6	55.9	51.3	47.8
		MCWB	45.5	44.7	46.1	48.8	55.2	59.5	62.9	63.5	59.5	52.5	49.2	45.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.0	49.6	51.2	55.2	61.0	65.1	68.2	67.3	65.3	58.1	53.3	50.2
		MCDB	51.2	51.7	54.9	58.3	66.7	70.3	74.9	72.8	70.6	60.3	54.8	52.2
	2%	WB	47.9	47.4	49.0	52.7	58.5	63.1	66.1	65.7	63.4	56.2	51.8	48.5
		MCDB	49.0	48.7	51.8	56.1	63.8	69.0	71.6	70.9	68.1	57.8	53.2	50.1
	5%	WB	46.8	46.2	47.7	50.7	57.1	61.4	64.8	64.7	61.7	54.7	50.8	47.0
		MCDB	48.0	47.5	50.1	54.0	62.0	67.3	70.4	70.1	65.7	56.3	52.3	48.7
	10%	WB	45.9	45.2	46.7	49.4	55.8	60.0	63.7	63.7	60.1	53.3	49.6	45.9
		MCDB	47.2	46.7	49.1	52.6	60.1	65.4	69.2	69.0	63.6	55.2	51.3	47.7
Mean Daily Temperature Range	5% DB	MDBR	4.6	5.4	6.1	7.0	7.8	7.9	8.0	7.3	6.2	4.9	5.0	4.7
		MCDBR	6.4	7.2	8.2	10.0	11.3	12.2	10.9	10.3	8.8	6.6	6.7	6.7
		MCWBR	4.6	4.8	5.3	5.7	5.9	6.2	5.8	5.2	4.7	4.5	5.0	4.3
	5% WB	MCDBR	5.1	5.5	7.5	7.6	9.1	9.4	9.1	7.9	7.5	5.4	5.6	5.6
		MCWBR	4.4	4.4	5.4	5.5	5.9	6.2	6.0	5.2	4.9	4.3	4.8	4.4
Clear-Sky Solar Irradiance	taub	0.316	0.307	0.328	0.358	0.375	0.362	0.350	0.351	0.335	0.332	0.314	0.305	
	taud	2.492	2.557	2.512	2.436	2.411	2.464	2.540	2.538	2.579	2.559	2.545	2.500	
	Ebn at Noon	237	272	282	283	281	285	287	282	277	258	237	225	
	Edh at Noon	19	23	28	33	35	34	31	30	26	22	18	17	
All-Sky Solar Radiation	RadAvg	271	548	820	1275	1660	1786	1975	1677	1175	644	321	216	
	RadStd	43	83	111	133	150	205	175	134	103	92	59	33	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (65 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page