

ENTRANCE ISLAND, BC, Canada

WMO: 717720

Lat: 49.2090N

Lon: 123.8100W

Elev: 8

StdP: 101.23

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -1.1	(c) 0.3	(d) -10.7	(e) 1.5	(f) 0.7	(g) -7.2	(h) 2.0	(i) 2.1	(j) 16.1	(k) 6.1	(l) 14.8	(m) 6.8	(n) 5.8	(o) 130	(p) 0.644

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 4.1	(c) 23.6	(d) 18.1	(e) 22.2	(f) 17.6	(g) 21.1	(h) 17.2	(i) 18.7	(j) 21.7	(k) 18.2	(l) 21.2	(m) 17.6	(n) 20.6	(o) 4.4	(p) 310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 17.4	(b) 12.5	(c) 21.0	(d) 16.7	(e) 11.9	(f) 20.3	(g) 16.1	(h) 11.5	(i) 19.7	(j) 53.2	(k) 21.8	(l) 51.3	(m) 21.4	(n) 49.5	(o) 20.7	(p) 21.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.2	12.6	11.2	-2.4	26.6	1.9	2.2	-3.7	28.2	-4.8	29.5	-5.8	30.8	-7.1	32.4
			-4.0	20.1	1.9	0.6	-5.4	20.5	-6.5	20.8	-7.5	21.2	-8.9	21.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.2	5.7	5.9	7.4	9.7	13.1	15.8	18.3	18.4	15.5	11.1	7.9	5.8		
	DBStd	5.16	2.53	2.20	2.04	1.99	2.41	2.30	2.09	2.06	2.03	1.92	2.42	2.58		
	HDD10.0	572	134	114	83	27	3	0	0	0	0	10	69	131		
	HDD18.3	2651	392	347	339	258	164	83	27	24	89	224	313	389		
	CDD10.0	1025	1	0	3	19	98	173	256	260	164	44	6	1		
	CDD18.3	62	0	0	0	0	1	7	25	26	3	0	0	0		
	CDH23.3	59	0	0	0	1	2	9	21	26	1	0	0	0		
	CDH26.7	6	0	0	0	0	0	1	4	4	0	0	0	0		
(14) Wind	WSAvg	5.3	5.6	5.4	5.4	5.0	4.7	4.8	5.1	4.8	4.9	5.3	5.9	6.2		
(15) Precipitation	PrecAvg	1066	166	106	100	59	44	38	21	27	38	106	161	181		
	PrecMax	1385	335	310	203	115	85	71	40	121	124	243	358	273		
	PrecMin	652	46	15	25	18	4	8	1	4	3	20	53	73		
	PrecStd	189	66	59	40	28	23	18	11	25	31	53	74	52		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.9	11.6	13.5	17.9	21.2	24.5	25.6	25.8	22.4	16.4	14.2	12.3		
		MCWB	9.4	9.0	9.6	13.1	15.0	16.3	19.0	17.9	18.1	13.8	11.7	9.8		
	2%	DB	10.1	10.0	11.6	14.6	18.8	21.8	23.5	23.5	20.5	15.0	12.3	10.4		
		MCWB	8.5	8.1	8.8	11.1	14.5	16.9	18.3	18.1	17.1	12.5	10.7	8.7		
	5%	DB	9.3	9.1	10.5	13.2	17.3	20.2	22.2	22.1	19.1	14.1	11.4	9.5		
		MCWB	8.0	7.4	8.3	10.1	13.6	16.2	17.7	17.8	16.1	11.9	10.1	8.0		
	10%	DB	8.6	8.4	9.7	12.2	16.1	18.9	21.1	21.0	18.1	13.3	10.7	8.8		
		MCWB	7.5	7.0	7.8	9.4	12.9	15.3	17.1	17.5	15.3	11.4	9.5	7.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.0	9.8	10.7	12.9	16.1	18.4	20.1	19.6	18.5	14.5	11.9	10.1		
		MCDB	10.7	10.9	12.7	14.6	19.3	21.3	23.8	22.7	21.5	15.7	12.7	11.2		
	2%	WB	8.8	8.5	9.5	11.5	14.7	17.3	18.9	18.7	17.5	13.4	11.0	9.2		
		MCDB	9.4	9.3	11.0	13.4	17.7	20.5	22.0	21.6	20.1	14.4	11.8	10.1		
	5%	WB	8.2	7.9	8.7	10.4	13.9	16.3	18.2	18.2	16.5	12.6	10.4	8.3		
		MCDB	8.9	8.6	10.1	12.2	16.7	19.6	21.3	21.2	18.7	13.5	11.3	9.3		
	10%	WB	7.7	7.3	8.2	9.7	13.2	15.5	17.6	17.6	15.6	11.8	9.8	7.7		
		MCDB	8.4	8.2	9.5	11.4	15.6	18.6	20.7	20.6	17.6	12.9	10.7	8.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	2.5	3.0	3.4	3.9	4.3	4.4	4.4	4.1	3.4	2.7	2.8	2.6		
		MCDBR	3.5	4.0	4.6	5.5	6.3	6.8	6.1	5.7	4.9	3.7	3.7	3.7		
	5% WB	MCWBR	2.5	2.7	2.9	3.2	3.3	3.4	3.2	2.9	2.6	2.5	2.8	2.4		
		MCWBR	2.8	3.1	4.2	4.2	5.0	5.2	5.1	4.4	4.2	3.0	3.1	3.1		
(40) Clear-Sky Solar Irradiance	taub		0.316	0.307	0.328	0.358	0.375	0.362	0.350	0.351	0.335	0.332	0.314	0.305		
		taud	2.492	2.557	2.512	2.436	2.411	2.464	2.540	2.538	2.579	2.559	2.545	2.500		
	Ebn at Noon		747	857	890	891	885	898	904	888	872	812	747	710		
		Edh at Noon	61	71	87	104	111	106	97	93	81	70	58	53		
(44) All-Sky Solar Radiation	RadAvg		0.85	1.73	2.58	4.02	5.23	5.63	6.23	5.29	3.71	2.03	1.01	0.68		
	RadStd		0.14	0.26	0.35	0.42	0.47	0.65	0.55	0.42	0.33	0.29	0.19	0.10		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (65 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page