

PITT MEADOWS, BC, Canada

WMO: 717750

Lat: 49.2083N

Lon: 122.6900W

Elev: 16

StdP: 14.69

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	19.2	23.6	6.4	7.6	30.5	13.3	10.8	28.3	16.6	45.7	14.1	43.9	2.5	100	0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.9	86.7	67.3	83.1	66.1	79.6	64.9	68.9	82.9	67.1	80.2	65.5	77.3	5.3	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.7	88.2	74.3	62.0	83.1	71.6	60.6	79.2	69.7	33.0	82.7	31.5	80.6	30.3	77.5	77.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.1	10.0	8.8	13.4	92.5	5.1	3.9	9.8	95.3	6.8	97.6	4.0	99.8	0.3	102.7
			12.8	71.8	5.2	2.8	9.1	73.9	6.1	75.5	3.2	77.1	-0.6	79.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	51.0	38.4	40.2	44.3	49.2	56.0	60.7	65.7	65.7	60.0	50.7	42.9	37.4	(6)
(7)		DBStd	11.32	6.54	5.38	4.87	4.70	5.35	4.85	4.78	4.30	4.52	4.59	6.07	6.30	(7)
(8)		HDD50	1556	359	274	186	68	10	0	0	0	0	46	222	391	(8)
(9)		HDD65	5275	824	693	643	473	283	147	46	44	160	443	664	855	(9)
(10)		CDD50	1922	1	1	8	45	195	321	487	486	301	68	8	1	(10)
(11)		CDD65	165	0	0	0	0	3	18	69	65	10	0	0	0	(11)
(12)		CDH74	2344	0	0	0	13	122	312	877	793	226	1	0	0	(12)
(13)		CDH80	682	0	0	0	1	18	92	292	231	48	0	0	0	(13)
(14)	Wind	WSAvg	3.2	3.1	3.4	4.0	3.7	3.3	3.2	3.1	2.8	2.6	2.8	3.4	3.2	(14)
(15)	Precipitation	PrecAvg	64.6	8.4	5.9	6.4	4.5	3.5	2.9	2.0	2.2	3.3	6.3	9.3	9.2	(15)
(16)		PrecMax	80.7	14.9	11.5	13.9	8.2	7.3	5.3	4.8	7.4	7.9	13.9	15.6	13.6	(16)
(17)		PrecMin	52.6	4.2	0.9	1.9	1.5	0.8	0.7	0.4	0.6	0.6	0.9	3.8	5.2	(17)
(18)		PrecStd	7.2	2.5	2.2	2.4	1.6	1.6	1.2	0.9	1.7	1.8	2.9	3.1	2.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.4	58.5	67.5	75.4	82.7	88.2	93.1	89.6	85.3	70.9	59.6	55.2	(19)
(20)			MCWB	51.2	49.2	53.7	58.2	62.5	66.8	71.3	67.7	66.5	58.7	55.1	53.1	(20)
(21)		2%	DB	51.6	54.1	60.8	68.9	77.4	82.3	87.3	85.9	80.3	65.7	55.8	50.5	(21)
(22)			MCWB	49.3	47.1	50.8	55.3	61.1	64.5	68.0	67.4	64.8	56.5	53.0	48.4	(22)
(23)		5%	DB	49.3	51.2	56.3	64.0	73.0	76.9	82.7	82.2	75.7	61.7	53.5	47.9	(23)
(24)			MCWB	47.2	46.3	48.2	52.0	59.5	62.6	66.5	66.4	62.9	55.2	50.9	45.7	(24)
(25)		10%	DB	46.9	48.5	52.9	59.7	68.2	72.4	78.6	78.5	71.1	58.8	51.3	45.5	(25)
(26)			MCWB	45.2	44.9	46.8	50.5	57.4	60.5	64.7	65.3	60.9	54.3	49.0	44.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.7	52.1	55.3	60.2	64.8	68.6	73.4	70.8	68.4	62.1	56.5	52.9	(27)
(28)			MCD B	53.5	55.4	63.2	71.2	79.0	84.6	89.8	85.3	81.2	67.9	58.0	54.3	(28)
(29)		2%	WB	49.9	49.1	52.0	56.6	62.3	65.8	69.6	68.4	65.9	58.8	53.6	48.8	(29)
(30)			MCD B	51.0	51.9	58.5	66.4	74.8	79.8	83.3	82.3	77.5	62.1	55.2	50.2	(30)
(31)		5%	WB	47.4	47.1	49.8	53.7	60.0	63.4	67.3	66.8	63.6	56.6	51.4	46.0	(31)
(32)			MCD B	48.8	49.7	54.6	61.3	70.8	75.2	80.2	79.7	73.0	59.9	52.7	47.2	(32)
(33)		10%	WB	45.3	45.2	47.8	51.4	57.9	61.2	65.3	65.3	61.6	54.8	49.3	44.1	(33)
(34)			MCD B	46.7	47.6	51.8	57.8	66.6	70.8	77.0	76.5	68.9	58.1	50.9	45.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.4	14.0	15.1	17.6	18.7	17.8	20.9	21.5	19.9	15.2	11.7	9.8	(35)
(36)			MCDBR	12.8	19.7	23.2	28.7	29.6	29.6	30.7	30.6	30.4	21.8	14.3	11.7	(36)
(37)			MCWBR	9.9	13.4	14.1	15.7	14.9	13.9	13.7	14.0	15.8	13.7	10.4	8.9	(37)
(38)		5% WB	MCD BR	11.0	15.5	20.0	23.7	26.0	26.7	28.6	27.6	26.8	17.8	10.7	10.2	(38)
(39)			MCWBR	9.1	11.3	12.8	13.8	13.8	13.1	13.5	13.3	14.8	12.0	8.9	8.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.319	0.315	0.330	0.372	0.405	0.373	0.372	0.376	0.359	0.343	0.325	0.310	(40)	
(41)		taud	2.386	2.452	2.436	2.337	2.282	2.397	2.419	2.430	2.475	2.504	2.462	2.399	(41)	
(42)		Ebn at Noon	231	266	280	278	272	281	279	273	267	252	229	218	(42)	
(43)		Edh at Noon	21	25	30	36	40	36	35	33	29	23	20	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	272	544	816	1270	1663	1784	1995	1692	1172	643	320	217	(44)	
(45)		RadStd	45	83	113	137	144	213	176	133	105	89	60	33	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (67 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page