

PITT MEADOWS, BC, Canada

WMO: 717750

Lat: 49.2083N

Lon: 122.6900W

Elev: 5

StdP: 101.26

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-7.1	-4.7	-14.2	1.1	-0.8	-10.4	1.5	-2.0	7.4	7.6	6.3	6.6	1.1	100	0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.6	30.4	19.6	28.4	19.0	26.5	18.3	20.5	28.3	19.5	26.8	18.6	25.2	2.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.6	12.6	23.5	16.7	11.9	22.0	15.9	11.3	21.0	58.9	28.2	55.4	27.0	52.5	25.3	25.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.4	4.5	3.9	DB	-10.3	33.6	2.8	2.2	-12.3	35.2	-14.0	36.5	-15.6	37.7	-17.6	39.3	(4)
(5)			WB	-10.6	22.1	2.9	1.6	-12.7	23.3	-14.4	24.2	-16.0	25.1	-18.1	26.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.6	3.6	4.6	6.8	9.6	13.3	15.9	18.7	18.7	15.6	10.4	6.0	3.0	(6)	
	DBStd	6.29	3.63	2.99	2.71	2.61	2.97	2.70	2.66	2.39	2.51	2.55	3.37	3.50	(7)	
	HDD10.0	864	199	152	103	38	6	0	0	0	0	26	123	217	(8)	
	HDD18.3	2931	458	385	357	263	157	82	26	24	89	246	369	475	(9)	
	CDD10.0	1068	1	1	4	25	108	178	271	270	167	38	4	1	(10)	
	CDD18.3	92	0	0	0	0	2	10	38	36	6	0	0	0	(11)	
	CDH23.3	1302	0	0	0	7	68	173	487	441	126	1	0	0	(12)	
	CDH26.7	379	0	0	0	1	10	51	162	128	27	0	0	0	(13)	
(14) Wind	WSAvg	1.4	1.4	1.5	1.8	1.7	1.5	1.5	1.4	1.2	1.1	1.3	1.5	1.4	(14)	
(15) Precipitation	PrecAvg	1642	213	150	163	115	88	74	51	57	83	160	236	234	(15)	
	PrecMax	2050	378	293	354	209	185	134	122	189	201	352	396	346	(16)	
	PrecMin	1335	107	22	47	37	20	17	11	15	15	22	96	132	(17)	
	PrecStd	182	64	57	62	41	41	30	24	43	45	73	80	56	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.4	14.7	19.7	24.1	28.2	31.2	33.9	32.0	29.6	21.6	15.3	12.9	(19)	
		MCWB	10.6	9.6	12.0	14.6	16.9	19.3	21.8	19.8	19.2	14.8	12.8	11.7	(20)	
	2%	DB	10.9	12.3	16.0	20.5	25.2	28.0	30.7	29.9	26.9	18.7	13.2	10.3	(21)	
		MCWB	9.6	8.4	10.5	12.9	16.2	18.1	20.0	19.7	18.2	13.6	11.7	9.1	(22)	
	5%	DB	9.6	10.7	13.5	17.8	22.8	24.9	28.1	27.9	24.3	16.5	11.9	8.8	(23)	
		MCWB	8.4	8.0	9.0	11.1	15.3	17.0	19.2	19.1	17.1	12.9	10.5	7.6	(24)	
	10%	DB	8.3	9.2	11.6	15.4	20.1	22.5	25.9	25.9	21.7	14.9	10.7	7.5	(25)	
		MCWB	7.3	7.2	8.2	10.3	14.1	15.8	18.2	18.5	16.1	12.4	9.4	6.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.5	11.2	13.0	15.7	18.2	20.3	23.0	21.6	20.2	16.7	13.6	11.6	(27)	
		MCDB	12.0	13.0	17.3	21.8	26.1	29.2	32.1	29.6	27.3	19.9	14.5	12.4	(28)	
	2%	WB	9.9	9.5	11.1	13.6	16.8	18.8	20.9	20.2	18.8	14.9	12.0	9.3	(29)	
		MCDB	10.6	11.1	14.7	19.1	23.8	26.5	28.5	28.0	25.3	16.7	12.9	10.1	(30)	
	5%	WB	8.6	8.4	9.9	12.0	15.6	17.5	19.6	19.4	17.6	13.7	10.8	7.8	(31)	
		MCDB	9.3	9.8	12.6	16.3	21.5	24.0	26.8	26.5	22.8	15.5	11.5	8.5	(32)	
	10%	WB	7.4	7.3	8.8	10.8	14.4	16.2	18.5	18.5	16.5	12.7	9.6	6.7	(33)	
		MCDB	8.1	8.7	11.0	14.3	19.2	21.6	25.0	24.7	20.5	14.5	10.5	7.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.8	7.8	8.4	9.8	10.4	9.9	11.6	11.9	11.0	8.4	6.5	5.4	(35)	
		MCDBR	7.1	11.0	12.9	15.9	16.4	16.4	17.1	17.0	16.9	12.1	8.0	6.5	(36)	
	5% WB	MCWBR	5.5	7.4	7.8	8.7	8.3	7.7	7.6	7.8	8.8	7.6	5.8	5.0	(37)	
		MCWBR	6.1	8.6	11.1	13.2	14.4	14.8	15.9	15.3	14.9	9.9	6.0	5.7	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.319	0.315	0.330	0.372	0.405	0.373	0.372	0.376	0.359	0.343	0.325	0.310	(40)	
		taud	2.386	2.452	2.436	2.337	2.282	2.397	2.419	2.430	2.475	2.504	2.462	2.399	(41)	
	Ebn at Noon	Ebn at Noon	729	838	884	875	856	886	881	862	843	794	722	688	(42)	
		Edh at Noon	67	78	94	115	127	114	110	104	90	74	62	58	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.86	1.72	2.57	4.00	5.24	5.62	6.29	5.33	3.69	2.03	1.01	0.68	(44)	
	RadStd	RadStd	0.14	0.26	0.35	0.43	0.46	0.67	0.56	0.42	0.33	0.28	0.19	0.10	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (67 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page