

SHERINGHAM POINT, BC, Canada

WMO: 717800

Lat: 48.3767N

Lon: 123.9211W

Elev: 7

StdP: 101.24

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-1.7	0.1	-10.5	1.5	1.1	-7.1	2.1	2.0	18.9	7.3	16.0	8.2	4.4	90	0.679

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.4	21.7	16.5	19.3	15.6	17.6	15.1	17.5	20.1	16.4	18.3	15.6	17.2	3.5	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.6	11.8	18.4	15.7	11.1	17.1	14.9	10.6	16.1	49.3	20.1	46.0	18.4	43.6	17.3	21.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.3	12.6	11.3	DB	-3.5	27.2	2.7	2.3	-5.4	28.9	-6.9	30.2	-8.4	31.5	-10.4	33.1	(4)
(5)			WB	-5.1	19.3	2.7	1.4	-7.0	20.3	-8.6	21.1	-10.1	21.9	-12.1	22.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.9	6.4	6.5	7.4	8.9	10.8	12.5	13.7	14.2	13.5	10.8	8.2	6.1	(6)
(7)		DBStd	3.64	2.75	2.40	2.13	1.93	1.98	1.96	1.95	1.85	1.82	1.87	2.50	2.63	(7)
(8)		HDD10.0	550	114	99	83	43	13	1	0	0	0	12	64	121	(8)
(9)		HDD18.3	3071	370	332	338	282	234	176	146	131	146	233	305	378	(9)
(10)		CDD10.0	526	2	1	3	11	37	76	114	129	106	38	8	1	(10)
(11)		CDD18.3	4	0	0	0	0	0	1	2	1	1	0	0	0	(11)
(12)		CDH23.3	32	0	0	0	0	0	8	12	9	2	0	0	0	(12)
(13)		CDH26.7	4	0	0	0	0	0	1	2	1	0	0	0	0	(13)
(14)	Wind	WSAvg	4.6	4.0	4.0	4.2	4.6	5.4	5.9	6.5	5.5	3.6	3.3	3.7	3.9	(14)
(15)	Precipitation	PrecAvg	1954	313	223	178	127	61	48	34	43	82	215	296	319	(15)
(16)		PrecMax	2388	485	400	282	228	116	102	113	154	177	469	551	478	(16)
(17)		PrecMin	1228	184	89	67	55	25	17	13	10	23	87	140	169	(17)
(18)		PrecStd	268	82	78	55	44	25	20	21	34	38	88	112	67	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.6	13.0	14.5	16.9	20.2	24.2	24.9	24.3	22.6	17.6	15.1	13.1	(19)
(20)			MCWB	10.6	8.9	10.3	12.0	12.9	16.9	18.5	17.7	16.9	14.3	13.3	11.6	(20)
(21)		2%	DB	11.7	11.3	12.4	14.1	16.7	19.2	20.7	20.6	19.8	15.6	13.1	11.1	(21)
(22)			MCWB	10.2	9.0	9.9	11.1	12.9	15.4	16.9	16.6	15.7	12.6	12.0	9.9	(22)
(23)		5%	DB	10.6	10.2	11.1	12.5	14.7	16.2	17.9	18.5	17.8	14.4	12.1	10.0	(23)
(24)			MCWB	9.3	8.6	9.3	10.3	12.4	14.0	15.8	15.9	15.1	12.2	11.2	8.9	(24)
(25)		10%	DB	9.7	9.4	10.2	11.4	13.3	14.8	16.2	17.0	16.4	13.3	11.2	9.2	(25)
(26)			MCWB	8.7	8.2	8.7	9.7	11.6	13.2	14.9	15.3	14.4	11.8	10.3	8.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.0	10.9	11.9	12.8	15.2	17.7	19.5	19.1	18.4	15.2	14.1	11.7	(27)
(28)			MCDWB	12.4	11.4	12.8	15.0	16.7	22.5	23.0	22.1	21.4	16.6	14.7	12.1	(28)
(29)		2%	WB	10.6	10.0	10.7	11.6	13.5	15.8	17.4	17.2	16.7	13.8	12.5	10.3	(29)
(30)			MCDWB	11.1	10.7	11.6	13.1	15.1	18.5	19.7	19.2	18.7	14.8	12.9	10.7	(30)
(31)		5%	WB	9.7	9.2	9.7	10.8	12.5	14.4	15.9	16.2	15.8	12.9	11.6	9.2	(31)
(32)			MCDWB	10.2	9.8	10.5	12.0	14.0	15.9	17.1	18.1	17.3	13.6	12.0	9.6	(32)
(33)		10%	WB	8.8	8.5	9.0	10.0	11.6	13.4	14.8	15.5	14.9	12.1	10.7	8.5	(33)
(34)			MCDWB	9.3	9.2	9.8	10.9	12.8	14.5	15.9	17.0	16.2	12.8	11.1	8.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.6	3.8	4.1	4.1	4.3	4.4	4.9	5.4	5.4	3.9	3.6	3.4	(35)
(36)			MCDBR	4.5	4.7	5.4	6.0	7.3	7.6	8.9	8.9	8.4	5.3	4.3	4.2	(36)
(37)			MCWBR	3.6	3.5	3.7	3.7	4.3	4.6	5.5	5.3	5.1	3.5	3.6	3.5	(37)
(38)		5% WB	MCDBR	4.2	4.2	4.6	5.5	6.2	7.0	7.8	7.8	7.4	4.7	4.1	3.9	(38)
(39)			MCWBR	3.5	3.4	3.6	3.8	4.2	4.6	5.3	5.3	5.2	3.6	3.8	3.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.319	0.316	0.334	0.363	0.382	0.362	0.351	0.355	0.342	0.334	0.327	0.314	(40)	
(41)		taud	2.510	2.547	2.507	2.414	2.379	2.455	2.526	2.516	2.546	2.554	2.495	2.487	(41)	
(42)		Ebn at Noon	757	851	887	888	880	899	905	887	868	816	735	711	(42)	
(43)		Edh at Noon	62	73	89	107	116	108	99	96	85	72	62	56	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.93	1.82	2.80	4.25	5.37	5.87	6.26	5.27	3.88	2.17	1.12	0.76	(44)	
(45)		RadStd	0.13	0.25	0.33	0.39	0.42	0.54	0.42	0.38	0.31	0.25	0.17	0.10	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (71 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page