

SISTERS ISLAND, BC, Canada

WMO: 717810

Lat: 49.4867N

Lon: 124.4350W

Elev: 20

StdP: 101.08

Time Zone: -8.00 (NAP)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-1.0	0.7	-8.9	1.8	1.1	-5.7	2.3	2.0	22.9	6.6	21.7	7.1	6.2	140	0.696

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.4	23.6	17.7	22.3	17.1	21.2	16.7	18.7	22.1	17.9	21.1	17.2	20.4	3.3	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.2	12.3	20.8	16.4	11.7	20.0	15.7	11.2	19.4	52.9	22.4	50.4	21.2	48.5	20.6	24.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.1	17.0	15.1	DB	-2.1	26.3	1.9	1.3	-3.5	27.3	-4.6	28.0	-5.7	28.8	-7.1	29.8	(4)
(5)			WB	-4.2	20.1	2.2	1.3	-5.8	21.0	-7.1	21.8	-8.3	22.5	-10.0	23.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.2	5.7	5.9	7.3	9.7	13.1	15.8	18.2	18.5	15.5	11.2	7.9	5.7	(6)	
	DBStd	5.13	2.43	2.09	1.95	1.99	2.51	2.28	2.08	1.84	1.95	1.78	2.39	2.37	(7)	
	HDD10.0	575	132	116	84	29	3	0	0	0	0	8	68	134	(8)	
	HDD18.3	2650	390	349	341	260	163	84	28	21	88	220	313	392	(9)	
	CDD10.0	1025	1	0	2	19	99	173	253	262	165	46	6	1	(10)	
	CDD18.3	58	0	0	0	0	1	7	23	25	3	0	0	0	(11)	
	CDH23.3	52	0	0	0	0	0	9	26	16	1	0	0	0	(12)	
	CDH26.7	2	0	0	0	0	0	0	2	0	0	0	0	0	(13)	
(14) Wind	WSAvg	6.4	7.3	6.6	6.9	6.2	5.6	5.8	5.5	5.2	5.3	6.7	7.6	7.9	(14)	
(15) Precipitation	PrecAvg	1085	171	102	98	61	45	42	22	34	41	116	167	171	(15)	
	PrecMax	1346	320	326	210	130	88	82	42	117	134	260	339	235	(16)	
	PrecMin	771	87	6	20	19	13	11	3	3	9	19	57	86	(17)	
	PrecStd	165	62	75	47	32	21	19	12	28	31	58	83	43	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.5	10.7	13.2	17.5	21.4	24.5	25.9	25.1	22.7	16.9	13.9	11.7	(19)	
		MCWB	9.2	8.4	9.5	11.5	13.8	16.3	19.1	17.5	17.0	13.5	11.3	9.3	(20)	
	2%	DB	10.2	9.7	11.4	15.0	19.4	22.0	23.7	23.4	20.7	15.3	12.4	10.1	(21)	
		MCWB	8.5	7.6	8.8	11.0	13.7	16.2	18.0	17.8	16.4	12.7	10.6	8.5	(22)	
	5%	DB	9.2	8.9	10.4	13.5	17.7	20.2	22.3	22.2	19.2	14.3	11.4	9.2	(23)	
		MCWB	8.0	7.1	8.2	10.1	13.3	15.5	17.3	17.4	15.6	12.0	10.0	7.7	(24)	
	10%	DB	8.6	8.3	9.7	12.3	16.3	18.8	21.1	21.2	18.1	13.4	10.6	8.4	(25)	
		MCWB	7.4	6.7	7.7	9.3	12.6	14.9	16.8	17.0	15.0	11.5	9.4	7.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.0	9.3	10.3	12.7	15.5	18.1	20.8	19.7	18.1	14.4	12.1	10.2	(27)	
		MCDB	10.8	10.2	12.0	16.0	19.2	21.9	24.3	23.0	21.4	16.0	13.3	11.3	(28)	
	2%	WB	8.9	8.2	9.4	11.6	14.6	16.9	18.9	18.7	17.0	13.4	11.1	8.8	(29)	
		MCDB	9.7	9.1	10.8	14.3	17.7	20.6	22.7	21.9	19.8	14.6	11.9	9.6	(30)	
	5%	WB	8.2	7.6	8.7	10.6	13.8	16.0	17.9	18.0	16.1	12.6	10.4	8.1	(31)	
		MCDB	9.0	8.6	10.1	12.9	16.6	19.4	21.3	21.1	18.5	13.7	11.2	9.0	(32)	
	10%	WB	7.5	7.0	8.0	9.7	13.1	15.2	17.2	17.4	15.4	11.9	9.7	7.3	(33)	
		MCDB	8.3	8.1	9.5	11.6	15.9	18.4	20.4	20.4	17.6	13.1	10.5	8.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	2.3	2.7	3.1	3.8	4.2	4.2	4.6	4.4	3.8	2.7	2.5	2.2	(35)	
		MCDBR	3.2	3.3	3.9	5.4	6.2	6.1	6.1	5.8	5.2	3.8	3.2	3.1	(36)	
	5% WB	MCWBR	2.3	2.2	2.4	3.0	3.3	3.5	3.5	3.2	2.8	2.4	2.5	2.5	(37)	
		MCWBR	3.0	2.9	3.7	5.0	5.3	5.5	5.5	5.2	4.7	3.4	3.0	2.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.319	0.311	0.332	0.347	0.369	0.364	0.356	0.357	0.338	0.337	0.318	0.313	(40)	
		taud	2.494	2.573	2.521	2.478	2.432	2.464	2.526	2.528	2.574	2.543	2.527	2.466	(41)	
	Ebn at Noon		739	851	884	902	890	895	898	882	868	803	735	689	(42)	
		Edh at Noon	61	70	86	100	109	106	99	94	81	71	58	55	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.83	1.73	2.56	3.99	5.19	5.60	6.16	5.28	3.70	1.99	0.99	0.65	(44)	
	RadStd		0.12	0.27	0.34	0.39	0.55	0.63	0.62	0.44	0.32	0.32	0.18	0.10	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	-2.03	N/A	N/A	-0.48	N/A	N/A	N/A	N/A
Regional (58 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page