

WHITE ROCK, BC, Canada

WMO: 717850

Lat: 49.0181N

Lon: 122.7839W

Elev: 13

StdP: 101.17

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-5.1	-2.9	-15.4	1.0	-1.7	-11.4	1.4	-0.7	8.2	9.2	7.0	9.3	2.2	70	0.454

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.9	25.0	18.6	23.4	17.9	22.1	17.3	19.6	23.6	18.7	22.4	17.9	21.3	1.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.0	12.9	21.8	17.1	12.2	20.6	16.3	11.6	19.9	55.9	23.8	52.8	22.5	50.4	21.3	24.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.1	4.8	3.9	-7.2	30.2	2.4	2.2	-9.0	31.8	-10.4	33.1	-11.8	34.4	-13.5	36.0		
(5)			-8.7	21.2	2.6	1.0	-10.6	21.9	-12.1	22.5	-13.6	23.0	-15.5	23.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.9	5.1	5.7	7.6	10.0	13.1	15.6	17.7	17.7	15.1	10.9	7.3	4.6
	DBStd	5.35	3.49	2.87	2.59	2.22	2.31	2.08	1.90	1.69	2.04	2.33	3.27	3.31
	HDD10.0	663	154	123	82	26	3	0	0	0	0	17	90	169
	HDD18.3	2751	411	355	333	249	163	87	34	32	98	231	331	426
	CDD10.0	990	2	1	7	27	99	167	239	240	154	45	9	1
	CDD18.3	34	0	0	0	0	1	4	15	13	2	0	0	0
	CDH23.3	160	0	0	0	1	5	24	68	51	11	0	0	0
	CDH26.7	28	0	0	0	0	1	3	13	9	2	0	0	0
Wind	WSAvg	1.5	1.7	1.7	1.8	1.6	1.4	1.4	1.4	1.3	1.2	1.4	1.7	1.8
Precipitation	PrecAvg	1049	142	102	90	74	62	50	34	40	51	101	150	151
	PrecMax	1338	261	238	177	145	138	138	85	133	135	288	270	266
	PrecMin	754	28	4	24	18	12	12	0	0	4	12	53	32
	PrecStd	156	56	52	34	28	29	30	23	36	31	54	55	50
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.0	13.7	16.9	20.8	23.6	26.5	28.4	27.5	24.8	19.3	15.7	13.2
		MCWB	10.9	9.1	10.8	14.3	15.9	18.5	20.0	18.7	17.5	13.9	12.7	11.4
	2%	DB	11.5	11.9	14.2	17.3	20.9	23.2	25.0	24.4	22.2	17.2	13.7	11.0
		MCWB	9.9	8.7	10.1	12.1	15.2	17.6	19.1	18.7	17.0	13.8	12.1	9.4
	5%	DB	10.5	10.6	12.6	15.5	19.0	21.2	23.2	22.9	20.5	15.7	12.6	9.8
		MCWB	9.1	8.4	9.5	11.5	14.6	16.4	18.3	18.1	16.5	12.9	11.4	8.3
	10%	DB	9.5	9.5	11.4	14.0	17.5	19.7	21.9	21.7	19.1	14.5	11.5	8.8
		MCWB	8.3	7.7	8.9	10.6	13.8	15.5	17.5	17.5	15.7	12.3	10.3	7.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.8	11.0	12.3	14.8	17.3	19.6	21.4	20.5	19.0	16.0	13.7	11.9
		MCDB	12.4	12.1	14.7	19.3	21.3	24.3	25.4	24.4	22.7	17.6	14.7	13.0
	2%	WB	10.4	9.7	11.1	13.1	15.9	18.0	19.9	19.4	17.8	14.4	12.5	9.9
		MCDB	11.1	10.9	13.3	15.9	19.4	21.9	24.0	23.2	20.9	16.0	13.4	10.8
	5%	WB	9.3	8.7	10.1	12.0	15.0	16.8	18.7	18.6	16.9	13.5	11.6	8.7
		MCDB	10.1	10.0	12.0	14.7	18.4	20.4	22.5	22.2	19.7	15.0	12.5	9.5
	10%	WB	8.4	8.0	9.2	11.1	14.1	15.9	17.8	17.9	16.1	12.6	10.5	7.7
		MCDB	9.3	9.3	11.0	13.5	17.1	19.3	21.3	21.1	18.5	14.1	11.3	8.6
Mean Daily Temperature Range	5% DB	MDBR	4.9	6.1	6.5	7.2	7.5	7.3	7.9	7.9	7.7	6.4	5.4	4.8
		MCDBR	5.4	7.5	8.4	10.3	10.6	10.0	10.3	10.2	10.4	8.0	5.8	5.2
		MCWBR	3.9	5.0	5.2	6.2	6.0	5.5	5.5	5.5	5.9	5.0	4.2	3.9
	5% WB	MCDBR	4.6	6.0	7.4	9.2	9.5	9.4	10.0	9.6	9.3	6.8	5.1	4.8
		MCWBR	3.7	4.3	5.0	5.9	5.7	5.4	5.7	5.6	5.7	4.7	4.0	3.9
Clear-Sky Solar Irradiance	taub	0.322	0.317	0.331	0.364	0.393	0.365	0.362	0.368	0.350	0.337	0.323	0.312	
	taud	2.472	2.529	2.505	2.397	2.329	2.427	2.455	2.455	2.499	2.526	2.498	2.464	
	Ebn at Noon	740	844	887	884	868	895	892	871	854	805	732	698	
	Edh at Noon	63	74	88	109	121	111	106	101	88	73	61	56	
All-Sky Solar Radiation	RadAvg	0.88	1.74	2.64	4.08	5.31	5.73	6.36	5.39	3.76	2.06	1.03	0.70	
	RadStd	0.14	0.26	0.35	0.42	0.45	0.64	0.53	0.40	0.33	0.27	0.18	0.10	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (71 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page