

YOHO PARK, BC, Canada

WMO: 717860

Lat: 51.447N

Lon: 116.324W

Elev: 5256

StdP: 12.11

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-21.7	-15.3	-27.1	1.5	-21.5	-20.4	2.2	-15.4	28.9	13.2	26.8	12.9	5.6	70	0.813

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.5	78.2	56.2	74.5	55.0	70.8	53.6	58.3	72.8	56.5	70.4	54.8	67.6	11.9	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
53.3	73.5	60.1	51.4	68.6	58.6	49.7	64.2	56.9	27.6	72.5	26.2	70.6	25.1	67.9	66.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.7	21.2	19.4	DB	-30.1	83.9	6.3	2.8	-34.6	86.0	-38.3	87.6	-41.8	89.2	-46.3	91.2	(4)
(5)			WB	-30.3	62.3	6.2	2.7	-34.8	64.3	-38.4	65.9	-41.9	67.4	-46.4	69.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	33.4	13.4	16.1	24.5	33.6	42.3	49.1	55.2	54.1	45.9	33.3	20.8	10.8		
	DBStd	17.57	12.33	10.62	9.46	6.43	6.15	5.31	5.76	5.58	6.44	7.21	9.99	12.22		
	HDD50	6503	1134	950	790	493	248	78	20	26	156	517	877	1214		
	HDD65	11554	1599	1370	1255	943	703	477	307	339	573	982	1327	1679		
	CDD50	425	0	0	0	0	9	51	180	152	33	0	0	0		
	CDD65	2	0	0	0	0	0	0	2	0	0	0	0	0		
	CDH74	349	0	0	0	0	1	31	182	123	12	0	0	0		
	CDH80	38	0	0	0	0	0	3	24	11	0	0	0	0		
	Wind	WSAvg	9.0	11.3	10.2	9.4	8.3	7.5	7.7	7.2	8.0	9.7	11.0	10.6		
	Precipitation	PrecAvg	23.7	2.0	1.3	1.3	1.3	2.1	2.8	2.2	1.9	1.8	2.5	2.1		
		PrecMax	31.0	3.3	2.6	2.4	3.3	3.9	5.9	4.3	4.0	3.8	5.1	3.3		
		PrecMin	18.6	0.7	0.3	0.2	0.7	1.0	1.4	0.8	0.7	0.7	0.8	0.9		
		PrecStd	3.1	0.7	0.6	0.6	0.5	0.7	1.1	0.9	0.9	0.7	1.2	0.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.9	35.7	49.7	59.8	72.5	78.2	83.0	81.4	75.6	58.6	39.0	32.7		
		MCWB	32.4	32.3	37.7	44.0	50.6	54.2	57.8	57.4	54.0	46.4	36.6	32.4		
	2%	DB	30.6	33.1	42.8	53.1	67.2	72.1	79.2	77.5	70.0	51.2	35.7	30.5		
		MCWB	30.3	31.1	34.4	40.1	48.7	52.4	57.2	55.9	53.7	44.0	34.8	30.2		
	5%	DB	29.0	31.2	38.6	48.1	61.5	67.2	75.1	73.8	65.3	46.8	33.6	28.1		
		MCWB	28.6	29.6	32.6	37.8	46.5	50.8	55.8	55.2	51.6	41.6	33.0	27.9		
	10%	DB	27.0	28.8	35.6	43.8	56.4	62.4	70.8	69.8	59.5	43.3	32.0	25.3		
		MCWB	26.6	27.4	31.8	35.6	44.6	49.3	54.5	53.8	49.5	39.7	31.5	24.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	32.6	33.7	38.1	45.3	52.6	56.8	61.5	60.3	56.4	48.3	37.4	32.6		
		MCDB	32.8	34.4	47.1	58.3	67.0	71.3	76.6	75.8	69.9	55.1	38.3	32.6		
	2%	WB	30.4	32.0	35.5	41.4	49.9	54.3	59.1	57.9	54.3	45.2	34.8	30.3		
		MCDB	30.6	32.8	40.0	51.0	62.6	67.4	73.3	72.9	67.3	49.8	35.3	30.5		
	5%	WB	28.7	29.8	33.8	38.7	47.8	52.3	57.2	56.0	52.2	42.6	32.9	27.9		
		MCDB	28.9	30.9	36.8	45.8	59.5	63.9	71.2	70.3	63.4	45.9	33.4	28.2		
	10%	WB	26.6	27.5	32.4	36.5	45.5	50.4	55.5	54.4	49.9	39.8	31.3	24.9		
		MCDB	27.0	28.8	35.0	42.4	55.5	60.1	68.0	67.4	58.8	42.9	31.6	25.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.1	15.6	18.4	20.1	22.7	22.2	25.5	26.3	21.1	13.3	9.7	10.5		
		MCDBR	8.4	15.2	22.1	27.4	34.0	33.3	35.8	36.1	34.3	20.6	7.8	7.3		
		MCWBR	7.9	12.2	14.8	15.8	17.4	16.0	16.4	17.3	18.7	13.5	7.0	7.2		
	5% WB	MCDBR	8.3	13.0	17.8	23.9	30.9	28.3	30.6	32.6	31.0	18.6	7.0	7.3		
		MCWBR	8.0	10.6	12.3	14.3	16.4	14.2	14.9	16.3	17.5	12.8	6.3	7.2		
(40) Clear-Sky Solar Irradiance	taub		0.231	0.242	0.270	0.313	0.329	0.350	0.335	0.344	0.312	0.281	0.238	0.224		
	taud		2.315	2.306	2.234	2.132	2.254	2.348	2.425	2.403	2.478	2.517	2.391	2.290		
	Ebn at Noon		259	288	297	293	292	286	290	281	280	270	255	241		
	Edh at Noon		19	26	35	43	41	37	34	33	27	21	18	17		
(44) All-Sky Solar Radiation	RadAvg		285	568	884	1371	1656	1621	1822	1571	1055	614	293	231		
	RadStd		32	62	99	127	149	150	149	106	126	75	40	26		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (24 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page