

YOHO PARK, BC, Canada

WMO: 717860

Lat: 51.447N

Lon: 116.324W

Elev: 1602

StdP: 83.50

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-29.8	-26.3	-32.8	0.2	-29.7	-29.1	0.3	-26.3	12.9	-10.4	12.0	-10.6	2.5	70	0.813

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.2	25.6	13.5	23.6	12.8	21.5	12.0	14.6	22.7	13.6	21.3	12.7	19.8	5.3	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.8	10.5	15.6	10.8	9.8	14.8	9.8	9.2	13.9	46.2	22.5	43.2	21.4	40.5	20.0	19.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.6	9.5	8.7	DB	-34.5	28.9	3.5	1.6	-37.0	30.0	-39.0	30.9	-41.0	31.8	-43.5	32.9	(4)
(5)			WB	-34.6	16.9	3.5	1.5	-37.1	17.9	-39.1	18.8	-41.1	19.7	-43.6	20.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	0.8	-10.3	-8.8	-4.2	0.9	5.7	9.5	12.9	12.3	7.7	0.7	-6.2	-11.8	(6)	
	DBStd	9.76	6.85	5.90	5.25	3.57	3.42	2.95	3.20	3.10	3.58	4.01	5.55	6.79	(7)	
	HDD10.0	3613	630	528	439	274	138	43	11	14	87	287	487	674	(8)	
	HDD18.3	6419	888	761	697	524	391	265	171	188	318	546	737	933	(9)	
	CDD10.0	236	0	0	0	0	5	28	100	84	18	0	0	0	(10)	
	CDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0	(11)	
	CDH23.3	194	0	0	0	0	1	17	101	68	7	0	0	0	(12)	
	CDH26.7	21	0	0	0	0	0	2	13	6	0	0	0	0	(13)	
(14) Wind	WSAvg	4.0	5.1	4.6	4.2	3.7	3.4	3.4	3.4	3.2	3.6	4.4	4.9	4.7	(14)	
(15) Precipitation	PrecAvg	602	52	34	34	33	53	72	57	55	48	45	63	53	(15)	
	PrecMax	787	84	65	62	83	100	149	108	101	97	87	130	83	(16)	
	PrecMin	473	19	8	6	17	25	36	20	20	18	17	21	24	(17)	
	PrecStd	79	18	14	14	13	18	27	23	22	24	19	30	15	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.5	2.1	9.8	15.5	22.5	25.7	28.4	27.5	24.2	14.8	3.9	0.4	(19)	
		MCWB	0.2	0.1	3.2	6.7	10.3	12.3	14.4	14.1	12.2	8.0	2.6	0.2	(20)	
	2%	DB	-0.8	0.6	6.0	11.7	19.6	22.3	26.2	25.3	21.1	10.7	2.1	-0.8	(21)	
		MCWB	-1.0	-0.5	1.3	4.5	9.3	11.3	14.0	13.3	12.0	6.7	1.5	-1.0	(22)	
	5%	DB	-1.7	-0.4	3.6	8.9	16.4	19.5	23.9	23.2	18.5	8.2	0.9	-2.1	(23)	
		MCWB	-1.9	-1.3	0.3	3.2	8.1	10.5	13.2	12.9	10.9	5.3	0.6	-2.3	(24)	
	10%	DB	-2.8	-1.8	2.0	6.5	13.5	16.9	21.6	21.0	15.3	6.3	0.0	-3.7	(25)	
		MCWB	-3.0	-2.5	-0.1	2.0	7.0	9.6	12.5	12.1	9.7	4.3	-0.3	-4.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.3	1.0	3.4	7.4	11.4	13.8	16.4	15.7	13.5	9.0	3.0	0.3	(27)	
		MCDB	0.4	1.3	8.4	14.6	19.5	21.9	24.8	24.4	21.1	12.9	3.5	0.3	(28)	
	2%	WB	-0.9	0.0	1.9	5.2	10.0	12.4	15.1	14.4	12.4	7.3	1.5	-0.9	(29)	
		MCDB	-0.8	0.4	4.5	10.5	17.0	19.7	23.0	22.7	19.6	9.9	1.8	-0.8	(30)	
	5%	WB	-1.8	-1.2	1.0	3.7	8.8	11.3	14.0	13.3	11.2	5.9	0.5	-2.3	(31)	
		MCDB	-1.7	-0.6	2.7	7.6	15.3	17.7	21.8	21.3	17.5	7.7	0.8	-2.1	(32)	
	10%	WB	-3.0	-2.5	0.2	2.5	7.5	10.2	13.0	12.4	10.0	4.3	-0.4	-3.9	(33)	
		MCDB	-2.8	-1.8	1.7	5.8	13.1	15.6	20.0	19.7	14.9	6.0	-0.2	-3.8	(34)	
(35) Mean Daily Temperature Range	MDBR		6.2	8.7	10.2	11.1	12.6	12.3	14.2	14.6	11.7	7.4	5.4	5.8	(35)	
	5% DB	MCDBR	4.7	8.4	12.3	15.2	18.9	18.5	19.9	20.0	19.1	11.4	4.3	4.1	(36)	
		MCWBR	4.4	6.8	8.2	8.8	9.6	8.9	9.1	9.6	10.4	7.5	3.9	4.0	(37)	
	5% WB	MCDBR	4.6	7.2	9.9	13.3	17.2	15.7	17.0	18.1	17.2	10.3	3.9	4.0	(38)	
		MCWBR	4.4	5.9	6.9	7.9	9.1	7.9	8.3	9.0	9.7	7.1	3.5	4.0	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.231	0.242	0.270	0.313	0.329	0.350	0.335	0.344	0.312	0.281	0.238	0.224	(40)	
	taud		2.315	2.306	2.234	2.132	2.254	2.348	2.425	2.403	2.478	2.517	2.391	2.290	(41)	
	Ebn at Noon		818	907	935	923	922	903	913	885	882	852	805	761	(42)	
	Edh at Noon		61	82	109	137	128	118	107	104	86	67	56	53	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.90	1.79	2.79	4.32	5.22	5.11	5.74	4.95	3.33	1.94	0.93	0.73	(44)	
	RadStd		0.10	0.20	0.31	0.40	0.47	0.47	0.47	0.33	0.40	0.23	0.13	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (24 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page