

CAPE RACE, NL, Canada

WMO: 718000

Lat: 46.6602N

Lon: 53.0755W

Elev: 87

StdP: 14.65

Time Zone: -3.50 (NAF)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	9.2	13.1	2.7	6.3	11.0	6.5	7.7	14.4	57.8	27.5	53.6	28.0	18.0	320	1.011

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.4	67.8	62.6	65.0	61.7	63.0	60.6	64.2	66.1	62.5	64.0	61.0	62.3	19.5	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.4	87.8	65.1	61.8	82.9	63.3	60.4	78.5	61.8	29.5	66.3	28.2	64.1	27.2	62.3	72.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 47.0	41.6	36.4	DB	3.1	75.6	4.4	3.6	0.0	78.2	-2.6	80.3	-5.1	82.3	-8.3	84.9	(4)
(5)			WB	3.1	67.4	4.7	3.5	-0.3	69.9	-3.1	72.0	-5.8	74.0	-9.2	76.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	41.0	27.7	26.5	29.0	34.4	39.9	46.7	54.9	58.7	54.2	46.9	39.7	32.3	(6)	
	DBStd	12.00	6.31	6.58	5.76	3.77	3.82	4.35	4.40	3.63	4.87	5.42	5.77	6.58	(7)	
	HDD50	3910	692	659	652	467	314	117	8	0	18	125	311	547	(8)	
	HDD65	8763	1157	1079	1117	917	778	550	313	197	324	560	759	1012	(9)	
	CDD50	624	0	0	0	0	0	18	160	270	144	30	2	0	(10)	
	CDD65	3	0	0	0	0	0	0	0	2	1	0	0	0	(11)	
	CDH74	9	0	0	0	0	0	0	3	2	4	0	0	0	(12)	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
	WSAvg	18.9	22.5	22.2	21.2	19.2	17.8	16.4	15.7	15.8	17.1	18.7	19.4	21.0	(14)	
	PrecAvg	55.7	4.8	4.1	4.3	4.4	4.2	4.0	4.4	4.1	4.7	5.7	5.5	5.6	(15)	
(16) Precipitation	PrecMax	62.4	8.1	6.3	7.2	10.0	7.0	7.3	7.8	6.4	10.1	8.9	8.0	8.7	(16)	
	PrecMin	48.7	2.3	2.0	1.6	1.9	1.7	1.6	1.4	1.7	2.0	3.6	2.5	2.9	(17)	
	PrecStd	3.8	1.5	1.0	1.3	1.8	1.2	1.5	1.7	1.1	1.8	1.6	1.8	1.4	(18)	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.4	41.5	42.4	48.5	57.2	63.9	72.0	72.2	70.2	61.3	54.7	47.9	(19)	
		MCWB	42.9	41.1	39.4	42.2	49.4	57.2	64.7	65.6	64.0	57.9	54.0	47.5	(20)	
	2%	DB	40.5	38.6	39.1	43.7	51.0	58.3	66.5	68.4	64.8	58.4	52.1	45.4	(21)	
		MCWB	40.0	37.9	37.3	41.1	46.4	54.1	62.0	63.4	61.1	56.5	51.4	44.8	(22)	
	5%	DB	38.1	36.5	37.4	41.5	48.0	55.3	63.5	65.8	62.6	56.6	50.1	43.3	(23)	
		MCWB	37.6	35.8	36.2	39.6	45.2	52.2	60.6	62.6	59.9	54.9	49.4	42.6	(24)	
	10%	DB	36.2	34.7	35.9	39.7	45.6	52.8	61.0	63.7	60.9	54.7	48.3	41.2	(25)	
		MCWB	35.5	34.0	34.6	38.1	43.5	50.6	58.9	61.6	58.7	53.0	47.5	40.3	(26)	
	0.4%	WB	43.0	41.3	40.6	44.8	50.5	59.1	66.9	67.4	65.5	59.4	53.7	47.9	(27)	
		MCDB	43.1	41.6	41.6	46.1	53.8	62.0	69.8	69.9	68.3	60.0	54.0	47.9	(28)	
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	39.9	38.2	38.1	42.2	47.8	55.4	63.3	64.6	62.5	57.4	51.2	44.9	(29)	
		MCDB	40.2	38.5	38.9	43.2	49.8	57.5	64.9	66.6	63.9	58.1	51.5	45.2	(30)	
	5%	WB	37.4	35.9	36.5	40.2	45.8	53.0	61.0	63.1	60.7	55.3	49.5	42.4	(31)	
		MCDB	37.8	36.3	37.3	41.4	47.7	54.7	62.5	64.8	61.9	56.2	49.9	42.9	(32)	
	10%	WB	35.4	34.0	35.0	38.5	44.0	51.0	59.0	61.8	59.2	53.4	47.6	39.8	(33)	
		MCDB	35.8	34.4	35.8	39.6	45.6	52.6	60.4	63.2	60.3	54.5	48.1	40.4	(34)	
	5% DB	MDBR	10.6	10.0	9.6	8.9	9.8	10.2	9.9	9.4	10.5	9.9	9.6	9.7	(35)	
		MCDBR	11.6	10.3	10.1	12.0	15.1	15.0	14.7	13.1	12.5	10.7	9.6	10.2	(36)	
		MCWBR	12.5	9.9	9.1	9.5	10.9	11.0	10.9	9.7	9.8	9.0	10.0	11.9	(37)	
		MCWBR	11.7	9.5	9.6	11.4	13.6	13.6	12.8	11.5	11.1	9.7	9.5	10.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.327	0.329	0.344	0.373	0.380	0.410	0.446	0.406	0.375	0.360	0.338	0.322	(40)	
		taud	2.332	2.394	2.405	2.357	2.392	2.335	2.272	2.404	2.455	2.437	2.409	2.359	(41)	
	Ebn at Noon		238	266	279	280	281	272	260	267	266	251	233	226	(42)	
		Edh at Noon	24	28	32	36	36	39	41	35	30	26	23	21	(43)	
(44) All-Sky Solar Radiation	RadAvg		305	566	941	1294	1558	1589	1529	1366	1144	714	400	263	(44)	
	RadStd		20	36	57	119	116	139	110	99	70	55	55	19	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.74	N/A	N/A	+2.36	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page