

ARGENTIA, NL, Canada

WMO: 718070

Lat: 47.294N

Lon: 53.993W

Elev: 62

StdP: 14.66

Time Zone: -3.50 (NAF)

Period: 94-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	11.8	14.9	1.7	6.0	13.3	5.0	7.1	16.0	47.2	32.9	43.2	33.8	15.7	290	0.844

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.8	68.9	65.2	66.9	63.7	65.3	62.5	66.2	68.0	64.5	66.1	63.0	64.7	14.9	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.4	94.0	67.5	63.7	88.4	65.7	62.2	83.9	64.2	31.0	68.2	29.6	66.3	28.6	64.8	73.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
39.3	34.9	30.2	7.4	74.2	4.1	2.4	4.4	75.9	2.1	77.3	-0.2	78.7	-3.2	80.4
			5.3	69.9	3.5	1.8	2.8	71.1	0.7	72.1	-1.2	73.1	-3.8	74.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.1	28.7	27.7	30.6	37.0	43.2	50.0	57.9	61.4	56.4	48.5	41.4	33.7
	DBStd	12.55	6.59	7.14	6.30	4.87	4.27	4.19	3.75	3.36	4.66	5.43	6.16	6.87
	HDD50	3419	661	625	602	391	216	52	1	0	5	94	265	507
	HDD65	7992	1126	1045	1067	840	676	451	221	117	261	510	707	971
	CDD50	908	0	0	0	1	5	50	246	353	196	48	8	1
	CDD65	9	0	0	0	0	0	0	1	6	2	0	0	0
	CDH74	4	0	0	0	0	0	0	2	2	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	15.0	18.8	18.0	16.4	14.6	12.6	12.0	12.1	12.1	13.6	15.5	16.7	18.1
Precipitation	PrecAvg	50.8	4.9	4.2	3.9	3.9	3.5	3.7	3.9	3.6	4.1	5.0	5.2	4.8
	PrecMax	60.9	9.2	5.7	8.1	8.6	5.9	7.8	8.7	6.8	9.0	8.5	8.3	8.0
	PrecMin	43.7	1.5	2.0	1.7	1.3	1.5	1.9	1.9	1.9	1.3	2.4	2.0	2.6
	PrecStd	4.1	1.7	1.0	1.6	1.8	1.1	1.5	1.7	1.2	1.7	1.7	1.8	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.2	51.5	51.1	55.7	61.2	65.8	71.2	72.6	70.7	66.3	60.3	55.3
		MCWB	50.8	48.7	48.7	51.4	56.1	60.2	66.4	68.2	66.3	63.9	58.3	53.8
	2%	DB	44.3	46.4	45.7	51.4	56.3	61.6	67.1	69.3	67.6	62.1	57.2	50.6
		MCWB	43.2	44.9	43.1	48.8	51.8	56.9	63.8	65.8	64.1	60.0	55.7	49.3
	5%	DB	39.8	40.7	40.9	47.2	52.7	58.5	64.9	67.4	65.0	58.9	53.9	46.4
		MCWB	38.8	39.4	38.8	44.7	49.1	54.7	62.1	64.3	62.0	56.7	52.4	45.4
	10%	DB	36.7	36.2	37.6	43.7	49.6	56.2	63.1	66.0	62.9	56.2	50.5	42.6
		MCWB	35.5	34.9	35.6	41.2	46.6	53.2	60.8	63.1	60.2	53.9	49.0	41.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.2	48.9	49.2	52.9	57.5	61.3	67.6	69.2	68.1	64.5	58.9	53.9
		MCDB	53.0	50.7	50.8	54.3	60.4	63.4	69.8	71.3	69.8	66.0	60.1	54.9
	2%	WB	43.5	44.8	43.3	48.7	53.2	58.0	64.6	66.7	64.8	60.5	55.7	49.4
		MCDB	44.3	46.4	45.5	50.8	55.1	60.3	66.2	68.4	66.9	61.8	57.0	50.5
	5%	WB	39.1	39.3	39.1	44.9	49.7	55.5	62.7	65.0	62.8	57.1	52.6	45.5
		MCDB	39.9	40.3	40.6	46.7	52.1	57.3	64.1	66.7	64.7	58.4	53.8	46.4
	10%	WB	35.7	35.0	35.8	41.5	47.0	53.5	61.2	63.7	61.0	54.4	49.2	41.7
		MCDB	36.5	35.9	37.2	43.2	49.3	55.3	62.5	65.4	62.6	56.0	50.4	42.7
Mean Daily Temperature Range	5% DB	MDBR	9.7	9.5	9.3	9.6	10.3	9.9	8.4	7.8	8.7	8.0	8.6	8.8
		MCDBR	15.5	15.9	14.2	15.4	15.1	13.7	10.9	9.1	10.6	11.4	13.2	13.8
		MCWBR	16.5	16.0	13.6	13.4	11.5	10.1	8.6	7.0	8.5	11.0	13.1	14.3
	5% WB	MCDBR	16.0	15.4	14.3	15.0	14.1	12.5	10.0	8.5	9.9	11.2	13.2	14.0
		MCWBR	16.6	15.7	14.3	13.8	11.8	10.2	8.6	7.3	8.8	11.2	13.3	14.5
Clear-Sky Solar Irradiance	taub		0.319	0.323	0.337	0.371	0.382	0.408	0.441	0.407	0.375	0.349	0.325	0.317
	taud		2.349	2.404	2.417	2.348	2.369	2.330	2.276	2.388	2.448	2.480	2.471	2.360
	Ebn at Noon		239	267	281	280	280	272	260	266	265	254	238	224
	Edh at Noon		23	27	31	36	37	39	41	35	30	25	21	21
All-Sky Solar Radiation	RadAvg		314	546	911	1292	1562	1619	1578	1372	1108	684	383	262
	RadStd		23	49	62	121	120	146	115	87	69	55	49	23

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page