

ARGENTIA, NL, Canada

WMO: 718070

Lat: 47.294N

Lon: 53.993W

Elev: 19

StdP: 101.10

Time Zone: -3.50 (NAF)

Period: 94-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-11.2	-9.5	-16.8	0.9	-10.4	-15.0	1.0	-8.9	21.1	0.5	19.3	1.0	7.0	290	0.844

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.3	20.5	18.4	19.4	17.6	18.5	16.9	19.0	20.0	18.0	19.0	17.2	18.2	6.6	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.6	13.4	19.7	17.6	12.6	18.7	16.8	12.0	17.9	54.1	20.1	51.1	19.0	48.6	18.2	22.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.6	15.6	13.5	DB	-13.7	23.5	2.3	1.3	-15.3	24.4	-16.6	25.2	-17.9	25.9	-19.5	26.9	(4)
(5)			WB	-14.8	21.0	2.0	1.0	-16.2	21.7	-17.4	22.3	-18.5	22.9	-19.9	23.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.2	-1.9	-2.4	-0.8	2.8	6.2	10.0	14.4	16.3	13.5	9.2	5.2	0.9	
	DBStd	6.97	3.66	3.97	3.50	2.71	2.37	2.33	2.08	1.87	2.59	3.02	3.42	3.82	
	HDD10.0	1899	367	347	334	217	120	29	1	0	3	52	147	282	
	HDD18.3	4440	626	581	593	467	376	251	123	65	145	283	393	539	
	CDD10.0	504	0	0	0	1	3	28	137	196	109	27	4	1	
	CDD18.3	5	0	0	0	0	0	0	1	3	1	0	0	0	
	CDH23.3	2	0	0	0	0	0	0	1	1	0	0	0	0	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	6.7	8.4	8.0	7.3	6.5	5.6	5.4	5.4	5.4	6.1	6.9	7.5	8.1	
Precipitation	PrecAvg	1291	124	106	98	99	89	94	99	91	105	127	133	123	
	PrecMax	1548	233	144	207	219	149	198	220	173	228	217	211	202	
	PrecMin	1109	39	50	44	34	39	48	47	48	32	62	52	67	
	PrecStd	104	43	25	40	45	29	39	42	30	43	42	46	33	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.8	10.8	10.6	13.2	16.2	18.8	21.8	22.6	21.5	19.0	15.7	12.9	
		MCWB	10.4	9.3	9.3	10.8	13.4	15.7	19.1	20.1	19.1	17.7	14.6	12.1	
	2%	DB	6.8	8.0	7.6	10.8	13.5	16.4	19.5	20.7	19.8	16.7	14.0	10.3	
		MCWB	6.2	7.2	6.2	9.3	11.0	13.8	17.7	18.8	17.9	15.5	13.2	9.6	
	5%	DB	4.3	4.8	5.0	8.4	11.5	14.7	18.3	19.7	18.3	15.0	12.2	8.0	
		MCWB	3.8	4.1	3.8	7.1	9.5	12.6	16.7	17.9	16.7	13.7	11.3	7.4	
	10%	DB	2.6	2.3	3.1	6.5	9.8	13.4	17.3	18.9	17.2	13.4	10.3	5.9	
		MCWB	1.9	1.6	2.0	5.1	8.1	11.8	16.0	17.3	15.7	12.2	9.5	5.2	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.6	9.4	9.6	11.6	14.2	16.3	19.8	20.7	20.0	18.0	15.0	12.2
			MCDB	11.7	10.4	10.4	12.4	15.8	17.4	21.0	21.9	21.0	18.9	15.6	12.7
2%		WB	6.4	7.1	6.3	9.3	11.8	14.4	18.1	19.3	18.2	15.8	13.2	9.6	
		MCDB	6.8	8.0	7.5	10.5	12.9	15.7	19.0	20.2	19.4	16.6	13.9	10.3	
5%		WB	4.0	4.0	3.9	7.1	9.8	13.1	17.1	18.4	17.1	14.0	11.4	7.5	
		MCDB	4.4	4.6	4.8	8.2	11.2	14.0	17.8	19.3	18.1	14.7	12.1	8.0	
10%		WB	2.0	1.6	2.1	5.3	8.3	12.0	16.2	17.6	16.1	12.4	9.5	5.4	
		MCDB	2.5	2.2	2.9	6.2	9.6	12.9	17.0	18.5	17.0	13.3	10.2	6.0	
Mean Daily Temperature Range		5% DB	MDBR	5.4	5.3	5.2	5.3	5.7	5.5	4.6	4.3	4.9	4.5	4.8	4.9
			MCDBR	8.6	8.8	7.9	8.5	8.4	7.6	6.0	5.0	5.9	6.3	7.3	7.6
	MCWBR		9.2	8.9	7.5	7.4	6.4	5.6	4.8	3.9	4.7	6.1	7.3	8.0	
	5% WB	MCDBR	8.9	8.6	7.9	8.3	7.8	6.9	5.5	4.7	5.5	6.2	7.3	7.8	
		MCWBR	9.2	8.7	7.9	7.7	6.5	5.7	4.8	4.1	4.9	6.2	7.4	8.1	
Clear-Sky Solar Irradiance	taub	0.319	0.323	0.337	0.371	0.382	0.408	0.441	0.407	0.375	0.349	0.325	0.317		
	taud	2.349	2.404	2.417	2.348	2.369	2.330	2.276	2.388	2.448	2.480	2.471	2.360		
	Ebn at Noon	753	842	886	882	882	857	821	838	835	802	750	706		
	Edh at Noon	73	85	98	115	117	123	128	110	95	79	65	65		
All-Sky Solar Radiation	RadAvg	0.99	1.72	2.87	4.07	4.92	5.10	4.97	4.33	3.49	2.16	1.21	0.82		
	RadStd	0.07	0.15	0.20	0.38	0.38	0.46	0.36	0.27	0.22	0.17	0.15	0.07		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page