

LOURDES DE BLANC SABLON, QC, Canada

WMO: 718080

Lat: 51.443N

Lon: 57.189W

Elev: 122

StdP: 14.63

Time Zone: -4.00 (W04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.1	-8.2	-24.4	1.4	-11.4	-20.1	1.8	-7.4	47.6	22.4	42.6	23.2	12.8	270	0.852

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.4	66.6	59.7	64.1	59.0	62.1	57.9	61.7	64.3	60.3	62.6	59.0	61.2	11.0	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.7	79.6	62.6	59.3	75.6	61.2	58.0	72.1	60.2	27.7	64.5	26.7	62.8	25.9	61.3	70.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
39.6	34.1	29.1	-17.6	73.4	4.7	2.9	-20.9	75.5	-23.7	77.2	-26.3	78.8	-29.7	80.9		
			-18.2	65.6	4.5	2.0	-21.5	67.1	-24.1	68.3	-26.7	69.4	-29.9	70.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	34.6	12.5	12.6	20.3	30.2	39.0	47.2	54.4	56.6	49.3	40.2	30.6	20.4
	DBStd	16.79	11.57	11.45	9.60	6.10	4.54	4.82	3.82	3.78	5.12	5.34	7.51	10.31
	HDD50	6062	1161	1047	921	594	343	109	7	3	73	305	581	918
	HDD65	11105	1626	1467	1386	1044	806	534	329	260	471	768	1031	1383
	CDD50	432	0	0	0	0	1	26	144	208	51	2	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	3	0	0	0	0	0	1	1	1	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	12.3	14.5	14.6	14.7	13.5	11.0	9.7	8.5	9.5	11.1	12.4	13.8	14.9
Precipitation	PrecAvg	43.7	4.3	3.6	3.7	2.6	2.7	3.2	3.8	4.2	3.9	3.7	3.5	4.4
	PrecMax	59.4	13.9	6.5	7.0	5.3	6.1	7.2	8.7	9.4	8.0	8.1	6.0	6.9
	PrecMin	34.1	1.9	1.6	2.3	1.5	0.4	1.7	1.5	1.8	2.1	1.9	1.7	1.8
	PrecStd	5.3	2.4	1.3	1.1	0.9	1.3	1.1	1.4	1.8	1.5	1.5	1.1	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.9	39.3	38.9	48.3	59.7	68.5	70.5	71.1	65.5	56.9	51.4	41.6
		MCWB	37.6	37.8	36.4	43.2	49.8	59.1	61.4	62.0	59.7	53.3	50.1	40.5
	2%	DB	35.4	35.8	36.1	42.6	53.5	62.5	66.2	66.6	61.9	53.0	45.8	38.7
		MCWB	34.3	34.1	34.2	39.3	46.1	54.7	59.5	60.3	57.2	50.6	45.0	37.7
	5%	DB	32.5	33.2	34.5	39.6	49.2	58.2	63.0	64.6	59.5	50.2	42.8	36.7
		MCWB	31.7	31.7	32.7	36.8	43.9	52.3	58.1	59.7	55.7	47.9	41.7	35.4
	10%	DB	29.8	30.1	32.5	37.5	46.3	55.1	60.8	62.9	57.5	48.2	40.4	34.5
		MCWB	28.7	28.8	31.1	35.0	42.5	50.6	56.8	59.0	54.4	45.9	39.1	33.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.1	38.0	37.4	44.5	52.2	60.1	63.8	64.6	61.7	54.4	50.0	41.0
		MCDB	38.6	38.6	38.4	48.0	56.7	66.5	67.9	67.7	63.5	55.9	51.2	41.5
	2%	WB	34.4	34.6	34.7	39.7	47.6	56.3	61.0	62.1	58.7	51.0	45.1	38.0
		MCDB	35.2	35.7	35.7	41.6	52.0	60.5	64.0	64.5	60.9	52.5	45.6	38.5
	5%	WB	31.8	31.8	33.0	37.2	44.9	53.5	59.2	60.9	56.8	48.6	42.0	35.6
		MCDB	32.5	33.1	34.1	39.1	48.2	56.8	61.6	63.1	58.6	49.8	42.6	36.6
	10%	WB	28.8	28.9	31.2	35.4	42.8	51.3	57.7	59.9	55.1	46.4	39.3	33.4
		MCDB	29.7	30.2	32.5	37.1	45.8	54.1	59.9	61.9	57.0	47.8	40.1	34.3
Mean Daily Temperature Range	5% DB	MDBR	14.8	14.4	12.7	10.2	12.4	12.8	11.4	11.4	11.8	10.2	10.5	12.5
		MCDBR	14.7	12.3	10.3	11.5	17.8	18.8	15.5	13.7	13.5	12.1	11.1	11.1
		MCWBR	14.9	11.7	9.6	9.2	12.2	12.0	9.9	9.1	10.2	10.4	11.2	11.4
	5% WB	MCDBR	15.2	13.3	10.4	10.8	15.9	16.2	13.2	10.8	11.7	11.4	11.3	11.4
		MCWBR	15.4	13.0	10.1	9.1	11.9	11.5	9.4	8.1	10.0	10.7	11.7	11.7
Clear-Sky Solar Irradiance	taub	0.276	0.280	0.303	0.344	0.377	0.377	0.410	0.377	0.351	0.320	0.290	0.275	
	taud	2.319	2.329	2.298	2.280	2.330	2.383	2.345	2.435	2.478	2.524	2.501	2.362	
	Ebn at Noon	236	271	285	284	278	279	266	271	266	254	235	218	
	Edh at Noon	20	26	33	38	38	36	37	32	28	22	17	16	
All-Sky Solar Radiation	RadAvg	270	465	799	1183	1552	1605	1558	1330	976	584	319	213	
	RadStd	38	81	115	183	126	145	117	95	68	43	30	30	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	+3.13	N/A	+0.63	+0.86	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	N/A	N/A	N/A	+3.01	N/A	+0.68	+1.01	N/A	N/A	N/A	N/A

Nomenclature: See separate page