

DEER LAKE, NL, Canada

WMO: 718090

Lat: 49.211N

Lon: 57.397W

Elev: 72

StdP: 14.66

Time Zone: -3.50 (NAF)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-6.8	-1.1	-14.4	2.5	-5.9	-8.1	3.6	0.2	29.4	24.0	25.8	21.9	2.5	60	0.682

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.2	80.6	66.1	77.9	64.6	75.0	63.3	69.0	76.6	67.2	74.2	65.4	71.9	11.5	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.2	96.8	73.0	64.4	90.7	71.0	62.6	85.0	69.6	33.2	76.8	31.7	74.5	30.4	71.9	74.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 23.2	20.4	18.3	DB	-18.1	86.7	7.9	2.6	-23.8	88.5	-28.4	90.0	-32.8	91.5	-38.5	93.3	(4)
(5)			WB	-18.5	72.1	7.7	1.4	-24.1	73.1	-28.6	73.9	-33.0	74.7	-38.6	75.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	40.1	19.3	18.3	24.5	35.0	45.0	54.5	62.9	62.0	53.7	43.6	34.9	25.8
	DBStd	17.09	9.20	10.20	9.38	6.59	6.07	6.93	5.49	5.48	6.69	6.45	7.54	8.47
	HDD50	4755	951	886	791	452	181	31	1	1	36	219	457	749
	HDD65	9172	1416	1306	1256	901	620	323	104	123	343	663	903	1214
	CDD50	1137	0	0	0	1	26	164	401	373	146	22	4	0
	CDD65	81	0	0	0	0	0	7	40	30	4	0	0	0
	CDH74	791	0	0	0	0	10	112	388	250	30	1	0	0
	CDH80	99	0	0	0	0	0	13	53	30	3	0	0	0
Wind	WSAvg	8.1	8.9	8.9	9.2	9.2	8.3	7.8	7.3	6.8	7.3	7.3	8.0	8.5
Precipitation	PrecAvg	43.5	4.2	3.1	3.0	2.6	2.8	3.3	3.3	4.1	3.7	4.3	4.4	4.5
	PrecMax	51.1	6.4	8.3	5.3	4.4	4.1	6.3	8.2	6.6	7.6	7.6	6.9	7.9
	PrecMin	31.9	2.1	0.9	0.5	1.0	1.5	1.0	0.8	2.0	1.3	1.9	2.3	2.1
	PrecStd	5.0	1.3	1.7	1.2	1.1	0.8	1.5	1.7	1.2	1.4	1.5	1.2	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.2	47.0	48.0	60.4	74.7	81.6	84.4	83.4	77.8	67.8	62.0	49.0
		MCWB	47.5	44.3	42.0	51.3	58.6	64.0	68.8	68.0	66.1	59.5	57.6	46.8
	2%	DB	41.4	40.0	43.3	53.9	68.3	77.2	81.3	79.8	73.0	62.5	55.8	43.3
		MCWB	39.5	37.8	38.6	46.1	54.5	61.7	66.5	66.5	63.3	56.5	52.6	41.4
	5%	DB	36.2	35.7	39.7	49.3	63.4	73.3	78.5	76.8	69.1	58.2	50.4	39.5
		MCWB	34.3	33.5	35.5	42.8	52.3	60.0	65.0	64.8	61.4	53.6	47.8	37.6
	10%	DB	32.6	32.9	36.7	45.5	58.8	69.2	75.5	73.6	66.1	54.8	45.6	36.7
		MCWB	30.8	31.0	33.4	39.6	50.3	58.7	64.0	63.1	60.0	50.8	43.3	34.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.6	44.8	44.1	53.0	60.6	68.1	71.9	71.2	68.5	61.7	58.0	47.1
		MCDB	49.3	46.3	46.7	57.9	69.0	76.8	81.3	79.1	74.4	65.1	61.4	48.8
	2%	WB	39.7	38.0	39.5	47.3	56.9	64.9	69.4	68.6	65.7	57.5	52.9	41.7
		MCDB	41.2	39.6	42.5	52.1	64.7	72.1	77.0	76.4	70.6	61.3	55.5	43.1
	5%	WB	34.4	33.8	36.1	43.4	53.8	62.3	67.5	66.8	63.0	54.3	48.3	37.8
		MCDB	36.0	35.4	38.9	48.4	61.5	71.0	74.7	73.8	67.9	57.7	50.3	39.2
	10%	WB	30.9	31.1	33.6	40.1	50.6	59.6	65.6	65.0	60.2	51.0	43.4	35.0
		MCDB	32.5	32.7	36.4	44.7	58.5	67.5	72.7	71.3	65.2	54.4	45.3	36.4
Mean Daily Temperature Range	5% DB	MDBR	14.8	16.5	16.7	15.2	19.9	20.8	20.2	19.4	18.4	15.4	12.0	11.6
		MCDBR	18.3	17.5	19.8	22.9	31.6	30.1	27.4	24.9	23.7	22.0	18.9	14.6
		MCWBR	17.7	15.9	16.1	16.0	19.5	16.8	14.8	13.6	15.2	16.6	16.7	14.2
	5% WB	MCDBR	18.3	16.5	17.1	20.7	27.1	24.3	21.6	20.8	20.1	20.0	18.6	14.1
		MCWBR	17.8	15.5	15.0	15.7	18.2	15.1	13.0	12.7	14.7	16.3	17.1	14.1
Clear-Sky Solar Irradiance	taub		0.299	0.358	0.341	0.388	0.385	0.388	0.427	0.403	0.377	0.339	0.317	0.304
	taud		2.224	2.015	2.225	2.221	2.342	2.358	2.286	2.347	2.417	2.485	2.435	2.265
	Ebn at Noon		233	238	273	272	278	277	263	265	260	253	231	214
	Edh at Noon		24	38	36	41	38	37	40	36	30	24	20	21
All-Sky Solar Radiation	RadAvg		271	499	889	1259	1528	1612	1614	1351	1012	617	315	194
	RadStd		27	71	81	146	107	174	128	93	82	50	35	19

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	+2.93	N/A	+0.97	+1.28	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)		N/A	N/A	+2.23	N/A	+0.68	+0.90	N/A	N/A	N/A	N/A

Nomenclature: See separate page