

CHEVERY, QC, Canada

WMO: 718140

Lat: 50.4650N

Lon: 59.6394W

Elev: 25

StdP: 14.68

Time Zone: -4.00 (W04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.0	-11.3	-25.8	1.3	-15.5	-20.6	1.8	-10.7	35.2	16.5	31.2	20.0	7.8	320	0.781

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.6	69.0	59.8	65.8	59.3	63.5	58.8	62.8	65.4	61.4	63.9	60.1	62.5	10.9	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.9	82.7	63.6	60.4	78.4	62.3	59.1	74.8	61.2	28.4	65.4	27.5	63.9	26.5	62.7	72.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.9	25.2	22.0	-24.2	78.1	5.4	3.5	-28.1	80.6	-31.3	82.7	-34.3	84.7	-38.2	87.2		
(5)			-24.5	66.7	5.4	3.0	-28.4	68.9	-31.6	70.7	-34.6	72.3	-38.6	74.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	34.6	10.4	11.4	19.6	30.1	39.5	48.8	55.9	57.5	50.6	40.9	30.3	18.8		
	DBStd	17.93	12.11	11.17	9.81	5.81	4.75	5.04	4.04	4.14	5.67	5.77	8.04	11.05		
	HDD50	6162	1228	1081	942	597	326	80	3	2	59	287	590	967		
	HDD65	11093	1693	1501	1407	1047	789	485	283	235	434	747	1040	1432		
	CDD50	546	0	0	0	0	1	44	187	234	76	4	0	0		
	CDD65	3	0	0	0	0	0	0	1	2	0	0	0	0		
	CDH74	25	0	0	0	0	0	2	12	9	2	0	0	0		
	CDH80	3	0	0	0	0	0	0	1	1	1	0	0	0		
	WSAvg	10.1	11.5	12.0	12.0	10.9	9.4	8.9	8.0	8.0	9.2	9.7	10.7	11.5		
	PrecAvg	49.4	4.4	3.4	3.7	3.0	3.4	3.8	4.5	5.0	4.5	4.5	4.4	4.7		
(15) Precipitation	PrecMax	59.4	10.4	5.7	5.8	5.1	5.8	7.4	9.0	8.3	7.8	7.2	7.0	7.6		
	PrecMin	41.6	1.6	1.4	1.9	1.6	1.4	2.2	2.6	2.4	2.5	2.3	2.0	2.3		
	PrecStd	4.0	1.7	1.0	1.0	0.8	1.2	1.0	1.2	1.5	1.1	1.3	1.1	1.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.7	36.6	39.4	46.0	60.3	70.0	74.9	74.3	70.7	59.3	48.5	40.9		
		MCWB	36.6	35.2	35.6	38.5	49.6	57.1	61.3	61.5	59.8	52.7	47.0	39.9		
	2%	DB	34.7	33.7	36.7	41.6	53.8	63.4	68.3	68.8	64.4	54.6	45.7	38.7		
		MCWB	33.9	32.7	34.0	37.2	46.2	54.5	59.4	61.0	56.7	50.3	44.5	37.7		
	5%	DB	32.4	31.7	34.7	39.1	50.2	59.7	64.9	66.0	61.5	52.0	43.6	36.6		
		MCWB	31.9	30.7	32.7	35.9	44.7	52.9	59.0	60.4	56.5	48.5	42.5	35.5		
	10%	DB	30.1	29.0	32.8	37.3	47.4	56.6	62.3	64.0	59.4	49.9	41.6	34.4		
		MCWB	29.3	27.8	31.3	35.0	43.3	52.2	58.4	60.1	55.6	47.3	40.3	33.3		
	0.4%	WB	36.9	35.8	36.7	41.4	51.5	59.8	64.7	65.3	62.2	54.5	47.6	40.3		
		MCDB	37.2	35.9	38.1	44.9	55.8	65.7	69.0	68.7	65.7	56.8	47.9	40.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	33.9	32.8	34.7	38.4	47.8	56.9	62.1	63.4	60.0	51.5	44.9	38.0		
		MCDB	34.4	33.4	36.2	40.3	52.2	60.5	64.8	66.0	62.4	53.4	45.4	38.5		
	5%	WB	31.9	30.8	33.2	36.7	45.7	54.6	60.5	62.1	58.2	49.5	42.8	35.7		
		MCDB	32.3	31.6	34.3	38.4	48.9	57.7	63.3	64.3	60.3	51.1	43.3	36.5		
	10%	WB	29.1	28.0	31.5	35.4	43.9	52.6	59.0	61.0	56.5	47.8	40.5	33.4		
		MCDB	29.8	28.9	32.6	36.8	46.8	55.6	61.4	63.1	58.5	49.4	41.3	34.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	17.8	17.8	16.5	11.6	12.9	12.8	11.7	12.6	14.4	13.5	12.7	14.7		
		MCDBR	16.7	15.0	13.2	12.5	19.1	19.0	17.5	16.4	17.8	15.6	11.5	12.3		
		MCWBR	16.2	14.7	11.4	9.6	12.7	11.3	10.5	10.3	11.8	11.8	11.4	12.3		
		MCDBR	15.9	15.3	12.0	10.7	15.3	15.9	13.8	12.8	13.8	12.2	10.9	12.7		
	5% WB	MCWBR	16.5	15.3	11.1	8.8	11.1	10.7	9.5	9.4	10.5	10.7	11.3	13.2		
(40) Clear-Sky Solar Irradiance	taub		0.280	0.293	0.302	0.339	0.361	0.380	0.413	0.384	0.352	0.330	0.297	0.279		
	taud		2.354	2.309	2.343	2.375	2.427	2.389	2.349	2.432	2.491	2.515	2.519	2.406		
	Ebn at Noon		241	268	287	287	284	279	266	270	267	253	237	225		
	Edh at Noon		20	27	32	35	35	36	37	33	28	23	17	17		
(44) All-Sky Solar Radiation	RadAvg		302	582	1006	1370	1617	1680	1604	1414	1050	654	337	228		
	RadStd		31	66	125	158	119	167	141	83	76	47	31	26		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)	N/A	N/A	+2.79	N/A	+0.72	+0.77	N/A	N/A	N/A	N/A

Nomenclature: See separate page