

CHEVERY, QC, Canada

WMO: 718140

Lat: 50.4650N

Lon: 59.6394W

Elev: 8

StdP: 101.23

Time Zone: -4.00 (W04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-26.7	-24.0	-32.1	0.2	-26.4	-29.2	0.3	-23.7	15.7	-8.6	13.9	-6.7	3.5	320	0.781

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.0	20.6	15.5	18.8	15.2	17.5	14.9	17.1	18.6	16.3	17.7	15.6	16.9	4.9	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.6	11.8	17.6	15.8	11.2	16.8	15.0	10.7	16.2	48.3	18.6	46.0	17.7	43.9	17.1	22.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.9	11.3	9.9	DB	-31.2	25.6	3.0	2.0	-33.4	27.0	-35.2	28.2	-36.8	29.3	-39.0	30.7
			WB	-31.4	19.3	3.0	1.7	-33.5	20.5	-35.3	21.5	-37.0	22.4	-39.2	23.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	1.5	-12.0	-11.5	-6.9	-1.1	4.2	9.3	13.3	14.2	10.3	4.9	-0.9	-7.3
	DBStd	9.96	6.73	6.20	5.45	3.23	2.64	2.80	2.25	2.30	3.15	3.20	4.47	6.14
	HDD10.0	3423	682	601	523	332	181	44	2	1	33	159	328	537
	HDD18.3	6163	941	834	782	582	438	269	157	131	241	415	578	796
	CDD10.0	303	0	0	0	0	1	24	104	130	42	2	0	0
	CDD18.3	2	0	0	0	0	0	0	1	1	0	0	0	0
	CDH23.3	14	0	0	0	0	0	1	7	5	1	0	0	0
	CDH26.7	2	0	0	0	0	0	0	1	1	1	0	0	0
Wind	WSAvg	4.5	5.1	5.4	5.4	4.9	4.2	4.0	3.6	3.6	4.1	4.4	4.8	5.1
Precipitation	PrecAvg	1254	113	86	93	75	87	96	114	128	114	114	113	120
	PrecMax	1508	265	144	148	129	148	187	228	212	199	184	178	194
	PrecMin	1056	40	36	49	40	35	56	67	61	63	59	50	59
	PrecStd	101	43	26	26	20	31	26	30	38	29	32	29	31
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.2	2.5	4.1	7.8	15.7	21.1	23.8	23.5	21.5	15.2	9.2	4.9
		MCWB	2.6	1.8	2.0	3.6	9.8	13.9	16.3	16.4	15.5	11.5	8.4	4.4
	2%	DB	1.5	1.0	2.6	5.3	12.1	17.4	20.2	20.5	18.0	12.6	7.6	3.7
		MCWB	1.1	0.4	1.1	2.9	7.9	12.5	15.2	16.1	13.7	10.1	7.0	3.2
	5%	DB	0.2	-0.2	1.5	3.9	10.1	15.4	18.3	18.9	16.4	11.1	6.5	2.6
		MCWB	-0.1	-0.7	0.4	2.2	7.1	11.6	15.0	15.8	13.6	9.2	5.8	2.0
	10%	DB	-1.1	-1.7	0.4	3.0	8.6	13.7	16.9	17.8	15.2	9.9	5.3	1.3
		MCWB	-1.5	-2.3	-0.4	1.6	6.3	11.2	14.6	15.6	13.1	8.5	4.6	0.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.7	2.1	2.6	5.2	10.9	15.4	18.2	18.5	16.8	12.5	8.7	4.6
		MCDB	2.9	2.2	3.4	7.1	13.2	18.7	20.6	20.4	18.7	13.8	8.8	4.8
	2%	WB	1.1	0.5	1.5	3.6	8.8	13.8	16.7	17.5	15.6	10.8	7.2	3.3
		MCDB	1.3	0.8	2.3	4.6	11.2	15.8	18.2	18.9	16.9	11.9	7.4	3.6
	5%	WB	-0.1	-0.7	0.6	2.6	7.6	12.6	15.8	16.7	14.5	9.7	6.0	2.1
		MCDB	0.2	-0.2	1.3	3.6	9.4	14.3	17.4	17.9	15.7	10.6	6.3	2.5
	10%	WB	-1.6	-2.2	-0.3	1.9	6.6	11.4	15.0	16.1	13.6	8.8	4.7	0.8
		MCDB	-1.2	-1.7	0.3	2.7	8.2	13.1	16.3	17.3	14.7	9.7	5.1	1.2
Mean Daily Temperature Range	5% DB	MDBR	9.9	9.9	9.2	6.4	7.2	7.1	6.5	7.0	8.0	7.5	7.1	8.2
		MCDBR	9.3	8.3	7.3	6.9	10.6	10.5	9.7	9.1	9.9	8.7	6.4	6.8
	5% WB	MCWBR	9.0	8.1	6.4	5.3	7.0	6.3	5.9	5.7	6.6	6.6	6.3	6.8
		MCWBR	8.9	8.5	6.7	6.0	8.5	8.8	7.7	7.1	7.7	6.8	6.0	7.1
Clear-Sky Solar Irradiance	taub		0.280	0.293	0.302	0.339	0.361	0.380	0.413	0.384	0.352	0.330	0.297	0.279
		taud	2.354	2.309	2.343	2.375	2.427	2.389	2.349	2.432	2.491	2.515	2.519	2.406
	Ebn at Noon		760	844	906	905	896	878	840	850	843	799	748	709
		Edh at Noon	64	86	100	109	109	114	117	103	87	71	55	53
All-Sky Solar Radiation	RadAvg		0.95	1.83	3.17	4.32	5.10	5.29	5.06	4.46	3.31	2.06	1.06	0.72
	RadStd		0.10	0.21	0.39	0.50	0.38	0.53	0.45	0.26	0.24	0.15	0.10	0.08

Historical Trends

	DBAvg	Heating		Cooling		Degree-Days			
		99% DB	99% DP	1% DB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		N/A	N/A	+1.55	N/A	+0.40	+0.43	N/A	N/A

Nomenclature: See separate page