

GOOSE BAY, NL, Canada

WMO: 718160

Lat: 53.317N

Lon: 60.417W

Elev: 160

StdP: 14.61

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.4	-16.8	-32.0	0.9	-19.6	-28.6	1.1	-16.0	32.4	8.4	29.3	8.3	10.1	260	0.756

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.2	82.5	64.1	78.1	62.2	74.2	60.6	66.3	77.9	64.4	74.4	62.4	71.4	12.7	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.1	83.8	70.3	60.2	78.3	68.9	58.3	73.0	67.1	31.1	77.8	29.7	74.3	28.2	71.5	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.2	23.6	20.9	DB	-26.4	90.4	3.1	3.5	-28.6	92.9	-30.5	95.0	-32.2	96.9	-34.5	99.5	(4)
(5)			WB	-26.7	70.5	3.1	2.0	-29.0	71.9	-30.8	73.1	-32.5	74.2	-34.7	75.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	33.6	2.6	4.8	16.0	30.3	42.7	54.0	61.2	60.5	51.2	39.3	26.4	12.1
	DBStd	22.36	12.92	11.83	11.68	8.65	7.29	8.46	6.85	6.53	7.37	6.77	9.07	12.01
	HDD50	6976	1470	1266	1055	591	251	49	3	3	69	337	707	1175
	HDD65	11560	1935	1686	1520	1040	693	347	156	171	420	795	1157	1640
	CDD50	984	0	0	0	1	24	168	351	328	105	7	0	0
	CDD65	94	0	0	0	0	1	16	40	31	6	0	0	0
	CDH74	919	0	0	0	0	34	200	353	283	49	0	0	0
	CDH80	246	0	0	0	0	8	66	87	74	11	0	0	0
	WSAvg	9.4	10.3	10.0	9.7	9.7	9.0	8.9	8.4	8.2	9.5	9.4	9.9	10.3
(15) Precipitation	PrecAvg	38.9	2.8	2.4	2.8	2.5	2.8	3.7	4.7	4.0	3.7	3.4	3.0	2.9
	PrecMax	50.7	8.1	5.9	6.8	6.1	5.7	7.3	9.4	7.1	6.5	6.6	7.6	5.9
	PrecMin	30.4	0.5	0.4	0.5	0.3	0.5	0.8	2.4	0.9	0.9	1.1	0.8	0.6
	PrecStd	5.3	1.4	1.1	1.4	1.3	1.2	1.4	1.6	1.5	1.3	1.3	1.3	1.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.3	40.4	45.4	59.0	79.5	88.3	87.6	87.4	80.4	64.5	54.1	41.9
		MCWB	35.6	37.6	38.9	44.9	58.0	65.7	65.8	67.2	64.8	55.3	50.4	39.2
	2%	DB	33.9	33.8	40.4	51.2	68.8	79.7	81.9	80.9	72.8	58.0	46.8	36.6
		MCWB	32.5	32.3	34.8	41.8	52.4	61.6	63.8	64.2	60.4	51.4	43.1	34.6
	5%	DB	29.7	29.6	36.3	46.7	62.2	73.7	77.7	76.4	67.9	53.6	41.2	33.8
		MCWB	28.2	27.6	32.4	39.5	49.0	58.8	62.3	62.2	58.3	47.7	38.7	32.3
	10%	DB	23.6	24.0	33.1	42.3	56.3	69.0	73.8	72.4	63.4	49.5	37.9	30.3
		MCWB	21.9	22.0	29.9	36.6	46.4	56.6	60.8	60.7	55.1	44.8	35.6	28.5
	0.4%	WB	36.1	38.1	39.8	46.8	58.2	67.7	68.3	68.8	66.0	56.6	51.0	39.3
		MCDB	37.7	40.3	44.6	55.3	74.9	83.3	80.5	82.3	77.8	62.3	53.7	41.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	32.6	32.5	35.6	42.9	53.9	63.8	66.1	66.2	62.1	52.4	43.5	34.9
		MCDB	33.8	33.6	39.5	50.5	66.3	75.8	76.9	77.2	70.2	57.5	46.1	36.2
	5%	WB	28.3	27.6	32.7	40.0	50.1	60.7	64.3	63.9	59.2	48.6	39.1	32.3
		MCDB	29.8	29.5	35.9	45.8	60.6	71.0	73.9	73.5	66.8	52.8	40.9	33.8
	10%	WB	21.9	22.1	30.2	37.2	46.6	58.0	62.4	61.9	55.8	45.1	35.8	28.6
		MCDB	23.6	24.0	33.4	41.7	55.4	67.1	71.0	70.6	62.7	48.9	37.6	30.4
	5% DB	MDBR	15.1	17.6	18.6	15.8	17.7	18.5	17.2	16.8	15.7	11.7	11.2	13.3
		MCDBR	17.7	17.1	19.6	21.9	30.9	27.5	24.8	24.3	22.6	18.6	13.9	14.0
		MCWBR	17.1	16.0	16.1	14.8	17.7	13.9	11.7	12.0	13.8	13.8	12.5	13.4
		MCWBR	17.5	16.4	18.2	19.3	28.1	23.6	20.8	21.0	20.5	17.3	14.1	13.4
(40) Clear-Sky Solar Irradiance	taub		0.251	0.273	0.282	0.342	0.375	0.380	0.413	0.376	0.350	0.313	0.275	0.250
		taud	2.244	2.226	2.234	2.132	2.279	2.363	2.319	2.413	2.455	2.521	2.419	2.243
	Ebn at Noon		233	264	287	280	277	276	264	268	262	251	227	209
		Edh at Noon	19	27	34	43	39	36	38	32	28	21	16	16
(44) All-Sky Solar Radiation	RadAvg		294	603	1019	1432	1635	1610	1479	1255	940	521	278	202
	RadStd		34	58	131	140	171	149	122	79	73	36	24	25

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page