

GOOSE BAY, NL, Canada

WMO: 718160

Lat: 53.317N

Lon: 60.417W

Elev: 49

StdP: 100.74

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-29.1	-27.1	-35.6	0.1	-28.7	-33.7	0.2	-26.7	14.5	-13.1	13.1	-13.2	4.5	260	0.756

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	28.1	17.8	25.6	16.8	23.4	15.9	19.0	25.5	18.0	23.5	16.9	21.9	5.7	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.7	12.0	21.3	15.7	11.2	20.5	14.6	10.4	19.5	54.5	25.4	51.1	23.5	47.7	21.9	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.2	10.5	9.3	-32.4	32.5	1.7	1.9	-33.7	33.9	-34.7	35.0	-35.7	36.1	-37.0	37.5		
(5)			-32.6	21.4	1.7	1.1	-33.9	22.2	-34.9	22.8	-35.8	23.4	-37.1	24.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	0.9	-16.4	-15.1	-8.9	-0.9	5.9	12.2	16.2	15.8	10.7	4.1	-3.1	-11.1	(6)	
(7)		DBStd	12.42	7.18	6.57	6.49	4.81	4.05	4.70	3.80	3.63	4.09	3.76	5.04	6.67	(7)	
(8)		HDD10.0	3876	817	703	586	328	139	27	2	2	38	187	393	653	(8)	
(9)		HDD18.3	6422	1075	937	844	578	385	193	87	95	233	442	643	911	(9)	
(10)		CDD10.0	547	0	0	0	1	13	93	195	182	58	4	0	0	(10)	
(11)		CDD18.3	52	0	0	0	0	1	9	22	17	3	0	0	0	(11)	
(12)		CDH23.3	511	0	0	0	0	19	111	196	157	27	0	0	0	(12)	
(13)		CDH26.7	137	0	0	0	0	4	37	48	41	6	0	0	0	(13)	
(14)	Wind	WSAvg	4.2	4.6	4.5	4.4	4.3	4.0	3.7	3.7	4.2	4.2	4.4	4.6	(14)		
(15)	Precipitation	PrecAvg	987	70	60	70	64	71	95	119	101	93	86	77	73	(15)	
(16)		PrecMax	1289	206	150	172	156	144	186	240	180	166	168	192	149	(16)	
(17)		PrecMin	771	12	9	13	8	12	20	62	24	24	29	20	16	(17)	
(18)		PrecStd	134	35	29	35	32	30	36	40	37	33	32	32	34	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.5	4.7	7.5	15.0	26.4	31.3	30.9	30.8	26.9	18.1	12.3	5.5	(19)	
(20)			MCWB	2.0	3.1	3.8	7.2	14.5	18.7	18.8	19.5	18.2	12.9	10.2	4.0	(20)	
(21)		2%	DB	1.1	1.0	4.6	10.7	20.4	26.5	27.7	27.2	22.7	14.4	8.2	2.6	(21)	
(22)			MCWB	0.3	0.1	1.6	5.4	11.3	16.4	17.7	17.9	15.8	10.8	6.2	1.5	(22)	
(23)		5%	DB	-1.3	-1.3	2.4	8.2	16.8	23.1	25.4	24.6	19.9	12.0	5.1	1.0	(23)	
(24)			MCWB	-2.1	-2.5	0.2	4.1	9.5	14.9	16.9	16.8	14.6	8.7	3.7	0.2	(24)	
(25)		10%	DB	-4.7	-4.4	0.6	5.7	13.5	20.6	23.2	22.4	17.5	9.7	3.3	-1.0	(25)	
(26)			MCWB	-5.6	-5.5	-1.2	2.6	8.0	13.6	16.0	16.0	12.8	7.1	2.0	-1.9	(26)	
(27)		Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.3	3.4	4.3	8.2	14.6	19.8	20.2	20.5	18.9	13.7	10.6	4.1	(27)
(28)				MDCB	3.1	4.6	7.0	13.0	23.9	28.5	26.9	28.0	25.4	16.8	12.1	5.0	(28)
(29)	2%		WB	0.3	0.3	2.0	6.1	12.2	17.7	18.9	19.0	16.7	11.3	6.4	1.6	(29)	
(30)			MDCB	1.0	0.9	4.1	10.3	19.1	24.3	25.0	25.1	21.2	14.2	7.9	2.3	(30)	
(31)	5%		WB	-2.0	-2.5	0.4	4.4	10.1	16.0	17.9	17.7	15.1	9.2	4.0	0.2	(31)	
(32)			MDCB	-1.2	-1.4	2.2	7.7	15.9	21.7	23.3	23.1	19.3	11.5	5.0	1.0	(32)	
(33)	10%		WB	-5.6	-5.5	-1.0	2.9	8.1	14.4	16.9	16.6	13.2	7.3	2.1	-1.9	(33)	
(34)			MDCB	-4.7	-4.4	0.8	5.4	13.0	19.5	21.7	21.4	17.0	9.4	3.1	-0.9	(34)	
(35)	Mean Daily Temperature Range		5% DB	MDBR	8.4	9.8	10.3	8.8	9.8	10.3	9.6	9.3	8.7	6.5	6.2	7.4	(35)
(36)				MCDBR	9.8	9.5	10.9	12.2	17.2	15.3	13.8	13.5	12.5	10.3	7.7	7.8	(36)
(37)		MCWBR		9.5	8.9	8.9	8.2	9.8	7.7	6.5	6.7	7.6	7.7	6.9	7.4	(37)	
(38)		5% WB	MCDBR	9.7	9.1	10.1	10.7	15.6	13.1	11.6	11.6	11.4	9.6	7.8	7.5	(38)	
(39)			MCWBR	9.4	8.6	8.7	7.7	9.4	7.5	6.2	6.5	7.6	7.6	7.3	7.2	(39)	
(40)																	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.251	0.273	0.282	0.342	0.375	0.380	0.413	0.376	0.350	0.313	0.275	0.250	(40)		
(41)		taud	2.244	2.226	2.234	2.132	2.279	2.363	2.319	2.413	2.455	2.521	2.419	2.243	(41)		
(42)		Ebn at Noon	736	833	906	884	872	870	831	846	826	792	715	660	(42)		
(43)		Edh at Noon	61	86	106	135	124	115	119	102	87	66	52	50	(43)		
(44)	All-Sky Solar Radiation	RadAvg	0.93	1.90	3.21	4.51	5.15	5.07	4.66	3.96	2.96	1.64	0.88	0.64	(44)		
(45)		RadStd	0.11	0.18	0.41	0.44	0.54	0.47	0.38	0.25	0.23	0.11	0.08	0.08	(45)		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page