

WABUSH, NL, Canada

WMO: 718250

Lat: 52.920N

Lon: 66.860W

Elev: 1809

StdP: 13.76

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-31.7	-27.5	-40.3	0.6	-31.2	-36.1	0.7	-27.1	25.0	-1.2	22.7	1.0	4.9	180	0.802

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.2	76.9	60.6	73.1	58.8	69.6	57.4	63.5	71.5	61.6	69.0	59.7	66.5	11.2	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.8	85.1	66.0	58.8	79.1	64.0	56.8	73.6	62.3	29.9	71.7	28.4	69.3	27.1	66.4	72.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.9	19.1	17.9	-39.8	83.4	5.1	3.1	-43.5	85.6	-46.4	87.4	-49.3	89.2	-53.0	91.4		
(5)			-40.0	67.6	5.0	2.1	-43.6	69.0	-46.5	70.2	-49.4	71.4	-53.0	72.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.1	-5.7	-3.4	8.9	24.6	40.1	51.8	57.9	56.1	46.7	34.6	19.4	3.7		
	DBStd	24.37	13.30	13.00	13.40	10.25	8.26	7.68	5.46	5.77	7.13	7.58	10.21	12.94		
	HDD50	8643	1726	1494	1273	763	325	66	4	12	146	480	918	1436		
	HDD65	13500	2191	1914	1738	1213	771	400	230	281	550	943	1368	1901		
	CDD50	639	0	0	0	0	19	121	248	201	47	3	0	0		
	CDD65	21	0	0	0	0	0	5	9	6	1	0	0	0		
	CDH74	253	0	0	0	0	17	74	91	58	13	0	0	0		
	CDH80	32	0	0	0	0	1	15	10	4	2	0	0	0		
	WSAvg	8.7	8.6	8.6	9.3	9.5	8.6	8.6	7.8	7.8	9.0	9.2	9.1	8.3		
	PrecAvg	36.9	2.6	1.9	2.4	2.3	2.5	3.5	4.5	3.7	4.0	3.4	3.1	2.8		
	PrecMax	50.4	4.1	3.1	5.4	5.9	5.4	6.4	7.8	6.2	7.0	6.1	6.0	5.4		
(15) Precipitation	PrecMin	27.3	0.8	0.4	0.6	0.4	1.1	1.5	2.7	1.8	2.2	1.4	1.4	0.7		
	PrecStd	5.4	0.9	0.7	1.1	1.3	1.1	1.2	1.4	1.3	1.3	1.1	1.2	1.1		
	DB	33.4	34.1	43.3	53.7	76.3	82.1	80.8	79.9	75.3	60.2	44.0	35.9			
	MCWB	32.5	32.9	36.1	41.3	55.7	62.4	62.1	63.6	62.5	52.2	41.0	35.2			
	2% DB	27.7	30.0	36.5	47.2	68.0	74.8	76.4	74.8	67.0	54.0	38.7	32.4			
(23) Mean Coincident Wet Bulb Temperatures	MCWB	26.9	28.8	32.9	38.3	51.7	58.9	60.1	61.4	57.8	49.2	37.5	31.9			
	5% DB	21.5	23.1	33.1	42.7	61.1	70.2	72.8	70.5	61.9	49.7	35.3	27.9			
	MCWB	20.5	21.4	30.5	36.1	48.0	56.2	59.0	59.2	55.2	46.0	33.9	27.0			
	10% DB	15.7	17.3	29.2	38.7	55.4	66.2	69.2	66.9	58.4	45.8	33.1	22.9			
	MCWB	14.8	16.0	26.6	34.2	45.9	54.2	57.8	57.9	53.0	42.9	32.0	21.9			
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	32.9	33.3	37.1	42.9	57.8	64.6	65.8	66.1	63.8	54.7	42.5	35.3			
	MCDB	33.6	33.6	41.1	50.3	70.2	74.9	73.8	74.0	70.5	58.9	43.4	35.7			
	2% WB	27.0	28.6	33.6	39.3	53.2	61.6	62.9	63.5	59.6	50.5	37.5	32.0			
	MCDB	27.8	30.1	35.9	45.2	64.7	70.6	70.1	71.2	64.9	53.1	38.3	32.4			
	5% WB	20.7	21.6	30.5	36.9	49.7	59.0	61.1	61.3	56.8	46.5	34.1	27.0			
(33) Mean Daily Temperature Range	MCDB	21.5	23.0	33.0	41.5	59.1	66.6	68.6	67.5	61.4	48.7	34.9	27.8			
	10% WB	14.8	16.1	26.7	34.8	46.4	56.2	59.6	59.0	53.4	43.1	32.1	22.0			
	MCDB	15.6	17.4	29.1	38.6	54.9	63.8	66.6	65.2	57.4	45.6	33.2	22.9			
	5% DB	18.7	19.7	21.6	22.8	31.0	27.5	24.4	22.8	21.4	18.5	11.7	15.4			
	MCWBR	18.4	18.6	18.3	15.8	17.3	13.7	11.5	11.7	13.8	14.0	11.3	15.4			
(40) Clear-Sky Solar Irradiance	taub	0.233	0.250	0.263	0.314	0.339	0.366	0.397	0.359	0.341	0.292	0.252	0.228			
	taud	2.237	2.232	2.228	2.135	2.318	2.389	2.324	2.444	2.469	2.547	2.316	2.207			
	Ebn at Noon	246	277	296	291	288	281	269	275	266	262	236	223			
	Edh at Noon	19	27	34	43	38	36	37	31	27	20	18	16			
(44) All-Sky Solar Radiation	RadAvg	353	721	1225	1637	1719	1659	1501	1204	895	499	248	223			
	RadStd	29	48	85	103	161	118	96	88	85	41	31	30			

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page