

PANGNIRTUNG, NU, Canada

WMO: 718260

Lat: 66.143N

Lon: 65.711W

Elev: 23

StdP: 101.05

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-37.2	-35.3	-42.1	0.1	-37.0	-40.0	0.1	-35.0	14.5	-6.4	12.3	-10.6	0.8	250	0.956

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.6	15.0	10.5	13.2	9.4	11.7	8.6	11.1	14.3	9.9	12.4	8.9	11.2	5.3	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
9.2	7.2	12.3	8.1	6.7	11.0	7.3	6.4	10.0	32.1	14.4	29.2	12.6	27.0	11.3	17.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.3	9.4	8.1	-37.4	19.9	2.5	2.5	-39.2	21.7	-40.6	23.1	-42.0	24.6	-43.8	26.4		
(5)			-37.5	13.7	2.5	1.6	-39.3	14.8	-40.7	15.7	-42.1	16.6	-43.9	17.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-7.6	-23.9	-25.5	-21.9	-13.1	-2.7	3.9	8.3	7.8	3.2	-3.1	-9.2	-16.6		
	DBStd	13.03	7.62	7.64	7.81	6.37	4.54	2.66	2.63	2.39	2.72	3.94	5.20	7.38		
	HDD10.0	6459	1051	994	988	692	395	184	67	75	204	407	577	823		
	HDD18.3	9478	1309	1228	1246	942	653	434	312	326	454	666	827	1082		
	CDD10.0	22	0	0	0	0	0	1	14	7	0	0	0	0		
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	2.9	2.0	2.0	2.1	2.6	3.5	3.7	3.5	3.3	3.1	3.1	3.2	2.6		
(15) Precipitation	PrecAvg	371	17	13	15	18	27	39	39	51	56	43	30	23		
	PrecMax	603	47	45	46	49	54	127	111	116	147	82	90	63		
	PrecMin	158	3	1	2	1	4	8	10	10	5	12	6	4		
	PrecStd	104	11	10	11	12	12	27	22	27	35	17	15	15		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.7	1.2	3.1	5.0	8.4	14.4	19.4	17.5	11.5	9.0	5.1	3.4		
		MCWB	-0.1	-1.6	0.8	2.1	4.9	8.6	12.6	12.3	7.0	5.0	2.5	0.8		
	2%	DB	-4.2	-5.1	-2.7	0.8	5.9	11.4	15.9	14.5	9.4	6.2	2.5	-0.2		
		MCWB	-6.0	-6.6	-4.2	-1.0	3.1	7.1	11.1	10.0	5.9	3.0	0.3	-2.2		
	5%	DB	-8.9	-10.6	-6.6	-1.7	4.3	9.5	13.8	12.9	8.0	3.5	-0.1	-3.7		
		MCWB	-10.2	-11.7	-7.8	-3.0	2.1	6.3	10.0	9.3	5.1	1.2	-1.6	-5.1		
	10%	DB	-12.6	-14.3	-10.6	-3.9	2.8	8.0	12.3	11.4	6.9	1.9	-2.1	-6.7		
		MCWB	-13.4	-15.1	-11.6	-5.1	1.0	5.4	9.2	8.6	4.6	0.3	-3.4	-7.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.6	-1.4	1.0	2.5	5.1	9.3	13.6	12.8	7.8	5.6	2.9	1.1		
		MCDB	2.8	1.0	2.9	4.7	7.9	13.0	18.6	16.6	10.4	8.7	4.8	3.5		
	2%	WB	-6.0	-6.6	-4.3	-0.8	3.4	7.6	11.8	10.7	6.5	3.3	0.4	-2.1		
		MCDB	-4.3	-5.2	-2.8	0.7	5.5	10.7	15.0	13.6	8.6	5.7	2.3	-0.3		
	5%	WB	-10.1	-11.7	-7.7	-3.0	2.2	6.4	10.5	9.7	5.6	1.6	-1.6	-5.0		
		MCDB	-8.9	-10.6	-6.6	-1.8	4.0	9.1	13.3	12.0	7.4	3.2	-0.3	-3.8		
	10%	WB	-13.4	-15.0	-11.6	-5.1	1.2	5.6	9.4	8.9	4.8	0.4	-3.4	-7.8		
		MCDB	-12.5	-14.3	-10.6	-3.9	2.5	7.9	11.9	10.9	6.5	1.7	-2.1	-6.7		
(35) Mean Daily Temperature Range	MDBR		5.7	5.7	6.2	6.7	5.0	5.1	5.6	4.9	3.9	3.7	4.3	5.2		
	5% DB	MCDBR	9.7	10.1	9.8	7.2	6.3	7.8	8.5	7.6	5.3	4.7	5.9	7.0		
		MCWBR	8.6	9.0	8.6	6.1	4.4	5.0	5.1	4.7	3.6	3.5	5.1	5.9		
	5% WB	MCDBR	9.7	10.0	9.9	7.2	5.9	7.2	8.1	6.7	4.9	4.5	5.8	7.1		
		MCWBR	8.6	9.0	8.8	6.1	4.3	4.9	5.3	4.6	3.5	3.5	5.1	6.1		
(40) Clear-Sky Solar Irradiance	taub		0.170	0.221	0.267	0.317	0.342	0.351	0.370	0.352	0.306	0.265	0.178	0.168		
	taud		1.855	2.101	2.129	2.021	2.069	2.233	2.314	2.378	2.366	2.147	1.914	1.883		
	Ebn at Noon		261	662	796	830	849	853	822	802	756	569	236	35		
	Edh at Noon		18	53	87	127	135	119	107	91	71	50	16	4		
(44) All-Sky Solar Radiation	RadAvg		0.09	0.72	2.48	4.78	6.17	6.20	5.61	3.94	2.25	0.88	0.16	0.01		
	RadStd		0.01	0.05	0.11	0.22	0.40	0.48	0.42	0.35	0.16	0.06	0.02	0.00		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	+1.80	+2.14	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (4 neighbors)	N/A	+1.56	+1.78	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page