

SCHEFFERVILLE, QC, Canada

WMO: 718280

Lat: 54.800N

Lon: 66.800W

Elev: 1697

StdP: 13.82

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -33.2	(c) -28.8	(d) -41.5	(e) 0.5	(f) -32.8	(g) -37.5	(h) 0.7	(i) -28.5	(j) 28.6	(k) -4.2	(l) 26.2	(m) -3.2	(n) 5.3	(o) 160	(p) 0.848

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.8	74.7	59.3	70.9	58.2	67.6	57.0	62.6	69.7	60.7	67.1	58.9	64.6	11.3	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
60.2	83.0	64.5	58.4	77.5	62.6	56.4	72.1	61.2	29.2	69.0	27.7	67.0	26.5	64.6	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 25.0	(b) 22.2	(c) 19.9	(e) -41.8	(f) 81.7	(g) 4.1	(h) 2.9	(i) -44.8	(j) 83.8	(k) -47.2	(l) 85.5	(m) -49.5	(n) 87.1	(o) -52.5	(p) 89.3		
(a) 25.0	(b) 22.2	(c) 19.9	(e) -41.8	(f) 66.6	(g) 4.1	(h) 2.7	(i) -44.8	(j) 68.6	(k) -47.1	(l) 70.2	(m) -49.4	(n) 71.7	(o) -52.4	(p) 73.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.4	-8.3	-7.0	4.9	20.4	36.6	49.1	56.0	54.4	44.5	32.6	17.6	1.8		
	DBStd	24.77	13.32	12.82	13.84	11.05	8.83	8.18	5.95	6.43	7.19	7.58	9.80	13.14		
	HDD50	9473	1807	1597	1399	888	425	113	15	27	196	540	973	1493		
	HDD65	14471	2272	2017	1864	1338	880	482	285	332	616	1004	1423	1958		
	CDD50	492	0	0	0	0	11	85	199	165	31	1	0	0		
	CDD65	15	0	0	0	0	0	4	5	5	1	0	0	0		
	CDH74	132	0	0	0	0	6	40	49	32	5	0	0	0		
	CDH80	11	0	0	0	0	0	6	4	1	0	0	0	0		
	WSAvg	9.5	9.5	9.4	10.0	10.3	9.1	9.4	8.7	8.7	10.1	10.0	10.0	9.4		
	PrecAvg	29.4	1.7	1.1	1.5	1.9	2.0	2.7	3.9	3.8	3.4	3.1	2.5	1.5		
(15) Precipitation	PrecMax	38.0	6.1	3.0	4.8	5.6	4.1	6.3	6.5	7.4	7.6	6.0	4.8	3.7		
	PrecMin	15.4	0.1	0.1	0.2	0.3	0.3	1.5	1.4	1.1	0.3	0.8	0.6	0.6		
	PrecStd	5.4	1.2	0.7	1.0	1.2	1.0	0.9	1.3	1.5	1.7	1.4	0.9	0.8		
	PrecStd	5.4	1.2	0.7	1.0	1.2	1.0	0.9	1.3	1.5	1.7	1.4	0.9	0.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.9	33.2	39.9	47.6	73.3	78.9	79.4	78.3	72.4	57.0	40.5	34.5		
		MCWB	32.2	32.1	34.2	37.8	54.9	59.9	60.5	61.4	60.9	50.5	38.7	33.4		
	2%	DB	26.0	27.2	34.6	43.0	62.9	72.4	74.3	72.9	64.5	51.0	36.5	31.3		
		MCWB	25.1	25.7	31.5	36.3	48.9	57.4	58.8	60.7	56.6	47.1	34.8	30.8		
	5%	DB	19.0	19.5	31.1	39.5	56.9	68.0	70.6	69.2	59.8	47.0	33.9	25.9		
		MCWB	18.2	18.2	28.7	34.6	46.0	55.4	58.1	58.7	54.2	44.1	32.5	24.9		
	10%	DB	12.9	13.3	26.7	36.6	51.5	63.8	67.2	65.5	55.7	43.5	31.4	21.1		
		MCWB	12.1	12.2	24.4	33.1	43.5	52.9	57.4	57.3	51.0	40.8	30.3	20.1		
	0.4%	WB	32.0	32.6	35.3	39.9	55.5	64.8	65.4	64.9	62.1	52.6	39.6	33.7		
		MCDB	32.8	33.2	38.5	44.2	70.2	74.3	69.9	71.3	69.4	55.1	40.3	34.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	25.1	25.7	32.0	37.0	50.6	60.3	62.1	62.6	58.5	48.0	35.2	30.6		
		MCDB	25.9	27.0	34.1	41.3	60.4	68.2	68.6	69.5	63.3	50.5	35.8	31.2		
	5%	WB	18.3	18.1	28.5	35.2	46.8	57.4	60.4	60.5	55.0	44.3	32.6	25.0		
		MCDB	19.0	19.2	31.2	39.1	55.2	64.6	66.1	67.2	58.8	46.6	33.6	25.7		
	10%	WB	12.1	12.3	24.5	33.3	44.0	54.5	58.9	58.6	51.5	41.0	30.2	20.2		
		MCDB	12.9	13.3	26.7	36.5	50.9	61.5	64.4	63.8	55.2	43.1	31.6	21.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.2	18.9	21.8	19.0	16.9	17.9	15.8	14.7	13.3	9.9	11.0	14.0		
		MCDBR	18.4	19.7	20.0	20.2	27.0	25.3	22.0	20.1	19.0	16.3	12.2	14.0		
		MCWBR	18.3	18.6	17.9	15.3	16.0	13.0	9.9	10.0	13.0	13.2	12.0	13.9		
		MCDBR	18.6	19.4	19.6	18.0	23.9	20.8	16.5	17.2	18.0	15.2	11.7	13.6		
	5% WB	MCWBR	18.4	18.5	17.9	14.3	15.2	12.5	9.6	10.0	14.4	13.3	11.8	13.6		
		MCWBR	18.4	18.5	17.9	14.3	15.2	12.5	9.6	10.0	14.4	13.3	11.8	13.6		
(40) Clear-Sky Solar Irradiance	taub		0.223	0.241	0.259	0.326	0.361	0.357	0.377	0.348	0.335	0.289	0.241	0.221		
	taud		2.224	2.252	2.234	2.086	2.188	2.407	2.369	2.463	2.462	2.490	2.262	2.146		
	Ebn at Noon		238	275	294	283	279	282	273	276	264	255	226	206		
	Edh at Noon		18	25	32	44	43	35	36	30	27	20	17	15		
(44) All-Sky Solar Radiation	RadAvg		287	631	1148	1589	1701	1606	1448	1174	844	461	219	187		
	RadStd		24	47	87	111	161	108	113	90	73	35	33	18		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page