

REVELSTOKE, BC, Canada

WMO: 718820

Lat: 50.9581N

Lon: 118.1765W

Elev: 1459

StdP: 13.94

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 3.2	(c) 8.2	(d) -5.0	(e) 4.4	(f) 6.6	(g) 0.6	(h) 6.0	(i) 10.3	(j) 28.6	(k) 25.5	(l) 25.2	(m) 24.6	(n) 4.1	(o) 0	(p) 0.561

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.8	87.2	64.2	83.3	62.6	79.7	61.3	66.6	81.3	64.7	78.3	63.1	75.4	5.1	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.8	87.1	70.2	60.2	82.0	68.1	58.7	77.8	66.4	32.0	81.8	30.5	78.1	29.3	75.8	75.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.8	17.5	14.0	-2.7	93.2	7.2	4.0	-7.9	96.1	-12.1	98.5	-16.1	100.7	-21.3	103.7		
			-3.3	70.6	7.1	2.4	-8.4	72.3	-12.6	73.7	-16.6	75.1	-21.8	76.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.5	26.4	28.3	35.6	45.2	55.1	61.0	66.5	65.0	56.2	44.3	34.6	27.1
	DBStd	15.69	8.78	7.43	5.82	5.16	5.90	5.26	5.63	5.21	5.26	5.07	6.23	7.97
	HDD50	3331	731	608	446	160	20	0	0	0	8	187	461	710
	HDD65	7292	1196	1028	910	593	310	142	51	66	269	641	911	1175
	CDD50	1703	0	0	0	17	178	331	510	464	193	10	0	0
	CDD65	191	0	0	0	0	3	23	96	65	4	0	0	0
	CDH74	2395	0	0	0	5	175	376	1044	726	69	0	0	0
	CDH80	740	0	0	0	0	31	101	377	220	11	0	0	0
Wind	WSAvg	3.9	3.6	3.6	4.0	4.5	4.8	4.4	4.0	3.5	3.1	3.1	4.0	4.2
Precipitation	PrecAvg	40.1	4.8	3.7	2.8	2.1	2.3	3.0	2.7	2.4	2.6	3.2	4.8	5.6
	PrecMax	50.6	10.3	7.2	5.9	4.6	4.3	4.8	6.0	6.0	6.0	6.9	9.1	10.2
	PrecMin	31.5	1.4	0.9	0.8	0.3	0.8	1.4	0.6	0.2	0.4	0.7	0.9	2.4
	PrecStd	5.0	2.4	1.7	1.2	1.1	0.9	1.1	1.5	1.5	1.5	1.7	2.1	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.8	42.6	57.1	72.7	83.9	88.4	93.5	90.4	80.6	63.1	48.7	41.0
		MCWB	36.8	37.6	44.7	53.6	59.6	63.5	65.9	65.3	61.6	51.9	45.5	38.4
	2%	DB	37.5	39.5	50.4	65.8	78.8	82.5	88.4	85.8	75.2	58.1	45.7	38.6
		MCWB	35.3	36.1	41.7	49.7	57.5	61.5	64.7	64.0	60.8	50.5	43.6	36.5
	5%	DB	35.9	37.5	46.3	61.1	74.5	78.3	84.2	81.7	70.8	54.7	43.9	37.0
		MCWB	34.4	35.0	39.8	47.2	55.0	59.6	63.4	62.8	58.4	49.2	42.2	35.2
	10%	DB	34.7	36.0	42.9	56.7	69.5	73.7	80.0	77.8	66.5	51.9	42.0	35.5
		MCWB	33.6	34.2	38.4	45.3	53.3	58.2	62.1	62.0	56.7	47.6	40.5	34.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.4	38.8	46.0	54.4	61.7	66.7	69.6	68.8	64.6	55.6	46.5	39.5
		MCDB	39.2	40.8	54.5	69.4	79.7	82.6	84.5	83.2	75.8	59.3	47.6	40.2
	2%	WB	35.8	36.9	42.9	51.0	58.6	63.4	66.9	66.4	61.9	52.9	44.2	37.2
		MCDB	36.9	38.3	48.6	63.2	74.1	77.7	82.2	80.4	71.3	56.0	45.2	38.0
	5%	WB	34.8	35.6	40.8	48.6	56.6	61.2	65.1	64.5	59.9	50.4	42.6	35.7
		MCDB	35.6	36.8	44.7	58.1	70.4	74.0	79.4	77.3	68.1	53.3	43.7	36.4
	10%	WB	33.9	34.5	38.8	46.5	54.7	59.3	63.4	62.9	57.9	48.2	40.6	34.2
		MCDB	34.4	35.5	42.1	54.7	66.8	70.1	76.3	74.3	64.6	51.0	41.6	35.0
Mean Daily Temperature Range	5% DB	MDBR	7.2	10.7	13.6	20.1	23.6	21.1	23.8	23.3	19.1	12.4	7.3	6.6
		MCDBR	6.0	10.2	19.4	29.6	34.5	31.6	32.1	31.0	27.0	17.6	8.7	6.1
		MCWBR	4.8	7.4	11.6	15.0	15.5	13.8	12.5	13.2	14.0	10.7	6.1	4.8
	5% WB	MCDBR	5.2	8.4	17.3	25.4	29.8	27.8	29.0	27.6	24.4	14.6	7.4	5.7
		MCWBR	4.3	6.3	11.0	13.8	14.0	12.9	12.6	12.9	13.4	9.7	5.5	4.9
Clear-Sky Solar Irradiance	taub	0.275	0.276	0.303	0.342	0.378	0.396	0.370	0.380	0.351	0.334	0.289	0.264	
	taud	2.248	2.286	2.235	2.194	2.276	2.309	2.427	2.395	2.456	2.445	2.344	2.250	
	Ebn at Noon	236	273	284	284	278	273	279	270	266	249	231	220	
	Edh at Noon	22	27	35	41	40	39	34	34	29	24	20	18	
All-Sky Solar Radiation	RadAvg	254	553	886	1370	1649	1684	1903	1643	1107	608	269	200	
	RadStd	30	64	109	121	154	166	168	110	113	84	37	28	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+139	N/A
(47) Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page