

BLUE RIVER, BC, Canada

WMO: 718830

Lat: 52.1290N

Lon: 119.2898W

Elev: 2240

StdP: 13.54

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-17.1	-8.8	-23.4	1.6	-16.4	-14.8	2.7	-6.1	18.0	13.1	14.9	14.7	0.4	0	0.600

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.9	87.4	61.5	83.2	60.6	78.9	59.2	64.4	80.0	62.6	77.5	60.9	74.5	5.1	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.8	83.3	66.9	57.9	77.9	64.7	56.3	73.4	63.1	30.7	79.8	29.3	77.8	28.0	74.4	81.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.6	10.9	8.5	DB	-26.0	92.9	9.3	3.3	-32.6	95.2	-38.1	97.2	-43.3	99.0	-50.0	101.4	(4)
(5)			WB	-26.2	69.4	9.2	3.1	-32.8	71.7	-38.2	73.5	-43.4	75.2	-50.0	77.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	40.5	20.3	23.1	32.2	40.4	50.1	56.8	62.0	60.5	51.8	39.9	29.1	19.2		
	DBStd	17.02	12.88	10.82	7.40	5.29	6.06	5.05	5.48	5.42	5.95	5.71	8.25	11.64		
	HDD50	4542	921	754	552	292	75	4	0	1	47	316	626	954		
	HDD65	8981	1386	1174	1017	738	463	252	125	157	396	778	1076	1419		
	CDD50	1094	0	0	0	3	78	207	374	328	101	3	0	0		
	CDD65	57	0	0	0	0	0	5	33	18	1	0	0	0		
	CDH74	2098	0	0	0	3	110	290	920	678	97	0	0	0		
	CDH80	716	0	0	0	0	15	82	362	236	21	0	0	0		
	WSAvg	1.7	1.2	1.5	1.9	2.1	2.4	2.1	2.0	1.7	1.4	1.2	1.4	1.2		
	PrecAvg	40.6	3.9	2.8	2.9	2.0	2.7	3.7	3.5	3.3	3.2	3.5	4.1	4.6		
(15) Precipitation	PrecMax	47.7	7.4	4.6	6.7	3.3	4.4	5.8	8.3	6.5	7.9	8.8	6.5	9.3		
	PrecMin	25.9	1.3	0.8	1.3	1.0	1.4	1.1	0.2	0.5	0.2	1.0	1.1	1.6		
	PrecStd	5.5	2.0	1.1	1.1	0.7	0.9	1.3	1.9	1.8	1.7	2.0	1.5	1.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.6	43.6	57.0	71.6	82.0	87.7	92.7	91.3	83.0	63.5	47.6	38.2		
		MCWB	36.6	37.0	43.0	51.5	56.6	60.7	63.7	63.3	60.6	52.8	43.9	34.9		
	2%	DB	35.6	39.5	50.2	63.8	77.1	81.4	88.5	86.3	76.3	56.1	42.9	34.4		
		MCWB	34.2	35.0	39.9	47.3	54.7	58.5	62.2	61.5	59.4	48.7	41.2	33.0		
	5%	DB	33.8	36.9	45.5	58.3	72.2	76.5	84.3	81.7	70.0	52.0	40.1	32.9		
		MCWB	33.0	33.9	37.9	44.5	52.8	56.9	61.3	60.8	56.6	47.3	38.7	32.3		
	10%	DB	32.6	34.6	42.0	53.3	67.0	71.8	79.1	76.9	64.5	48.6	37.3	32.0		
		MCWB	32.1	32.7	36.5	42.2	51.0	55.3	59.9	59.6	54.6	45.1	36.2	31.7		
	0.4%	WB	37.1	38.5	44.3	52.6	58.4	63.4	67.3	67.4	63.2	54.1	44.7	35.7		
		MCDB	38.6	41.5	53.6	66.9	75.3	79.6	83.7	81.8	76.5	60.0	46.1	37.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	34.5	36.1	41.2	48.9	56.3	60.7	64.7	64.5	60.2	51.1	41.5	33.3		
		MCDB	35.1	38.4	48.1	61.3	71.8	75.6	80.9	79.4	73.0	54.1	42.5	33.9		
	5%	WB	33.2	34.3	39.0	45.9	54.3	58.7	62.9	62.5	57.9	48.1	38.9	32.4		
		MCDB	33.7	36.0	44.0	55.4	68.2	71.6	78.5	76.7	67.8	51.1	40.0	32.7		
	10%	WB	32.3	32.9	37.0	43.5	52.4	57.0	61.2	60.7	55.6	45.4	36.3	31.8		
		MCDB	32.6	34.2	41.1	51.5	64.1	68.1	75.0	73.8	63.0	48.0	37.1	32.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.2	17.7	19.0	23.8	27.4	24.9	27.9	29.0	24.6	15.7	9.3	11.4		
		MCDBR	8.6	16.5	25.2	35.3	40.4	37.7	40.8	41.1	37.4	23.2	10.9	8.0		
		MCWBR	7.4	12.6	16.0	19.5	19.6	17.2	17.9	19.4	21.3	15.5	8.6	7.1		
		MCDBR	8.1	13.0	21.2	30.4	33.5	30.6	34.7	35.3	33.5	20.3	9.9	7.5		
	5% WB	MCWBR	7.1	10.1	14.1	17.8	17.0	14.8	16.4	18.1	19.6	14.3	8.3	6.7		
(40) Clear-Sky Solar Irradiance	taub		0.260	0.265	0.295	0.342	0.373	0.384	0.354	0.354	0.332	0.306	0.268	0.252		
	taud		2.269	2.297	2.232	2.133	2.256	2.323	2.454	2.453	2.506	2.523	2.369	2.245		
	Ebn at Noon		238	274	285	282	278	276	283	277	272	258	235	218		
	Edh at Noon		20	26	34	43	41	38	33	31	27	21	18	17		
(44) All-Sky Solar Radiation	RadAvg		232	510	805	1318	1606	1583	1722	1502	1006	530	237	183		
	RadStd		30	70	110	134	196	150	176	90	113	82	42	30		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page