

KAMLOOPS, BC, Canada

WMO: 718870

Lat: 50.6993N

Lon: 120.4406W

Elev: 345

StdP: 97.25

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.1	-14.6	-24.3	0.4	-16.6	-20.4	0.6	-13.7	12.4	-2.2	10.8	-2.2	3.3	90	0.557

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.0	34.2	17.9	32.1	17.4	30.0	16.7	18.9	31.1	18.1	29.6	17.3	28.0	3.1	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.0	11.1	21.0	13.9	10.3	20.5	12.9	9.7	20.3	55.0	31.3	52.2	29.8	49.7	28.3	22.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.2	9.0	8.0	-20.4	37.5	4.1	1.8	-23.3	38.8	-25.7	39.8	-28.1	40.8	-31.0	42.0		
(5)			-20.9	20.8	4.0	0.8	-23.7	21.4	-26.1	21.9	-28.3	22.4	-31.1	23.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.6	-2.3	-0.4	5.1	9.9	14.9	18.3	22.1	21.4	16.0	8.6	2.5	-2.0		
	DBStd	9.58	5.84	5.09	4.27	3.27	3.58	3.26	3.37	3.16	3.38	3.59	5.10	5.48		
	HDD10.0	1543	381	291	157	41	4	0	0	0	1	68	228	373		
	HDD18.3	3497	639	524	411	254	118	39	8	10	86	301	476	631		
	CDD10.0	1381	0	0	4	37	154	249	375	352	181	26	2	0		
	CDD18.3	293	0	0	0	0	10	38	125	104	16	0	0	0		
	CDH23.3	3374	0	0	0	12	184	464	1408	1118	187	1	0	0		
	CDH26.7	1394	0	0	0	1	48	171	651	473	50	0	0	0		
(14) Wind	WSAvg	3.1	3.2	3.0	3.5	3.4	3.0	2.9	2.7	2.6	2.6	3.1	3.5	3.4		
(15) Precipitation	PrecAvg	286	28	15	11	15	24	33	30	30	28	17	25	33		
	PrecMax	390	70	44	25	70	57	73	72	125	87	53	68	108		
	PrecMin	164	6	2	0	3	6	4	3	5	0	3	6	6		
	PrecStd	52	15	9	6	13	13	17	19	24	19	10	15	18		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.3	12.1	18.6	25.2	30.9	34.6	37.3	36.0	31.2	21.2	14.8	10.6		
		MCWB	5.0	6.4	9.8	13.1	15.9	17.7	18.9	18.3	17.1	13.3	8.9	6.0		
	2%	DB	6.8	9.3	15.4	21.2	27.7	31.1	34.9	33.5	27.9	18.1	12.1	7.6		
		MCWB	3.8	4.9	7.9	11.2	14.6	16.4	18.2	17.9	16.3	11.6	7.8	4.3		
	5%	DB	5.2	7.4	13.4	18.9	25.2	28.2	32.7	31.5	25.3	16.2	10.3	5.8		
		MCWB	3.0	3.8	6.8	9.9	13.5	15.4	17.7	17.4	15.2	10.4	6.6	3.1		
	10%	DB	3.8	5.7	11.6	16.7	22.7	25.8	30.4	29.3	22.9	14.4	8.7	4.1		
		MCWB	2.1	3.0	5.9	8.7	12.6	14.7	16.9	16.7	14.1	9.5	5.8	2.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.5	7.2	10.0	13.4	16.6	18.5	20.2	20.0	18.1	14.2	9.9	6.5		
		MCDB	8.7	11.1	17.7	23.0	28.1	31.1	34.2	32.1	27.5	19.5	13.4	9.8		
	2%	WB	4.1	5.4	8.5	11.9	15.2	17.2	19.1	18.8	16.9	12.5	8.3	4.7		
		MCDB	6.3	8.4	14.4	20.1	25.4	28.8	31.9	30.8	26.0	17.0	11.1	7.2		
	5%	WB	3.1	4.3	7.4	10.5	14.2	16.2	18.2	18.0	15.8	11.1	7.1	3.3		
		MCDB	4.9	6.9	12.6	17.5	23.3	26.1	30.2	29.4	24.2	15.2	9.7	5.5		
	10%	WB	2.2	3.1	6.2	9.3	13.2	15.2	17.4	17.2	14.7	9.8	6.0	2.1		
		MCDB	3.6	5.5	10.9	15.7	21.3	24.0	28.6	27.6	21.6	13.6	8.4	3.9		
(35) Mean Daily Temperature Range	MDBR		5.2	7.3	10.1	12.1	12.7	12.5	14.0	14.1	12.6	9.2	6.0	5.1		
	5% DB	MCDBR	6.2	8.6	12.9	15.9	17.6	17.1	18.1	18.2	16.7	11.6	7.6	6.6		
		MCWBR	4.3	5.4	7.1	8.0	7.4	6.3	6.2	6.9	7.6	6.4	4.8	4.4		
	5% WB	MCDBR	5.8	8.0	12.2	14.4	15.5	15.1	16.3	16.6	15.4	10.6	6.9	6.3		
		MCWBR	4.1	5.2	7.0	7.4	6.8	5.9	6.1	6.5	7.2	6.1	4.6	4.4		
(40) Clear-Sky Solar Irradiance	taub		0.302	0.298	0.334	0.370	0.393	0.388	0.370	0.383	0.354	0.338	0.313	0.291		
	taud		2.304	2.406	2.382	2.313	2.291	2.340	2.418	2.385	2.447	2.458	2.413	2.349		
	Ebn at Noon		718	843	869	870	863	869	880	849	838	783	708	677		
	Edh at Noon		67	78	97	116	125	120	109	107	91	75	61	56		
(44) All-Sky Solar Radiation	RadAvg		0.97	1.93	3.17	4.54	5.44	5.89	6.42	5.47	3.81	2.21	1.05	0.74		
	RadStd		0.09	0.15	0.21	0.38	0.43	0.51	0.50	0.32	0.32	0.22	0.11	0.08		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (21 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page