

COMOX, BC, Canada

WMO: 718930

Lat: 49.720N

Lon: 124.900W

Elev: 84

StdP: 14.65

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	24.3	27.6	11.8	10.1	28.3	17.5	13.3	31.7	38.8	42.5	35.7	43.1	6.0	290	0.566

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.6	80.8	64.1	77.3	63.0	74.1	61.8	65.5	77.5	64.1	74.6	62.8	72.0	7.3	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.1	80.7	68.7	59.9	77.2	67.5	58.7	74.0	66.6	30.4	78.0	29.3	75.0	28.4	72.2	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.8	25.5	21.7	20.0	87.8	3.6	3.5	17.5	90.4	15.4	92.4	13.4	94.4	10.8	97.0		
(5)			18.2	68.6	3.9	2.3	15.4	70.3	13.1	71.6	10.9	72.9	8.1	74.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.4	39.3	39.4	42.9	47.9	54.9	60.1	65.2	64.8	58.5	49.3	42.7	38.6		
	DBStd	10.70	5.53	4.71	4.33	4.19	5.01	4.69	4.25	4.01	4.13	4.08	5.30	5.15		
	HDD50	1593	333	298	223	87	13	0	0	0	0	63	223	353		
	HDD65	5465	797	718	686	512	314	161	49	53	200	488	669	818		
	CDD50	1726	1	0	2	25	165	305	470	460	255	39	4	0		
	CDD65	120	0	0	0	0	1	15	53	47	4	0	0	0		
	CDH74	746	0	0	0	1	18	125	313	260	29	0	0	0		
	CDH80	146	0	0	0	0	1	29	69	43	4	0	0	0		
(14) Wind	WSAvg	7.8	8.2	7.5	8.8	8.1	7.4	7.5	7.7	6.9	6.7	7.6	8.7	8.8		
(15) Precipitation	PrecAvg	53.6	8.3	5.2	5.1	3.0	1.8	1.7	1.0	1.4	2.1	5.9	8.5	9.5		
	PrecMax	71.2	17.1	16.1	10.0	7.0	4.4	3.9	1.9	5.9	7.8	13.9	17.6	14.7		
	PrecMin	33.7	3.3	0.0	0.9	0.6	0.2	0.5	0.1	0.0	0.0	0.2	2.4	4.4		
	PrecStd	9.4	3.3	3.5	2.4	1.8	1.1	0.9	0.5	1.2	1.8	3.4	4.3	2.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.1	52.1	58.4	67.6	76.6	84.1	87.1	84.5	77.8	63.6	55.7	52.2		
		MCWB	49.3	47.4	49.8	53.4	59.6	63.7	67.5	64.9	63.0	55.8	51.8	49.3		
	2%	DB	50.0	49.4	53.8	61.9	71.2	77.4	80.8	80.1	72.5	59.8	53.3	48.8		
		MCWB	47.8	46.2	47.8	51.5	57.7	61.5	65.3	64.0	60.5	53.9	50.8	47.0		
	5%	DB	48.0	47.6	51.3	58.0	67.2	72.2	77.1	76.7	69.2	57.6	51.6	47.3		
		MCWB	46.5	44.9	46.5	50.1	56.5	60.2	63.5	63.1	59.6	53.1	49.8	45.6		
	10%	DB	46.6	46.1	49.5	55.2	63.8	68.3	73.8	73.3	66.3	55.6	50.2	45.9		
		MCWB	45.2	43.8	45.7	48.7	55.1	58.4	62.1	62.0	58.1	52.2	48.5	44.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.3	49.5	51.3	56.2	61.0	65.0	69.0	67.0	64.1	58.4	53.4	50.0		
		MCDB	51.9	50.6	55.5	64.9	71.9	78.3	82.8	79.5	73.6	61.4	54.7	51.1		
	2%	WB	48.2	47.1	49.2	53.2	59.1	62.7	65.9	65.4	62.2	55.8	51.5	47.6		
		MCDB	49.4	48.3	52.3	59.6	68.1	74.0	78.8	76.6	69.8	57.7	52.5	48.4		
	5%	WB	46.8	45.5	47.8	51.2	57.5	60.9	64.3	64.1	60.7	54.2	50.2	45.9		
		MCDB	47.8	46.9	50.3	56.4	65.2	70.2	75.3	74.0	66.9	56.2	51.3	46.8		
	10%	WB	45.3	44.4	46.5	49.7	56.0	59.4	62.8	62.9	59.2	52.7	48.7	44.6		
		MCDB	46.3	45.8	49.0	53.8	62.5	67.1	72.2	71.6	64.6	54.8	49.9	45.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.5	9.7	11.1	12.9	14.1	13.8	15.6	15.5	13.8	10.5	8.8	7.8		
		MCDBR	8.0	10.4	13.4	18.1	20.7	20.9	21.7	21.5	19.2	13.4	8.4	8.3		
	5% WB	MCWBR	6.3	7.9	9.0	10.7	11.2	10.1	10.1	9.9	9.9	8.8	6.8	7.0		
		MCWBR	7.3	8.4	11.3	15.4	17.8	17.7	19.9	18.4	16.4	10.1	7.6	7.9		
(40) Clear-Sky Solar Irradiance	taub		0.323	0.319	0.342	0.367	0.388	0.376	0.380	0.383	0.349	0.353	0.327	0.320		
		taud	2.425	2.519	2.461	2.390	2.352	2.421	2.443	2.436	2.534	2.455	2.455	2.387		
	Ebn at Noon		229	265	276	279	276	280	277	271	271	246	225	210		
		Edh at Noon	20	23	29	35	37	35	34	33	27	24	19	18		
(44) All-Sky Solar Radiation	RadAvg		256	536	797	1244	1626	1753	1929	1657	1156	619	304	200		
	RadStd		37	88	109	127	178	198	203	139	102	104	57	30		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+124	+25
(47) Regional (50 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page