

COMOX, BC, Canada

WMO: 718930

Lat: 49.720N

Lon: 124.900W

Elev: 26

StdP: 101.02

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-4.3	-2.5	-11.2	1.4	-2.1	-8.0	1.9	-0.2	17.4	5.8	16.0	6.2	2.7	290	0.566

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.7	27.1	17.8	25.2	17.2	23.4	16.5	18.6	25.3	17.8	23.7	17.1	22.2	3.3	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.2	11.5	20.4	15.5	11.0	19.7	14.9	10.6	19.2	52.7	25.5	50.2	23.9	48.1	22.4	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.3	11.4	9.7	DB	-6.6	31.0	2.0	2.0	-8.1	32.4	-9.2	33.6	-10.3	34.7	-11.8	36.1	(4)
(5)			WB	-7.7	20.3	2.2	1.3	-9.2	21.3	-10.5	22.0	-11.7	22.7	-13.3	23.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.2	4.0	4.1	6.0	8.8	12.7	15.6	18.4	18.2	14.7	9.6	5.9	3.7
	DBStd	5.95	3.07	2.62	2.40	2.33	2.79	2.61	2.36	2.23	2.30	2.27	2.95	2.86
	HDD10.0	885	185	166	124	48	7	0	0	0	0	35	124	196
	HDD18.3	3036	443	399	381	284	174	89	27	29	111	271	372	454
	CDD10.0	959	1	0	1	14	92	169	261	256	142	22	2	0
	CDD18.3	67	0	0	0	0	1	8	29	26	2	0	0	0
	CDH23.3	414	0	0	0	1	10	69	174	144	16	0	0	0
	CDH26.7	81	0	0	0	0	1	16	38	24	2	0	0	0
Wind	WSAvg	3.5	3.6	3.3	3.9	3.6	3.3	3.3	3.5	3.1	3.0	3.4	3.9	3.9
Precipitation	PrecAvg	1362	211	133	130	76	45	44	26	35	54	150	217	241
	PrecMax	1808	435	410	255	179	111	99	48	149	197	352	447	374
	PrecMin	855	85	1	23	14	6	12	2	1	0	5	61	111
	PrecStd	239	85	88	60	45	27	24	13	31	45	86	109	74
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.7	11.1	14.6	19.8	24.8	28.9	30.6	29.2	25.5	17.6	13.2	11.2
		MCWB	9.6	8.5	9.9	11.9	15.3	17.6	19.7	18.3	17.2	13.2	11.0	9.6
	2%	DB	10.0	9.6	12.1	16.6	21.8	25.2	27.1	26.7	22.5	15.4	11.8	9.4
		MCWB	8.8	7.9	8.8	10.8	14.3	16.4	18.5	17.8	15.9	12.2	10.4	8.3
	5%	DB	8.9	8.6	10.7	14.4	19.6	22.3	25.1	24.8	20.7	14.2	10.9	8.5
		MCWB	8.0	7.2	8.1	10.1	13.6	15.7	17.5	17.3	15.3	11.7	9.9	7.6
	10%	DB	8.1	7.8	9.7	12.9	17.6	20.2	23.2	23.0	19.0	13.1	10.1	7.7
		MCWB	7.3	6.6	7.6	9.3	12.8	14.7	16.7	16.7	14.5	11.2	9.2	6.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.2	9.7	10.7	13.5	16.1	18.3	20.5	19.4	17.8	14.7	11.9	10.0
		MCDB	11.1	10.3	13.0	18.3	22.1	25.7	28.2	26.4	23.1	16.3	12.6	10.6
	2%	WB	9.0	8.4	9.6	11.8	15.0	17.1	18.8	18.5	16.8	13.2	10.8	8.7
		MCDB	9.6	9.1	11.3	15.3	20.1	23.3	26.0	24.8	21.0	14.3	11.4	9.1
	5%	WB	8.2	7.5	8.8	10.7	14.2	16.1	18.0	17.8	15.9	12.3	10.1	7.7
		MCDB	8.8	8.3	10.1	13.5	18.4	21.2	24.1	23.4	19.4	13.4	10.7	8.2
	10%	WB	7.4	6.9	8.1	9.8	13.3	15.2	17.1	17.1	15.1	11.5	9.3	7.0
		MCDB	8.0	7.7	9.4	12.1	17.0	19.5	22.3	22.0	18.1	12.7	10.0	7.7
Mean Daily Temperature Range	5% DB	MDBR	4.2	5.4	6.2	7.2	7.8	7.7	8.7	8.6	7.7	5.8	4.9	4.3
		MCDBR	4.4	5.8	7.4	10.0	11.5	11.6	12.0	12.0	10.7	7.4	4.7	4.6
		MCWBR	3.5	4.4	5.0	6.0	6.2	5.6	5.6	5.5	5.5	4.9	3.8	3.9
	5% WB	MCDBR	4.0	4.7	6.3	8.6	9.9	9.8	11.1	10.2	9.1	5.6	4.2	4.4
		MCWBR	3.3	3.8	4.6	5.4	5.7	5.1	5.5	5.1	5.0	4.1	3.5	3.8
Clear-Sky Solar Irradiance	taub	0.323	0.319	0.342	0.367	0.388	0.376	0.380	0.383	0.349	0.353	0.327	0.320	
	taud	2.425	2.519	2.461	2.390	2.352	2.421	2.443	2.436	2.534	2.455	2.455	2.387	
	Ebn at Noon	721	835	869	879	871	883	874	853	853	774	710	662	
	Edh at Noon	64	73	91	109	118	111	107	103	85	77	61	58	
All-Sky Solar Radiation	RadAvg	0.81	1.69	2.51	3.92	5.13	5.53	6.08	5.22	3.65	1.95	0.96	0.63	
	RadStd	0.12	0.28	0.34	0.40	0.56	0.62	0.64	0.44	0.32	0.33	0.18	0.10	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+69	+14
(47) Regional (50 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page