

PRINCE GEORGE, BC, Canada

WMO: 718960

Lat: 53.8890N

Lon: 122.6719W

Elev: 691

StdP: 93.29

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-28.6	-24.5	-32.8	0.2	-28.2	-28.7	0.3	-24.2	11.3	1.9	10.2	1.5	1.1	0	0.642

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.6	27.9	16.2	25.8	15.4	23.9	14.5	17.2	25.5	16.2	23.8	15.3	22.3	2.7	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.1	10.9	19.2	13.2	10.3	18.1	12.3	9.7	17.4	50.9	25.8	47.7	23.9	45.0	22.5	20.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.6	8.4	7.4	-32.3	30.9	4.7	2.1	-35.7	32.4	-38.4	33.6	-41.1	34.7	-44.5	36.2		
(5)			-32.4	18.9	4.7	1.0	-35.8	19.6	-38.5	20.2	-41.2	20.7	-44.6	21.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	4.4	-7.4	-5.5	-0.7	4.8	10.1	13.7	15.8	15.0	10.4	4.4	-2.1	-6.9	(6)
(7)		DBStd	9.81	8.57	7.02	5.81	3.58	3.58	2.92	2.84	3.01	3.45	3.87	5.86	7.40	(7)
(8)		HDD10.0	2614	539	434	332	161	43	3	0	1	37	177	363	524	(8)
(9)		HDD18.3	5123	797	667	590	407	255	143	88	109	239	432	613	782	(9)
(10)		CDD10.0	554	0	0	0	4	47	113	181	157	48	4	0	0	(10)
(11)		CDD18.3	20	0	0	0	0	0	3	11	7	0	0	0	0	(11)
(12)		CDH23.3	530	0	0	0	1	22	80	233	174	19	0	0	0	(12)
(13)		CDH26.7	114	0	0	0	0	2	13	63	35	2	0	0	0	(13)
(14)	Wind	WSAvg	2.8	3.0	2.8	3.3	3.1	2.8	2.6	2.3	2.2	2.4	3.0	3.3	3.2	(14)
(15)	Precipitation	PrecAvg	658	61	36	38	30	56	69	66	60	64	56	58		(15)
(16)		PrecMax	901	161	83	68	65	111	148	134	136	128	105	137		(16)
(17)		PrecMin	469	14	8	9	12	8	14	20	11	9	21	3	21	(17)
(18)		PrecStd	105	33	19	16	13	23	35	34	30	29	30	24	28	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.2	7.8	13.4	20.9	25.9	28.6	31.4	29.6	25.7	18.2	12.3	7.0	(19)
MCWB			3.9	3.2	6.4	10.9	13.7	15.9	17.4	17.1	15.3	11.5	7.1	2.9	(20)	
2%		DB	5.6	5.8	10.2	16.9	23.1	25.5	28.4	27.5	22.8	15.0	8.7	5.0	(21)	
		MCWB	2.8	2.4	4.6	8.6	12.2	14.8	16.5	16.3	14.3	9.5	5.6	2.0	(22)	
5%		DB	4.0	4.1	8.4	14.1	20.8	23.4	25.9	25.2	20.0	12.3	6.2	3.4	(23)	
		MCWB	1.9	1.4	3.7	6.8	11.3	13.8	15.7	15.6	13.1	8.1	3.8	1.4	(24)	
10%		DB	2.4	2.7	6.6	11.8	18.6	21.1	23.6	23.0	17.4	10.5	4.6	1.9	(25)	
		MCWB	1.0	0.6	2.7	5.6	10.5	12.8	14.8	14.7	11.6	7.0	2.7	0.5	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.3	4.1	7.0	11.1	14.6	17.0	18.6	16.1	12.2	7.6	4.0	(27)	
MCDWB			6.4	6.4	11.7	19.3	24.1	25.2	28.3	26.7	23.3	16.2	10.9	5.6	(28)	
2%		WB	3.1	2.8	5.3	9.1	13.1	15.6	17.4	17.2	14.8	10.4	5.9	2.3	(29)	
		MCDWB	5.2	5.2	9.0	15.7	20.7	23.6	26.2	25.2	21.7	13.8	8.3	4.1	(30)	
5%		WB	2.0	1.7	4.2	7.5	12.1	14.5	16.3	16.1	13.6	8.7	4.3	1.5	(31)	
		MCDWB	3.6	3.7	7.7	13.0	19.2	21.5	24.0	23.6	18.9	11.5	5.9	3.2	(32)	
10%		WB	1.0	0.8	3.0	6.2	11.0	13.5	15.3	15.1	12.3	7.3	2.9	0.5	(33)	
		MCDWB	2.3	2.4	6.3	10.7	17.5	19.7	22.2	21.8	16.5	9.9	4.2	1.9	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.8	8.7	9.9	11.4	12.8	12.1	12.6	13.3	12.1	9.1	6.3	6.7	(35)
MCDBR			6.7	8.7	11.7	15.7	17.6	16.7	17.9	17.6	16.9	12.5	7.8	6.9	(36)	
MCWBR			4.9	6.1	7.3	8.7	8.6	7.7	7.9	8.1	9.2	7.9	5.5	5.2	(37)	
5% WB		MCDWR	6.0	7.9	10.7	13.9	15.2	14.4	15.6	16.0	15.6	11.3	7.5	6.5	(38)	
		MCWBR	4.7	5.7	7.0	8.1	7.7	6.9	7.3	7.9	8.7	7.5	5.6	5.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.259	0.272	0.287	0.319	0.347	0.353	0.345	0.349	0.310	0.294	0.278	0.248	(40)	
taud		2.317	2.342	2.386	2.439	2.421	2.420	2.482	2.462	2.582	2.594	2.438	2.312	(41)		
Ebn at Noon		723	839	904	915	900	896	897	873	875	817	702	662	(42)		
Edh at Noon		56	76	91	99	107	108	100	97	75	60	50	45	(43)		
(44)	All-Sky Solar Radiation	RadAvg	0.74	1.67	3.06	4.63	5.43	5.93	5.74	4.92	3.26	1.79	0.79	0.55	(44)	
(45)		RadStd	0.08	0.21	0.26	0.29	0.38	0.45	0.55	0.24	0.27	0.17	0.09	0.06	(45)	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+58	N/A

Nomenclature: See separate page