

MCINNES ISLAND, BC, Canada

WMO: 718970

Lat: 52.262N

Lon: 128.719W

Elev: 85

StdP: 14.65

Time Zone: -8.00 (NAP)

Period: 82-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	24.5	28.8	9.5	9.0	26.4	16.5	12.7	30.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.6	63.9	59.2	62.4	58.2	61.0	57.5	60.0	62.7	58.9	61.3	58.1	60.3	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
58.5	73.5	61.0	57.6	71.1	60.1	56.9	69.2	59.4	26.4	63.0	25.7	61.5	25.1	60.5	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) N/A	N/A	N/A	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.8	40.7	40.7	42.8	44.7	49.1	54.0	56.7	57.5	54.9	49.5	42.6	39.4
	DBStd	7.33	4.43	4.14	3.45	2.70	2.75	2.54	2.63	2.15	2.51	3.55	4.41	4.94
	HDD50	1583	289	259	225	161	50	0	1	0	1	45	222	330
	HDD65	6297	754	679	690	609	494	332	258	232	303	480	671	795
	CDD50	762	0	0	0	2	21	119	208	233	148	30	1	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	2	0	0	0	0	0	2	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Precipitation	PrecAvg	109.2	13.3	9.7	9.3	7.8	6.1	5.0	4.1	5.6	8.4	14.0	13.3	11.6
	PrecMax	142.3	27.5	18.9	19.8	15.0	12.1	10.3	8.8	19.4	12.8	21.8	21.4	19.6
	PrecMin	93.0	4.6	1.6	1.1	2.7	2.0	0.5	0.5	0.8	2.1	7.0	4.2	5.5
	PrecStd	12.6	5.5	3.8	3.5	3.3	2.8	2.5	2.4	4.2	2.8	3.7	4.5	3.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.7	48.6	52.7	56.6	60.5	67.2	65.6	66.1	64.3	58.5	53.3	49.3
		MCWB	47.5	44.8	47.0	46.7	53.7	56.1	60.3	61.2	58.6	53.1	50.8	47.4
	2%	DB	47.7	47.1	49.8	52.1	56.8	61.8	63.5	63.8	61.5	55.9	51.3	47.3
		MCWB	46.4	44.5	45.9	47.4	52.3	56.5	59.2	59.7	57.0	53.0	49.6	45.7
	5%	DB	46.6	46.2	48.2	50.1	55.0	59.6	62.0	62.3	59.8	54.7	49.8	46.1
		MCWB	45.3	44.0	44.9	46.1	51.3	55.7	58.1	58.7	56.3	52.4	48.1	44.6
	10%	DB	45.5	45.3	46.8	48.6	53.5	58.0	60.6	61.0	58.5	53.5	48.5	44.9
		MCWB	44.2	43.3	44.1	45.1	50.0	54.6	57.3	57.9	55.7	51.5	46.7	43.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.2	46.6	48.3	49.9	55.0	58.6	61.2	62.2	60.0	55.7	51.8	47.9
		MCDB	48.3	47.2	50.3	52.4	58.3	61.6	64.7	64.8	63.2	56.6	52.4	49.0
	2%	WB	46.8	45.6	46.8	48.2	52.9	57.4	59.6	60.3	58.3	54.1	50.0	46.2
		MCDB	47.2	46.3	48.6	51.0	55.7	60.3	62.6	62.6	60.4	55.1	51.2	46.9
	5%	WB	45.6	44.7	45.7	46.8	51.6	56.2	58.6	59.3	57.3	52.9	48.4	45.0
		MCDB	46.2	45.7	47.3	49.0	54.3	59.0	61.1	61.4	59.0	54.0	49.7	45.8
	10%	WB	44.5	43.8	44.7	45.8	50.5	54.8	57.8	58.3	56.4	51.9	47.0	43.7
		MCDB	45.2	45.0	46.3	47.9	53.1	57.3	60.1	60.4	58.0	53.1	48.4	44.7
Mean Daily Temperature Range	5% DB	MDBR	4.7	5.0	5.9	6.4	6.8	6.5	6.9	6.6	5.6	5.0	4.8	4.9
		MCDBR	4.8	5.6	8.0	9.1	9.7	9.2	8.8	8.5	7.3	6.9	5.4	6.0
		MCWBR	4.6	4.7	5.9	6.3	7.0	6.1	5.4	5.9	5.3	5.3	5.1	5.7
	5% WB	MCDBR	4.6	5.1	6.9	7.7	8.7	8.1	7.6	7.8	6.4	6.2	5.1	5.8
		MCWBR	4.8	4.6	5.4	5.9	6.7	5.9	5.1	5.9	5.3	5.6	5.2	5.8
Clear-Sky Solar Irradiance	taub	0.314	0.319	0.347	0.372	0.378	0.371	0.362	0.365	0.356	0.340	0.319	0.304	
	taud	2.424	2.514	2.436	2.371	2.398	2.459	2.525	2.528	2.531	2.504	2.419	2.387	
	Ebn at Noon	219	257	269	274	278	280	281	274	263	244	213	200	
	Edh at Noon	18	22	29	35	35	33	31	29	26	22	18	16	
All-Sky Solar Radiation	RadAvg	194	467	775	1231	1586	1664	1602	1375	948	522	244	162	
	RadStd	26	86	110	87	164	158	207	155	105	81	37	27	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (13 neighbors)	N/A	N/A	N/A	+0.76	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page