

KUUIJUARAPIK, QC, Canada

WMO: 719050

Lat: 55.282N

Lon: 77.765W

Elev: 12

StdP: 101.18

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-35.7	-33.1	-40.2	0.1	-35.7	-37.6	0.1	-33.0	12.8	-16.8	11.7	-17.5	3.4	130	0.877

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.1	25.5	16.8	22.8	15.8	20.4	14.9	18.3	22.9	17.0	21.0	15.6	19.7	5.8	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.6	11.8	20.2	15.2	10.8	19.1	13.7	9.8	17.5	52.1	23.1	47.9	21.0	44.0	19.7	27.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.7	11.1	9.9	-40.0	29.9	2.9	2.2	-42.1	31.5	-43.8	32.8	-45.5	34.0	-47.6	35.6		
(5)			-40.1	20.8	2.9	1.9	-42.2	22.1	-43.9	23.2	-45.5	24.3	-47.6	25.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-2.8	-21.2	-22.0	-15.6	-6.8	2.1	7.8	11.8	12.5	8.7	3.6	-3.6	-12.5
	DBStd	13.36	7.12	6.97	8.36	6.83	5.99	5.62	4.62	4.08	3.72	3.68	4.25	7.07
	HDD10.0	4954	966	897	794	503	261	111	31	16	69	202	407	698
	HDD18.3	7743	1224	1130	1053	753	505	321	209	188	291	456	657	957
	CDD10.0	272	0	0	0	0	14	43	88	93	30	3	0	0
	CDD18.3	20	0	0	0	0	1	3	8	8	1	0	0	0
	CDH23.3	181	0	0	0	0	17	38	66	57	3	0	0	0
	CDH26.7	38	0	0	0	0	5	7	16	10	0	0	0	0
Wind	WSAvg	4.8	4.7	4.3	4.3	4.5	4.3	4.2	4.0	4.5	5.4	5.4	5.7	5.6
Precipitation	PrecAvg	662	25	20	25	21	38	61	82	86	112	82	64	48
	PrecMax	769	57	43	64	36	70	136	157	187	172	135	99	83
	PrecMin	570	11	8	6	7	9	12	28	30	56	46	41	17
	PrecStd	53	13	10	14	8	19	33	39	37	32	24	18	19
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.1	0.2	6.4	12.1	25.8	27.9	28.3	27.8	23.0	17.1	7.7	2.0
		MCWB	-0.3	-0.8	2.6	6.1	14.9	17.4	17.6	18.5	17.1	12.9	6.3	1.1
	2%	DB	-4.3	-4.3	3.3	8.0	19.7	23.5	25.0	24.7	19.7	13.8	4.5	0.1
		MCWB	-5.0	-5.2	1.3	4.0	11.8	15.4	16.7	17.2	15.2	11.5	3.2	-0.4
	5%	DB	-7.1	-7.3	0.4	5.6	15.5	20.4	22.3	21.8	17.1	11.1	2.9	-1.5
		MCWB	-7.6	-8.1	-1.0	2.5	9.5	13.8	15.7	16.3	13.5	8.7	2.1	-2.1
	10%	DB	-10.6	-11.1	-2.7	3.1	11.7	17.6	19.6	19.4	14.7	8.9	1.7	-3.0
		MCWB	-11.1	-11.8	-3.9	1.0	7.1	12.1	14.9	15.3	12.0	7.1	0.8	-3.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.1	-0.6	3.2	6.7	15.3	19.7	19.9	19.9	18.1	13.7	6.5	1.2
		MCDB	0.1	0.3	5.6	10.8	25.0	24.5	25.0	24.9	21.5	16.0	7.3	1.7
	2%	WB	-4.9	-5.2	1.4	4.5	12.2	16.8	17.8	18.4	15.8	11.5	3.5	-0.4
		MCDB	-4.5	-4.4	3.2	7.5	18.3	22.1	22.0	23.2	19.0	13.4	4.2	0.0
	5%	WB	-7.6	-8.1	-1.0	2.8	9.8	14.4	16.6	17.0	13.9	9.1	2.1	-2.0
		MCDB	-7.2	-7.4	0.4	5.1	15.1	19.5	20.9	20.6	16.3	10.9	2.8	-1.5
	10%	WB	-11.1	-11.8	-4.0	1.0	7.2	12.3	15.3	15.5	12.0	7.1	0.9	-3.7
		MCDB	-10.6	-11.1	-2.7	3.0	11.5	17.4	19.5	19.1	14.7	8.7	1.6	-3.0
Mean Daily Temperature Range	5% DB	MDBR	7.6	9.5	10.2	8.9	8.2	9.4	8.7	7.1	6.1	4.9	4.7	6.1
		MCDBR	8.5	11.2	11.4	11.6	15.3	14.9	13.5	12.0	10.9	8.5	4.7	5.5
		MCWBR	8.5	10.9	10.0	8.3	9.0	8.5	7.5	6.3	7.4	6.5	4.4	5.5
	5% WB	MCDBR	8.6	11.2	11.1	10.4	14.9	14.3	11.9	10.5	10.1	8.0	4.7	5.5
		MCWBR	8.6	10.9	9.9	7.8	9.2	9.6	7.8	6.4	7.7	6.8	4.5	5.6
Clear-Sky Solar Irradiance	taub	0.222	0.247	0.284	0.295	0.318	0.342	0.356	0.364	0.351	0.320	0.281	0.214	
	taud	2.203	2.201	2.141	2.164	2.285	2.420	2.487	2.461	2.468	2.472	2.260	2.221	
	Ebn at Noon	739	845	885	928	924	903	883	852	813	754	635	664	
	Edh at Noon	55	82	112	127	121	107	99	96	83	65	54	43	
All-Sky Solar Radiation	RadAvg	0.79	1.80	3.29	4.80	5.45	5.66	5.09	3.92	2.48	1.36	0.56	0.45	
	RadStd	0.09	0.16	0.35	0.44	0.47	0.58	0.45	0.26	0.25	0.11	0.07	0.06	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	+1.26	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	+1.16	-0.72	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page