

KUUIJUAQ, QC, Canada

WMO: 719060

Lat: 58.0987N

Lon: 68.4175W

Elev: 40

StdP: 100.85

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-35.7	-33.9	-40.4	0.1	-35.4	-38.9	0.1	-33.6	15.0	-12.7	12.7	-16.5	2.2	220	0.842

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.1	24.2	16.1	21.9	15.1	19.6	14.0	17.5	22.2	16.1	20.5	14.7	18.9	4.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.7	11.2	19.4	14.0	10.0	18.0	12.4	9.0	16.8	49.6	22.3	45.3	20.6	41.3	19.0	22.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.9	9.4	8.2	DB	-39.0	28.6	1.9	1.8	-40.3	29.9	-41.4	31.0	-42.5	32.0	-43.9	33.3	(4)
(5)			WB	-39.1	19.7	1.9	1.4	-40.4	20.7	-41.5	21.5	-42.5	22.3	-43.9	23.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-4.1	-23.0	-22.6	-16.6	-7.7	1.6	8.1	12.6	11.9	6.8	1.1	-6.7	-15.7	(6)	
	DBStd	13.66	7.36	6.74	7.54	6.46	4.99	4.30	3.78	3.65	3.60	3.65	4.97	7.58	(7)	
	HDD10.0	5361	1023	912	824	531	266	87	16	20	109	277	501	796	(8)	
	HDD18.3	8186	1281	1146	1082	781	520	307	183	201	345	534	751	1054	(9)	
	CDD10.0	225	0	0	0	0	4	30	96	80	14	1	0	0	(10)	
	CDD18.3	8	0	0	0	0	0	1	4	3	0	0	0	0	(11)	
	CDH23.3	107	0	0	0	0	2	17	57	31	1	0	0	0	(12)	
	CDH26.7	17	0	0	0	0	0	3	9	4	0	0	0	0	(13)	
(14) Wind	WSAvg	3.8	3.8	3.9	4.2	4.2	3.9	3.9	3.4	3.3	3.7	3.9	4.0	3.8	(14)	
(15) Precipitation	PrecAvg	573	31	28	31	28	29	54	72	76	84	59	47	35	(15)	
	PrecMax	748	56	90	76	55	62	102	135	146	151	99	82	111	(16)	
	PrecMin	445	11	4	6	4	2	12	19	31	26	24	21	12	(17)	
	PrecStd	76	13	23	15	13	15	21	27	28	32	19	17	20	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-0.5	-0.3	3.5	10.4	21.2	25.5	28.0	26.7	20.9	14.1	4.7	3.1	(19)	
		MCWB	-1.4	-1.1	1.1	5.5	12.2	15.9	17.6	17.8	15.0	11.3	3.2	1.8	(20)	
	2%	DB	-4.4	-4.5	0.4	6.6	16.5	21.8	24.7	23.3	17.6	10.1	2.7	0.5	(21)	
		MCWB	-5.0	-5.2	-1.0	3.4	9.6	13.8	16.5	16.4	13.6	7.9	1.5	-0.4	(22)	
	5%	DB	-7.5	-9.0	-2.0	4.1	12.7	18.9	22.3	20.9	14.8	7.7	1.3	-2.1	(23)	
		MCWB	-8.0	-9.7	-3.2	1.7	7.6	12.4	15.2	15.3	11.7	5.7	0.4	-3.1	(24)	
	10%	DB	-10.9	-12.1	-4.7	2.0	9.2	16.2	19.8	18.6	12.6	6.0	-0.2	-4.8	(25)	
		MCWB	-11.4	-12.7	-5.7	0.2	5.6	11.1	14.2	14.2	10.0	4.4	-1.1	-5.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.1	-1.2	1.4	5.7	12.5	18.0	19.0	19.0	16.6	11.3	3.5	2.0	(27)	
		MCDB	-0.1	-0.6	3.1	9.2	20.6	21.6	24.8	23.9	19.4	13.8	4.3	3.0	(28)	
	2%	WB	-5.0	-5.2	-0.8	3.6	10.0	15.0	17.5	17.5	13.9	8.3	1.7	-0.3	(29)	
		MCDB	-4.4	-4.5	0.5	6.1	15.8	20.3	22.6	22.1	16.3	9.8	2.5	0.6	(30)	
	5%	WB	-8.0	-9.6	-3.2	1.9	7.8	13.0	16.1	16.1	12.1	6.0	0.4	-3.0	(31)	
		MCDB	-7.5	-9.1	-2.0	3.9	12.3	18.5	21.3	19.8	14.7	7.3	1.2	-2.2	(32)	
	10%	WB	-11.4	-12.7	-5.8	0.3	5.8	11.1	14.7	14.6	10.1	4.5	-1.1	-5.5	(33)	
		MCDB	-10.9	-12.1	-4.9	2.1	9.2	15.9	19.4	18.3	12.3	5.8	-0.2	-4.8	(34)	
(35) Mean Daily Temperature Range	MDBR		8.0	9.1	10.1	9.2	8.1	10.0	10.1	9.2	7.1	5.2	5.8	7.2	(35)	
	5% DB	MCDBR	9.5	10.7	11.2	11.0	15.1	15.5	14.6	13.1	10.8	7.8	5.9	6.7	(36)	
		MCWBR	9.4	10.5	10.2	8.6	9.2	9.1	7.7	7.4	7.3	6.2	5.7	6.4	(37)	
	5% WB	MCDBR	9.6	10.5	11.0	10.4	14.4	13.9	12.7	11.7	9.9	7.4	5.9	6.6	(38)	
		MCWBR	9.5	10.4	10.1	8.4	9.1	9.1	7.6	7.3	7.3	6.3	5.9	6.4	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.216	0.244	0.269	0.358	0.359	0.347	0.364	0.354	0.329	0.290	0.248	0.206	(40)	
	taud		2.156	2.232	2.209	1.983	2.193	2.432	2.418	2.460	2.501	2.493	2.173	2.054	(41)	
	Ebn at Noon		661	814	886	837	871	890	864	849	819	759	592	532	(42)	
	Edh at Noon		47	72	99	149	130	104	104	93	77	57	47	37	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.63	1.64	3.31	4.95	5.39	5.17	4.77	3.79	2.32	1.18	0.52	0.36	(44)	
	RadStd		0.05	0.12	0.29	0.45	0.63	0.48	0.39	0.32	0.19	0.09	0.07	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	+0.93	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page