

INUKJUAK, QC, Canada

WMO: 719070

Lat: 58.4672N

Lon: 78.0786W

Elev: 80

StdP: 14.65

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-32.3	-28.4	-40.3	0.5	-32.0	-36.2	0.7	-28.0	35.3	-2.3	31.5	1.6	4.6	50	1.006

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	70.8	58.3	66.7	56.2	62.9	54.6	60.3	67.8	57.8	64.6	55.2	61.6	12.1	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.1	69.7	63.1	54.3	62.9	60.3	51.9	57.6	57.3	26.7	68.3	25.0	64.6	23.4	61.7	68.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 33.3	29.6	26.5	DB	-37.7	77.7	4.3	3.5	-40.8	80.2	-43.3	82.2	-45.7	84.2	-48.8	86.7	(4)
(5)			WB	-37.8	64.1	4.2	2.4	-40.9	65.8	-43.3	67.2	-45.7	68.5	-48.8	70.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.7	-9.3	-11.8	-2.4	13.8	30.3	42.8	52.2	51.1	43.2	33.8	21.0	6.1	
	DBStd	23.98	11.42	10.65	12.88	11.13	8.68	7.93	6.63	5.38	4.94	6.08	8.86	13.02	
	HDD50	10190	1838	1731	1625	1087	615	247	52	49	211	504	869	1362	
	HDD65	15426	2303	2151	2090	1537	1077	666	400	433	654	969	1319	1827	
	CDD50	242	0	0	0	0	3	31	119	82	7	0	0	0	
	CDD65	4	0	0	0	0	0	0	3	1	0	0	0	0	
	CDH74	38	0	0	0	0	1	4	24	8	1	0	0	0	
	CDH80	1	0	0	0	0	0	0	1	0	0	0	0	0	
Wind	WSAvg	13.1	12.3	11.8	13.0	13.4	13.3	12.7	12.4	12.6	14.0	13.8	13.5	13.8	
Precipitation	PrecAvg	19.7	0.8	0.8	1.5	0.9	1.1	1.5	1.7	2.3	3.2	2.2	1.9	1.5	
	PrecMax	30.5	2.8	1.9	9.0	1.9	2.9	2.6	4.7	5.0	6.2	4.7	4.1	3.5	
	PrecMin	11.5	0.0	0.1	0.0	0.0	0.2	0.5	0.1	0.4	0.9	0.7	0.6	0.4	
	PrecStd	4.0	0.7	0.6	2.0	0.5	0.7	0.6	1.0	0.9	1.3	0.9	0.6	0.8	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.4	22.5	33.7	40.1	65.6	73.5	77.4	74.3	61.4	51.3	39.1	32.8	
		MCWB	24.6	21.9	32.7	37.1	52.7	58.7	60.8	61.3	54.4	48.1	38.1	31.9	
	2%	DB	18.7	14.9	26.9	35.8	54.1	67.4	72.1	68.0	55.7	46.0	35.6	29.8	
		MCWB	17.7	14.3	25.8	33.9	46.8	54.2	58.5	58.8	50.7	43.9	34.8	28.9	
	5%	DB	13.8	10.0	22.2	33.4	46.7	62.5	68.0	63.8	52.6	43.3	33.9	27.2	
		MCWB	13.2	9.4	21.2	32.0	42.2	52.1	56.6	56.6	49.1	41.7	32.8	26.2	
	10%	DB	8.3	5.0	16.8	30.6	41.1	57.5	64.2	60.0	50.2	41.2	32.3	24.6	
		MCWB	7.7	4.3	15.9	29.3	38.0	49.6	55.4	54.2	47.7	39.7	31.2	23.6	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.0	21.8	32.8	37.6	54.2	61.3	63.4	63.5	56.4	49.0	38.0	32.0
			MCDB	25.5	22.5	34.4	39.6	65.2	69.9	73.4	69.6	59.6	50.7	38.7	32.6
2%		WB	17.8	14.2	25.8	34.3	46.9	56.2	60.2	60.6	51.8	44.4	34.9	29.0	
		MCDB	18.5	14.6	26.7	35.6	53.1	64.8	68.5	67.0	54.0	45.6	35.4	29.6	
5%		WB	13.2	9.4	21.2	32.1	42.3	52.7	58.1	57.5	49.7	42.0	33.1	26.3	
		MCDB	13.8	9.9	22.2	33.2	46.7	61.9	65.9	62.7	51.7	43.2	33.7	27.1	
10%		WB	7.6	4.2	16.0	29.3	38.1	49.5	55.8	54.7	47.9	40.0	31.3	23.6	
		MCDB	8.2	4.8	16.8	30.6	40.9	57.4	63.0	59.0	50.0	41.1	32.3	24.6	
Mean Daily Temperature Range	5% DB	MDBR	12.6	13.7	15.2	14.0	10.8	15.0	14.3	11.1	8.6	7.3	10.0	12.1	
		MCDBR	16.1	17.1	17.1	13.4	20.2	24.7	21.6	18.6	12.6	9.6	7.2	10.4	
		MCWBR	16.1	17.0	16.9	12.7	13.8	13.8	10.8	10.1	8.5	8.2	7.5	10.6	
	5% WB	MCDBR	16.2	17.1	17.2	13.1	19.6	23.3	19.3	16.3	10.5	8.9	7.2	10.7	
		MCWBR	16.2	16.9	17.0	12.5	13.7	14.0	11.2	10.1	8.0	8.2	7.6	10.9	
Clear-Sky Solar Irradiance	taub	0.220	0.250	0.295	0.342	0.342	0.351	0.368	0.355	0.347	0.305	0.254	0.196		
	taud	2.083	2.140	2.080	1.991	2.175	2.401	2.431	2.474	2.441	2.474	2.195	2.086		
	Ebn at Noon	199	249	266	271	281	281	273	269	251	232	182	173		
	Edh at Noon	16	25	36	47	42	34	32	29	26	18	14	11		
All-Sky Solar Radiation	RadAvg	180	489	981	1464	1678	1819	1641	1231	764	364	123	80		
	RadStd	16	40	100	177	189	158	148	86	63	39	17	11		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page