

CORAL HARBOUR, NU, Canada

WMO: 719150

Lat: 64.188N

Lon: 83.349W

Elev: 204

StdP: 14.59

Time Zone: -5.00 (W05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-41.1	-38.3	-47.8	0.3	-40.8	-45.6	0.4	-38.0	35.2	-9.4	29.7	-11.9	9.1	330	1.044

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.9	66.4	55.1	61.8	52.6	58.4	51.0	56.0	64.4	53.7	60.7	51.6	57.4	12.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
51.5	57.0	57.9	49.5	52.8	56.1	47.7	49.3	54.2	23.9	64.6	22.5	60.8	21.2	57.5	63.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
31.7	27.9	23.7	-44.3	73.6	4.1	3.3	-47.2	76.0	-49.6	77.9	-51.9	79.7	-54.9	82.1		
			-44.3	59.8	4.0	2.2	-47.2	61.4	-49.6	62.7	-51.9	63.9	-54.8	65.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.8	-20.1	-20.9	-12.2	4.2	21.8	38.4	50.7	47.0	36.1	22.5	5.5	-9.6
	DBStd	26.67	11.63	10.27	12.01	10.79	8.45	6.40	5.30	4.90	5.56	8.26	12.69	13.64
	HDD50	13312	2173	1985	1929	1375	873	352	56	121	416	852	1334	1846
	HDD65	18679	2638	2405	2394	1825	1338	797	445	559	866	1317	1784	2311
	CDD50	107	0	0	0	0	0	5	76	26	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	9	0	0	0	0	0	0	9	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	11.4	11.3	11.1	11.2	11.0	11.5	11.0	10.2	10.7	11.6	12.3	13.0	12.3
Precipitation	PrecAvg	11.9	0.4	0.4	0.5	0.7	0.7	1.1	1.7	2.2	1.6	1.5	0.9	0.6
	PrecMax	21.5	0.9	1.3	2.3	2.6	1.7	3.3	4.4	5.0	3.9	6.5	2.0	1.5
	PrecMin	7.7	0.0	0.0	0.0	0.1	0.1	0.0	0.1	0.6	0.2	0.2	0.3	0.0
	PrecStd	2.6	0.2	0.3	0.4	0.4	0.4	0.7	1.1	1.0	0.9	1.0	0.5	0.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.1	12.0	22.3	32.9	39.9	64.7	74.9	69.2	54.8	36.9	31.4	28.7
		MCWB	19.2	11.3	21.4	32.0	36.5	53.7	59.1	56.0	47.5	36.1	31.0	28.4
	2%	DB	9.6	3.7	15.8	28.1	36.2	57.3	69.1	62.3	50.2	35.1	28.8	21.3
		MCWB	8.6	2.7	14.8	26.8	34.2	48.7	56.3	53.0	44.8	34.3	28.3	20.6
	5%	DB	2.0	-1.5	11.1	24.4	34.5	52.6	64.9	58.8	46.8	34.0	26.9	16.7
		MCWB	1.0	-2.3	10.2	23.3	32.9	45.8	54.3	51.5	43.5	33.3	26.4	16.1
	10%	DB	-2.7	-5.6	6.0	20.7	32.9	49.1	61.1	55.7	44.2	32.8	24.0	10.5
		MCWB	-3.4	-6.4	5.1	19.5	31.6	43.6	52.4	49.8	41.7	32.2	23.2	9.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.4	11.3	21.6	32.6	36.9	54.1	59.8	57.8	49.5	36.5	31.2	28.5
		MCDB	20.3	11.7	22.3	33.0	39.2	63.8	71.9	63.5	52.8	36.6	31.3	28.8
	2%	WB	8.8	2.8	14.9	27.0	34.6	49.5	57.2	54.5	45.9	34.6	28.6	20.5
		MCDB	9.8	3.7	15.7	28.1	35.9	56.2	67.1	60.8	48.3	34.9	28.8	21.1
	5%	WB	1.1	-2.2	10.2	23.3	33.2	46.2	55.2	52.3	43.9	33.4	26.4	16.1
		MCDB	1.8	-1.5	11.1	24.3	34.3	52.0	63.4	57.3	46.4	33.8	26.9	16.7
	10%	WB	-3.5	-6.3	5.2	19.6	31.8	43.6	53.1	50.4	42.0	32.3	23.3	9.7
		MCDB	-2.8	-5.6	6.0	20.7	32.8	48.7	60.2	54.8	44.2	32.7	23.9	10.4
Mean Daily Temperature Range	5% DB	MDBR	12.5	12.6	15.2	16.2	11.0	10.8	14.9	12.5	9.6	9.7	13.8	13.6
		MCDBR	15.7	15.6	16.3	13.2	8.9	17.9	22.1	18.2	14.6	6.8	12.1	15.8
		MCWBR	15.4	15.4	16.2	12.8	7.9	11.5	11.7	10.9	10.8	6.8	12.4	15.8
	5% WB	MCDBR	15.6	15.5	16.3	13.1	8.1	17.4	19.9	16.2	13.1	6.8	12.4	15.9
		MCWBR	15.3	15.4	16.2	12.8	7.4	11.6	11.4	10.7	10.3	7.0	12.7	15.9
Clear-Sky Solar Irradiance	taub	0.194	0.228	0.275	0.337	0.339	0.326	0.359	0.346	0.317	0.273	0.173	0.158	
	taud	1.864	2.147	2.125	1.978	2.111	2.365	2.399	2.441	2.423	2.225	1.934	1.892	
	Ebn at Noon	112	225	256	260	274	283	268	262	245	199	127	59	
	Edh at Noon	9	18	30	44	42	34	32	28	23	17	8	3	
All-Sky Solar Radiation	RadAvg	50	287	837	1528	1764	1855	1722	1147	661	218	65	19	
	RadStd	7	25	44	60	156	177	160	93	67	20	11	1	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page